



---

**Britt Surveying and Mapping, LLC**

1438 SW Main Blvd • Lake City, FL 32025

386-752-7163 P • 386-752-5573 F • [www.brittsurvey.com](http://www.brittsurvey.com)

03/16/2023

L-29312

Re: 08898-122

Exceptions Realty

To Whom It May Concern:

The finished slab elevation is found to be 89.40 feet. The minimum floor elevation per the building permit is shown to be one foot above the road and the centerline of SW Milkweed Court is 87.05 feet. All elevations are shown in NAVD 88 datum.

Sincerely,

A handwritten signature in blue ink, appearing to read "L. Scott Britt", is written over the printed name.

L. Scott Britt

LS 5757