



August 3, 2021

Allen Strickland  
Wade Custom Homes  
1431 E. Wade Street,  
Trenton, FL 32693

SUBJECT: ELEVATION LETTER  
Parcel No. 27-6S-16-03951-137  
504 SW Vixen Lane, Fort White, Florida

To Whom It May Concern:


Parcel No. 27-6S-16-03951-137 is located in Flood Zone X. The property naturally slopes toward a low in the middle of the property. The structure will be elevated on a concrete pad. Stormwater will flow around the structure to the south.

**Requirements For Structure To Be Protected from the Base Flood Event:**

**The finished floor elevation for the foundation of the structure shall be at 68.5 feet NAVD and above the highest adjacent natural grade at the proposed building site.** Any disturbed area around the proposed structure shall be graded to direct all runoff to the south.

Sincerely,

Terry R. White, Jr., P.E.  
Water Resources Engineer



I certify that the finished floor elevation listed above will protect the structure against water damage from a base flood event, as defined in Article 8 of the Land Development Regulations.

Digitally signed by Terry R White  
Date: 2021.08.03 07:38:27-04'00'

Terry R. White, Jr., P.E.

**8/3/21**

Date