

March 27, 2024

Heather Raulerson
369 SW Pinehurst Drive
Lake City, FL 32024

Subject: Lot 9 Forest Country, 6th Addition Elevation Letter

Dear Josh:

Daniel & Gore, LLC has performed a vertical survey on Lot 9, Forest Country, 6th Addition, Columbia County, Florida from a benchmark being a 60d nail in a 14" Oak Tree on site (elevation – 90.88', NGVD 1988) and have determined the following:

- The Subdivision plat requires the minimum finish floor elevation to be 89.5'.
- The finish floor elevation of the foundation is at 89.9', being the 0.4' above the minimum finish floor requirement.

If you have any questions, please call me.

Sincerely,

Scott Daniel, PSM