



Britt Surveying and Mapping, LLC

1438 SW Main Blvd • Lake City, FL 32025

386-752-7163 P • 386-752-5573 F • www.brittsurvey.com

12/13/2022

Permit # 000045726

L-29112

Re: 03099-208

Mike Roberts

To Whom It May Concern:

The finished slab elevation is found to be 99.77 feet. The minimum floor elevation per the building permit is shown to be 101.9 feet. All elevations are shown in NAVD 88 datum.

Sincerely,

L. Scott Britt
L. Scott Britt

LS 5757