

37827



---

**Britt Surveying and Mapping, LLC**  
2086 SW Main Blvd Ste 112 • Lake City, FL 32025  
386-752-7163 P • 386-752-5573 F • [www.brittsurvey.com](http://www.brittsurvey.com)

07/22/19

L-25945

Re: Lot 26 Southern Meadows Phase 2

Luis Alicea

To Whom It May Concern:

The top of the finished floor elevation is found to be 86.51 feet on said lot 26. The minimum floor elevation per the building permit #37827 is 84.00 feet. The bottom of the meter box is found to be 84.36 feet. The elevations shown hereon are based on plat datum (NGVD 29).

Sincerely,

A handwritten signature in black ink, appearing to read "L. Scott Britt", is written over a faint circular embossed seal. The signature is fluid and cursive.

L. Scott Britt  
LS 5757

*Sealed*