

Mark Disosway, P.E.

163 SW Midtown Place, Suite 103 Lake City, FL 32025, Ph (386) 754-5419

1/7/20

Columbia County Building Department

Re: Aaron Simque Homes / Aaron Simque Res. / Lot 4 West Paces Columbia County, FL

To whom it may concern:

This letter is in reference to inspection issues on the above referenced project.

1. On the engineering we provided we called for (2) 1.75" x 9.25" LVL headers @ garage doors. It is ok to use (3) 2x12 sp #2 instead with 9' max span.
2. On the engineering we provided we called for (2) 1.75" x 9.25" LVL beam @ rear porch. It is ok to use (3) 2x12 sp #2 instead with 14' max span.

Mark Disosway, PE
Florida Professional Engineer #53915