



Load Short Form

Entire House

High Springs Electric

Job:
 Date: March 21, 2024
 By: Donna Brackeen
 Plan: Litchfield Classic GR

Project Information

For: Brockway Residence, Red Door Homes
 1108 SW Central Terr., Ft. White, FL 32038

Design Information

	Htg	Clg	Infiltration	
Outside db (°F)	33	92	Method	Simplified
Inside db (°F)	68	75	Construction quality	Average
Design TD (°F)	35	17	Fireplaces	0
Daily range	-	M		
Inside humidity (%)	50	50		
Moisture difference (gr/lb)	29	43		

HEATING EQUIPMENT

Make Trane
 Trade TRANE
 Model 4TWR5036H1
 AHRI ref 211215794
 Efficiency 7.8 HSPF2
 Heating input
 Heating output 31800 Btuh @ 47°F
 Temperature rise 0 °F
 Actual air flow 0 cfm
 Air flow factor 0 cfm/Btuh
 Static pressure 0.50 in H2O
 Space thermostat
 Capacity balance point = 24 °F

COOLING EQUIPMENT

Make Trane
 Trade TRANE
 Cond 4TWR5036H1
 Coil TEM6A0D60H51++TDR
 AHRI ref 211215794
 Efficiency 12.0 EER2, 14.3 SEER2
 Sensible cooling 23800 Btuh
 Latent cooling 10200 Btuh
 Total cooling 34000 Btuh
 Actual air flow 1133 cfm
 Air flow factor 0.045 cfm/Btuh
 Static pressure 0.50 in H2O
 Load sensible heat ratio 0.85

ROOM NAME	Area (ft²)	Htg load (Btuh)	Clg load (Btuh)	Htg AVF (cfm)	Clg AVF (cfm)
(Rest of House)	1704	22576	26180	0	1184
(Unconditioned)	459	0	0	0	0
Entire House	2162	22576	25050	0	1133
Other equip loads		0	0		
Equip. @ 0.97 RSM			24399		
Latent cooling			4420		
TOTALS	2162	22576	28819	0	1133

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.



Load Short Form (Rest of House) High Springs Electric

Job:
Date: March 21, 2024
By: Donna Brackeen
Plan: Litchfield Classic GR

Project Information

For: Brockway Residence, Red Door Homes
1108 SW Central Terr., Ft. White, FL 32038

Design Information

	Htg	Clg	Infiltration	
Outside db (°F)	33	92	Method	Simplified
Inside db (°F)	68	75	Construction quality	Average
Design TD (°F)	35	17	Fireplaces	0
Daily range	-	M		
Inside humidity (%)	50	50		
Moisture difference (gr/lb)	29	43		

HEATING EQUIPMENT

Make	n/a
Trade	n/a
Model	n/a
AHRI ref	n/a
Efficiency	n/a
Heating input	
Heating output	0 Btuh
Temperature rise	0 °F
Actual air flow	0 cfm
Air flow factor	0 cfm/Btuh
Static pressure	0 in H2O
Space thermostat	n/a

COOLING EQUIPMENT

Make	n/a
Trade	n/a
Cond	n/a
Coil	n/a
AHRI ref	n/a
Efficiency	n/a
Sensible cooling	0 Btuh
Latent cooling	0 Btuh
Total cooling	0 Btuh
Actual air flow	0 cfm
Air flow factor	0 cfm/Btuh
Static pressure	0 in H2O
Load sensible heat ratio	0

ROOM NAME	Area (ft²)	Htg load (Btuh)	Clg load (Btuh)	Htg AVF (cfm)	Clg AVF (cfm)
m bd	291	4469	4519	0	204
kit dining	270	3674	6520	0	295
pntry	33	1250	457	0	21
bd2	153	2017	1845	0	83
ent	46	0	0	0	0
family	264	564	2441	0	110
m bath	97	1633	860	0	39
wic	41	161	170	0	8
laundry	45	638	903	0	41
bath	71	973	784	0	35
foyer	72	1562	630	0	29
flex	125	1698	3307	0	150
bd3	148	3936	3744	0	169
hall	47	0	0	0	0

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.



(Rest of House)	1704	22576	26180	0	1184
Other equip loads		0	0		
Equip. @ 0.97 RSM			25500		
Latent cooling			4420		
TOTALS	1704	22576	29920	0	1184


Private Provider Plan Review
Completed by Michael Williams
Licenses: BU2215, PX4929, BN7822
Or Associated Duly Authorized Representative



Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.



12'-0"





Manual S Compliance Report

Entire House

High Springs Electric

Private Provider Plan Review
Completed by Michael Williams
Licenses: BU2215, PX4929, BN7822
Or Associated Duty Authorized Representative



Job:
Date: March 21, 2024
By: Donna Brackeen
Plan: Litchfield Classic GR

Project Information

For: Brockway Residence, Red Door Homes
1108 SW Central Terr., Ft. White, FL 32038

Cooling Equipment

Design Conditions

Outdoor design DB:	92.4°F	Sensible gain:	25050	Btuh	Entering coil DB:	77.4°F
Outdoor design WB:	75.8°F	Latent gain:	4420	Btuh	Entering coil WB:	63.6°F
Indoor design DB:	75.0°F	Total gain:	29470	Btuh		
Indoor RH:	50%	Estimated airflow:	1133	cfm		

Manufacturer's Performance Data at Actual Design Conditions

Equipment type:	Split ASHP		
Manufacturer:	Trane	Model:	4TWR5036H1+TEM6A0D60H51++TDR
Actual airflow:	1133	cfm	
Sensible capacity:	23800	Btuh	95% of load
Latent capacity:	10200	Btuh	231% of load
Total capacity:	34000	Btuh	115% of load SHR: 70%

Heating Equipment

Design Conditions

Outdoor design DB:	33.3°F	Heat loss:	22576	Btuh	Entering coil DB:	68.0°F
Indoor design DB:	68.0°F					

Manufacturer's Performance Data at Actual Design Conditions

Equipment type:	Split ASHP		
Manufacturer:	Trane	Model:	4TWR5036H1+TEM6A0D60H51++TDR
Actual airflow:	0	cfm	
Output capacity:	31800	Btuh	141% of load
Supplemental heat required:	0	Btuh	
Capacity balance:	24	°F	
Economic balance:	-99	°F	

Meets all requirements of ACCA Manual S.



Right-Suite® Universal 2023 23.0.05 RSU07253

...ectric\Red Door Homes\Litchfield Classic GR.rup Calc = MJ8 Front Door faces: W

2024-Mar-21 15:47:43

Page 1



Duct System Summary

Entire House

High Springs Electric

Job:
 Date: March 21, 2024
 By: Donna Brackeen
 Plan: Litchfield Classic GR

Project Information

For: Brockway Residence, Red Door Homes
 1108 SW Central Terr., Ft. White, FL 32038

	Heating	Cooling
External static pressure	0.50 in H ₂ O	0.50 in H ₂ O
Pressure losses	0.18 in H ₂ O	0.18 in H ₂ O
Available static pressure	0.32 in H ₂ O	0.32 in H ₂ O
Supply / return available pressure	0.217 / 0.103 in H ₂ O	0.217 / 0.103 in H ₂ O
Lowest friction rate	0.099 in/100ft	0.099 in/100ft
Actual air flow	0 cfm	1133 cfm
Total effective length (TEL)	323 ft	

Supply Branch Detail Table

Name	Design (Btuh)	Htg (cfm)	Clg (cfm)	Design FR	Diam (in)	H x W (in)	Duct Matl	Actual Ln (ft)	Ftg.Eqv Ln (ft)	Trunk
bath	c 784	0	35	0.138	4.0	0x 0	VIFx	36.9	120.0	st5
bd2	c 1845	0	83	0.099	6.0	0x 0	VIFx	59.2	160.0	st4
bd3-A	c 3744	0	169	0.130	8.0	0x 0	VIFx	46.7	120.0	st5
family	c 2441	0	110	0.120	7.0	0x 0	VIFx	46.6	135.0	st3
flex	c 3307	0	150	0.165	7.0	0x 0	VIFx	31.7	100.0	st2
foyer	c 630	0	29	0.167	4.0	0x 0	VIFx	30.2	100.0	st2
kit dining	c 3260	0	147	0.120	7.0	0x 0	VIFx	45.7	135.0	st3
kit dining-A	c 3260	0	147	0.119	7.0	0x 0	VIFx	47.1	135.0	st3
laundry	c 903	0	41	0.196	4.0	0x 0	VIFx	15.7	95.0	st1
m bath	c 860	0	39	0.205	4.0	0x 0	VIFx	10.8	95.0	st1
m bd	c 2260	0	102	0.162	6.0	0x 0	VIFx	18.8	115.0	st1
m bd-A	c 2260	0	102	0.158	6.0	0x 0	VIFx	22.7	115.0	st1
prtry	c 457	0	21	0.099	4.0	0x 0	VIFx	59.5	160.0	st4
wic	c 170	0	8	0.202	4.0	0x 0	VIFx	12.8	95.0	st1

Supply Trunk Detail Table

Name	Trunk Type	Htg (cfm)	Clg (cfm)	Design FR	Veloc (fpm)	Diam (in)	H x W (in)	Duct Material	Trunk
st5	Peak AVF	0	205	0.130	587	8.0	0 x 0	VinIFlx	st2
st2	Peak AVF	0	383	0.130	488	12.0	0 x 0	VinIFlx	
st4	Peak AVF	0	104	0.099	390	7.0	0 x 0	VinIFlx	st3
st3	Peak AVF	0	509	0.099	477	14.0	0 x 0	VinIFlx	st1
st1	Peak AVF	0	801	0.099	574	16.0	0 x 0	VinIFlx	

Return Branch Detail Table

Name	Grille Size (in)	Htg (cfm)	Clg (cfm)	TEL (ft)	Design FR	Veloc (fpm)	Diam (in)	H x W (in)	Stud/Joist Opening (in)	Duct Matl	Trunk
rb2	0x 0	0	83	95.4	0.108	425	6.0	0x 0		VIFx	rt2
rb3	0x 0	0	169	103.8	0.099	485	8.0	0x 0		VIFx	rt2
rb4	0x 0	0	150	97.6	0.105	560	7.0	0x 0		VIFx	rt2
rb5	0x 0	0	251	57.8	0.178	568	9.0	0x 0		VIFx	rt1
rb1	0x 0	0	531	56.6	0.182	497	14.0	0x 0		VIFx	rt1

Return Trunk Detail Table

Name	Trunk Type	Htg (cfm)	Clg (cfm)	Design FR	Veloc (fpm)	Diam (in)	H x W (in)	Duct Material	Trunk
rt2	Peak AVF	0	402	0.099	512	12.0	0 x 0	VinIFlx	rt1
rt1	Peak AVF	0	1184	0.099	543	20.0	0 x 0	VinIFlx	

Private Provider Plan Review
 Completed by Michael Williams
 Licenses: BU2215, PX4929, BN7822
 Or Associated Duty Authorized Representative

