

38362

CAROL CHADWICK, P.E.

*Civil Engineer*

1208 S.W. Fairfax Glen

Lake City, FL 32025

307.680.1772

ccpewyo@gmail.com

www.carolchadwickpe.com

August 8, 2019

Chris Williams

Chrisdw84@gmail.com

re: ELEVATION CERTIFICATION – 4601 SW CR 240, Lake City, FL, Colt Dunlap

As requested, I inspected the building site for the proposed construction at the above referenced site. The natural topography of the property slopes away from SW CR 240 towards Rose Creek located in the approximate center of the lot. Per the SRWMD Flood Report, Rose Creek is covered by an AE flood zone. Per a survey By Daniel & Gore, LLC, the home will be located outside of the flood zone. The BFE for the flood zone is 62.00.


The proposed building site is lower than the nearest adjacent road, SW CR 240. The proposed minimum finished floor elevation of the structure is 67.00 feet. The finished floor elevation will be approximately 32" above the adjacent ground elevation at the building site. The area around the proposed structure shall be graded to convey all storm water runoff around and away from the building site.

I certify that the minimum finished floor elevation listed above will protect the structure against water damage from a base flood event, as defined in Article 8 of the Land Development Regulations.

Should you have any questions, please don't hesitate to contact me.

Respectfully,

Carol Chadwick, P.E.



Cc: Brandon Stubbs, bstubbs@columbiacountyfla.com  
Troy Crews, troy\_crews@columbiacountyfla.com

CC Job #FL19096