



---

**Britt Surveying and Mapping, LLC**

2086 SW Main Blvd Ste 112 • Lake City, FL 32025  
386-752-7163 P • 386-752-5573 F • [www.brittsurvey.com](http://www.brittsurvey.com)

10/02/2020

Permit # 000040075

Lot 31 of Cannon Creek Place

L-26990

Trent Giebeig

To whom it may concern,

The elevation of the top of the slab on Lot 31 is found to be 99.87 feet. The minimum floor elevation is shown to be 98 feet per the permit. The Elevations shown hereon are based on NAVD 88 Datum.

*Sealed*  
Sincerely,

  
L. Scott Britt  
LS 5757