



Britt Surveying and Mapping, LLC
2086 SW Main Blvd Ste 112 • Lake City, FL 32025
386-752-7163 P • 386-752-5573 F • www.brittsurvey.com

02/15/2022

Permit # 000043364

L-28311

Bryan Zecher

Re: Lot 17 Wester Wood

To Whom It May Concern:

The top of the finished slab on Lot 17 is found to be 97.03 feet. The center of SW Phlox Glen is found to be 91.57 feet. The building permit shows the minimum floor elevation to be one foot above the road. The elevations shown hereon are based on NAVD 88 datum.

Sincerely,

A handwritten signature in black ink, appearing to read "L. Scott Britt", is written over a faint, circular, textured background that resembles a surveyor's seal or a stamp.

L. Scott Britt
LS 5757