



CAL-TECH TESTING, INC.

ENGINEERING & TESTING LABORATORY

P.O. Box 1625, Lake City, FL 32056-1625
2907 Spring Glen Road • Jacksonville, FL 32207

Lake City • (386) 755-3633
Fax • (386) 752-5456

Jacksonville • (904) 381-8901
Fax • (904) 381-8902

JOB NO.: 26-133
DATE TESTED: 1/16/26

54796

REPORT OF IN-PLACE DENSITY TEST

ASTM METHOD: (D-2922) Nuclear (D-2937) Drive Cylinder Other

PROJECT: 189 S.W. Thames st.

CLIENT: FL Homes

GENERAL CONTRACTOR: SAC **EARTHWORK CONTRACTOR:** SAC

SOIL USE (SEE NOTE): I **SPECIFICATION REQUIREMENTS:** 95%

TECHNICIAN: S. Dilger

MODIFIED (ASTM D-1557): **STANDARD (ASTM D-698):** _____

TEST NO.	TEST LOCATION	TEST:		PROCTOR NO.	WET DENS. LBS./CU.FT.	DRY DENS. LBS./CU.FT.	MOIST PERCENT	% MAX. DENS.
		DEPTH	ELEV. LIFT					
	16ft E 7ft S from NW corner	12 in		109.3	119.6	110.3	8.4	101
	12ft W 6ft S from NE corner	12 in		109.3	118.8	108.3	9.5	99
	16ft E 8ft N from SW corner	12 in		109.3	119.1	108.9	9.3	100

REMARKS: _____

PROCTOR NO.	SOIL DESCRIPTION	PROCTOR VALUE	OPT. MOIST.
		109.3	

NOTE: 1. Building Fill 2. Trench Backfill 3. Base Course 4. Subbase/Stabilized Subgrade 5. Embankment 6. Subgrade/Natural Soil 7. Other
The test results presented in this report are specific only to the samples tested at the time of testing. The tests were performed in accordance with generally accepted methods and standards. Since material conditions can vary between test location and change with time, sound judgement should be exercised with regard to the use and interpretation of the data.