

28th November 2023

BUILDING OFFICIAL / INSPECTOR COUNTY BUILDING DEPT.

RE: DRYDEN RESIDENCE

Permit #: 000047377

TO WHOM IT MAY CONCERN:

THE HEADER BEAM AT TOP OF POSTS CAN BE SWAPPED WITH DBL  $2\times12$  SYP BEAM IN LIEU OF THE DBL 1.75''  $\times$  11.25'' Lyl BEAM AS SPECIFIED ON PAGE 6.2

YOURS TRULY, NICHOLAS PAUL GEISLER, ARCHITECT AROOOTOOS