



NFPS



PO BOX 3823
LAKE CITY, FL 32056



PHONE (386) 752-4675
FAX (386) 752-4674



www.nfps.net

DATE: Tuesday, May 03, 2022

TO: Columbia County Building Department

FROM: James B. Smith, PSM – North Florida Professional Services

CC: Keith Eaker

RE: Finished Floor Elevation – 137 SW Bre Ln, Lake City FL 32024

This is to certify that the following elevations of were obtained on the finished floor of a building constructed on Parcel # 33-3S-16-02439-222 at the address of 137 SW Bre Ln., Lake City, FL 32024

Permit # 43222 FFE: 118.70'

The required elevation is 117.40'

James B. Smith, PSM
Florida Certification No. 7355

