



UES Project No: 0210.2300208.0000  
UES Report No: 02-1108316

21

4475 Southwest 35th Terrace, Gainesville, FL 32608 - P: 352.372.3392 - F: 352.336.7914

---

### Inspection Report

**Client:** Hal Ferris  
2210 SW Old Bellamy Road  
Ft. White, FL 32038

**Project:** Ferris Residence - Ft. White, FL  
2210 SW Old Bellamy Road, Ft. White, Columbia County, FL

**Date of Activity:** 10/04/2023

**Technician:** James Brewer

---

As Requested, a Universal Engineering Sciences Technician was present at the above referenced location for the purpose of performing reinforcing steel observation of the concrete foundation utilizing the Profoscope Rebar Locator.

Two locations on two sides of the structure was excavated to a depth below the bottom of the foundation and consisted of approximately 2 feet parallel to the exposed foundation face. The Profoscope Rebar Locator detected two horizontal reinforcing bars approximately two to three inches above the bottom of the foundation and approximately three inches coverage from the face of the foundation wall.

*This test was performed without deviation from ASTM procedures.*

*This report shall not be reproduced, except in full, without the written approval of Universal Engineering Sciences.*