

31 MAY 2022

BUILDING OFFICIAL
COLUMBIA COUNTY, BUILDING DEPT.
COLUMBIA COUNTY COURTHOUSE ANNEX
LAKE CITY, FLORIDA 32055

RE: FOOTE ALTERATIONS
PERMIT Nr.: _____


DEAR SIR:

PLEASE BE ADVISED OF THE FOLLOWING CHANGE FOR THE ABOVE
REFERENCED PROJECT:

IN LIEU OF THE ASSEMBLIES AS SHOWN IN THE CONSTRUCTION DOCUMENTS
FOR THE ROOF OVERBUILD, LATERAL TENSION LOADS SHALL BE
RESTRAINED VIA A CABLE SYSTEM AS DIPICTED IN THE ATTACHED HAND
SKETCH AND AS-BUILT PHOTOS. IN ADDITION, TWO VERTICAL CABLES
SHALL BE INSTALLED FROM THE NEW RIDGE TO THE EXISTING RIDGE TO
RESTRAIN UPLIFT OF THE NEW OVEBUILD ROOF ASSEMBLY

SHOULD YOU HAVE ANY FURTHER QUESTIONS WITH THIS, PLEASE CALL FOR
ASSISTANCE.

YOURS TRULY,
NICHOLAS PAUL GEISLER, ARCHITECT AR0007005



N. P.
GEISL
ER

Digitally signed by: N. P.
GEISLER
DN: CN = N. P. GEISLER
C = US O = AR0007005
OU = ARCHITECT
Date: 2022.05.31 17:17:
50 -05'00'