



Hall's Pump and Well Services, Inc.

904 NW Main Blvd.

Lake City, FL 32055

hallspumpandwell@bellsouth.net

Contractor #

1503

Submitted By

Benjamin D. Dicks

6/2/2020

Parcel ID 17-4S-17-08410-000

Well Letter of Compliance

Property Owners:FORTY SEVEN PROPERTIES INC

Columbia County, 3795 US HIGHWAY 441 , LAKE CITY

Drop pipe size, 1-1/4" inch

4 Inch black steel well casing, 235mm wall thickness

Tank sized, PC 244, 81 gallon, will supply a 23.9 gal. draw down
at 40/60 pressure setting.

All wells will have a pump and tank combination that will be
sufficient for 1 minute of runtime

If you have any questions please call our office @ 386-752-1854

Pump size 1.0 hp, 230 volt, single ph, pump and motor
or 4' in diameter

Benjamin Dicks,

Office Coordinator,

Hall's Pump and Well Services, Inc.

904 NW Main Blvd.

Lake City, FL 32055

(P): (386)752-1854

Thanks,