

DATE 06/21/2010

Columbia County Building Permit

This Permit Must Be Prominently Posted on Premises During Construction

PERMIT

000028672

APPLICANT WENDY GRENNELL PHONE 288-2428

ADDRESS 3104 SW OLD WIRE ROAD FT. WHITE FL 32038

OWNER SHARON HENRY PHONE 497-4247

ADDRESS 236 SW GOLDENROD GLEN FT. WHITE FL 32038

CONTRACTOR RONNIE NORRIS PHONE 623-7716

LOCATION OF PROPERTY 47S, TL HERLONG, TR CHOCTAW, TR GOLDENROD, PROPERTY
AT END ON LEFT

TYPE DEVELOPMENT MH, UTILITY ESTIMATED COST OF CONSTRUCTION 0.00

HEATED FLOOR AREA TOTAL AREA HEIGHT STORIES

FOUNDATION WALLS ROOF PITCH FLOOR

LAND USE & ZONING A-3 MAX. HEIGHT

Minimum Set Back Requirments: STREET-FRONT 30.00 REAR 25.00 SIDE 25.00

NO. EX.D.U. FLOOD ZONE X DEVELOPMENT PERMIT NO.

PARCEL ID 12-6S-16-03816-303 SUBDIVISION TUSTENUGGEE TRAILS UNREC

LOT 3 BLOCK PHASE UNIT TOTAL ACRES 10.07

IH1025/145 Wendy Grennell

Culvert Permit No. Culvert Waiver Contractor's License Number Applicant/Owner/Contractor

EXISTING 10-246 BK HD Y

Driveway Connection Septic Tank Number LU & Zoning checked by Approved for Issuance New Resident

COMMENTS: ONE FOOT ABOVE THE ROADCheck # or Cash CASH

FOR BUILDING & ZONING DEPARTMENT ONLY

(footer/Slab)

Temporary Power Foundation Monolithic
date/app. by date/app. by date/app. by

Under slab rough-in plumbing Slab Sheathing/Nailing
date/app. by date/app. by date/app. by

Framing Insulation
date/app. by date/app. by

Rough-in plumbing above slab and below wood floor Electrical rough-in
date/app. by date/app. by

Heat & Air Duct Peri. beam (Lintel) Pool
date/app. by date/app. by date/app. by

Permanent power C.O. Final Culvert
date/app. by date/app. by date/app. by

Pump pole Utility Pole M/H tie downs, blocking, electricity and plumbing
date/app. by date/app. by date/app. by

Reconnection RV Re-roof
date/app. by date/app. by date/app. by

BUILDING PERMIT FEE \$ 0.00 CERTIFICATION FEE \$ 0.00 SURCHARGE FEE \$ 0.00

MISC. FEES \$ 350.00 ZONING CERT. FEE \$ 50.00 FIRE FEE \$ 48.88 WASTE FEE \$ 67.00

FLOOD DEVELOPMENT FEE \$ FLOOD ZONE FEE \$ 25.00 CULVERT FEE \$ TOTAL FEE 540.88

INSPECTORS OFFICE CLERKS OFFICE

NOTICE: IN ADDITION TO THE REQUIREMENTS OF THIS PERMIT, THERE MAY BE ADDITIONAL RESTRICTIONS APPLICABLE TO THIS PROPERTY THAT MAY BE FOUND IN THE PUBLIC RECORDS OF THIS COUNTY. AND THERE MAY BE ADDITIONAL PERMITS REQUIRED FROM OTHER GOVERNMENTAL ENTITIES SUCH AS WATER MANAGEMENT DISTRICTS, STATE AGENCIES, OR FEDERAL AGENCIES.

"WARNING TO OWNER: YOUR FAILURE TO RECORD A NOTICE OF COMMENCEMENT MAY RESULT IN YOUR PAYING TWICE FOR IMPROVEMENTS TO YOUR PROPERTY. IF YOU INTEND TO OBTAIN FINANCING, CONSULT WITH YOUR LENDER OR AN ATTORNEY BEFORE RECORDING YOUR NOTICE OF COMMENCEMENT."

EVERY PERMIT ISSUED SHALL BECOME INVALID UNLESS THE WORK AUTHORIZED BY SUCH PERMIT IS COMMENCED WITHIN 180 DAYS AFTER ITS ISSUANCE, OR IF THE WORK AUTHORIZED BY SUCH PERMIT IS SUSPENDED OR ABANDONED FOR A PERIOD OF 180 DAYS AFTER THE TIME THE WORK IS COMMENCED. A VALID PERMIT RECIEVES AN APPROVED INSPECTION EVERY 180 DAYS. WORK SHALL BE CONSIDERED NOT SUSPENDED, ABANDONED OR INVALID WHEN THE PERMIT HAS RECIEVED AN APPROVED INSPECTION WITHIN 180 DAYS OT THE PREVIOUS INSPECTION.

The Issuance of this Permit Does Not Waive Compliance by Permittee with Deed Restrictions.

PERMIT APPLICATION / MANUFACTURED HOME INSTALLATION APPLICATION

For Office Use Only

(Revised 1-10-08)

Zoning Official

BLK 18.00.10

Building Official

NO 6-18-10

AP#

1006-37

Date Received

6/11/10

By

GP

Permit #

28672

Flood Zone

X

Development Permit

N/A

Zoning

A-3

Land Use Plan Map Category

A-3

Comments

FEMA Map#

N/A

Elevation

N/A

Finished Floor

1 above Rd

River

N/A

In Floodway

N/A

Site Plan with Setbacks Shown

EH #

10-0746

EH Release

Well letter

Existing well

Recorded Deed or Affidavit from land owner

Letter of Auth. from installer

State Road Access

Parent Parcel #

STUP-MH

F W Comp. letter

IMPACT FEES: EMS

Fire

Corr

Road/Code

School

= TOTAL

VF

Property ID #

12-65-16-03816-303

Subdivision

Tusknage Trails Unrec. S/D Lot 3

New Mobile Home

✓

Used Mobile Home

MH Size

42x60x12

Year

2010

Applicant

Wendy Grennell

Phone #

386-288-2428

Address

3104 SW Old Wire Road

Ft White FL 32038

Name of Property Owner

Sharon Henry

Phone#

386-497-4247

911 Address

236 SW Goldenrod Gln

Ft White 32038

Circle the correct power company -

FL Power & Light

Clay Electric

(Circle One) -

Suwannee Valley Electric

Progress Energy

Name of Owner of Mobile Home

Sharon Henry

Phone #

386-497-4247

Address

859 SW Roanoke Terr

Ft White FL 32038

Relationship to Property Owner

same

Current Number of Dwellings on Property

0

Lot Size

Total Acreage

10.07

Do you : Have

Existing Drive

Private Drive

Culvert Permit

Culvert Waiver (Circle one)

(Currently using)

(Blue Road Sign)

(Putting in a Culvert)

(Not existing but do not need a Culvert)

Is this Mobile Home Replacing an Existing Mobile Home

No

Driving Directions to the Property

47 South to Herlong turn (L)

cross over Old Wire Rd to SW Choctaw turn (R)

to SW Goldenrod turn (R) property at end

on (L)

Name of Licensed Dealer/Installer

Ronnie Norri's

Phone #

386-623-7116

Address

1004 SW Charles Terr

Lake City FL 32024

License Number

IH 1025/145/1

Installation Decal #

823

COLUMBIA COUNTY PERMIT WORKSHEET

page 1 of 2

These worksheets must be completed and signed by the Installer.
Submit the originals with the packet.

Installer Ronn & Norris License # TH 1025/195/1

New Home ☒ Used Home ☐

Home installed to the Manufacturer's Installation Manual ☒

Home is installed in accordance with Rule 15-C ☒

Single wide ☐ Wind Zone II ☒ Wind Zone III ☐

Double wide ☐ Installation Decal # 823

Triple/Quad ☒ Serial # ordered


911 Address where home is being installed. 236 SW Goldenrod Blvd

Manufacturer JACOBSSEN Length x width 42x 60x 40

NOTE: If home is a single wide fill out one half of the blocking plan
If home is a triple or quad wide sketch in remainder of home

I understand Lateral Arm Systems cannot be used on any home (new or used)
where the sidewall ties exceed 5 ft 4 in. W

Installer's initials



PIER SPACING TABLE FOR USED HOMES

Load bearing capacity	Footer size (sq in)	16" x 16" (256)	18 1/2" x 18 1/2" (342)	20" x 20" (400)	22" x 22" (484)*	24" x 24" (576)*	26" x 26" (676)
1000 dsf	3'		4'	5'	6'	7'	8'
1500 dsf	4' 6"		6'	7'	8'	8'	8'
2000 dsf	6'		8'	8'	8'	8'	8'
2500 dsf	7' 6"		8'	8'	8'	8'	8'
3000 dsf	8'		8'	8'	8'	8'	8'
3500 dsf	8'		8'	8'	8'	8'	8'

* interpolated from Rule 15C-1 pier spacing table.

PIER PAD SIZES

I-beam pier pad size 17x25

Perimeter pier pad size 16x16

Other pier pad sizes (required by the mfg.) 16x16

Draw the approximate locations of marriage wall openings 4 foot or greater. Use this symbol to show the piers.

List all marriage wall openings greater than 4 foot and their pier pad sizes below.

Opening Pier pad size

8 17x25
4 17x25
4 17x25

TIEDOWN COMPONENTS

Longitudinal Stabilizing Device (LSD)

Manufacturer

Longitudinal Stabilizing Device w/ Lateral Arms Manufacturer

ANCHORS

4 ft 5 ft

FRAME TIES

within 2' of end of home spaced at 5' 4" oc

OTHER TIES

Number

Sidewall 22

Longitudinal 40

Marriage wall 4

Shearwall 6

COLUMBIA COUNTY PERMIT WORKSHEET

page 2 of 2

POCKET PENETROMETER TEST

The pocket penetrometer tests are rounded down to 1500 psf or check here to declare 1000 lb. soil without testing.

x 1500 x 1500 x 1500

POCKET PENETROMETER TESTING METHOD

1. Test the perimeter of the home at 6 locations.
2. Take the reading at the depth of the footer.
3. Using 500 lb. increments, take the lowest reading and round down to that increment.

x 1500 x 1500 x 1500

TORQUE PROBE TEST

The results of the torque probe test is 205 inch pounds or check here if you are declaring 5' anchors without testing 205. A test showing 275 inch pounds or less will require 5 foot anchors.

Note: A state approved lateral arm system is being used and 4 ft. anchors are allowed at the sidewall locations. I understand 5 ft anchors are required at all centerline tie points where the torque test reading is 275 or less and where the mobile home manufacturer may require anchors with 4000 lb. holding capacity.

Installer's initials W

ALL TESTS MUST BE PERFORMED BY A LICENSED INSTALLER

Installer Name Paul Amund

Date Tested 5/27/10

Electrical

Connect electrical conductors between multi-wide units, but not to the main power source. This includes the bonding wire between multi-wide units. Pg. _____

Plumbing

Connect all sewer drains to an existing sewer tap or septic tank. Pg. _____

Connect all potable water supply piping to an existing water meter, water tap, or other independent water supply systems. Pg. _____

Site Preparation

Debris and organic material removed ✓
Water drainage: Natural ✓ Swale ✓ Pad ✓ Other ✓

Fastening multi wide units

Floor: Type Fastener: L17 Length: 6 Spacing: 24
Walls: Type Fastener: 5/16" Length: 6 Spacing: 16
Roof: Type Fastener: L17 Length: 6 Spacing: 16
For used homes a min. 30 gauge, 8" wide, galvanized metal strip will be centered over the peak of the roof and fastened with galv. roofing nails at 2" on center on both sides of the centerline.

Gasket (weatherproofing requirement)

I understand a properly installed gasket is a requirement of all new and used homes and that condensation, mold, mildew and buckled marriage walls are a result of a poorly installed or no gasket being installed. I understand a strip of tape will not serve as a gasket.

Installer's initials W

Type gasket _____
Pg. _____

Installed:

Between Floors Yes ✓
Between Walls Yes ✓
Bottom of ridgebeam Yes ✓

Weatherproofing

The bottomboard will be repaired and/or taped. Yes ✓ Pg. _____
Siding on units is installed to manufacturer's specifications. Yes ✓
Fireplace chimney installed so as not to allow intrusion of rain water. Yes ✓

Miscellaneous

Skirting to be installed. Yes ✓ No ✓
Dryer vent installed outside of skirting. Yes ✓ N/A ✓
Range downflow vent installed outside of skirting. Yes ✓ N/A ✓
Drain lines supported at 4 foot intervals. Yes ✓
Electrical crossovers protected. Yes ✓
Other: _____

Installer verifies all information given with this permit worksheet is accurate and true based on the

Installer Signature Paul Amund

Date 5-27-10

17 3/16" X 25 3/16" PIER FOOTER SPACINGS*
(MIN. 432 7/8 SQ.IN)

MAXIMUM I-BEAM PIER SPACING

FLOOR WIDTH	MAXIMUM PIER SPACING (SOIL BEARING CAPACITY)					
	1000 (PSF)	1500 (PSF)	2000 (PSF)	2500 (PSF)	3000 (PSF)	3500 (PSF)
120" WIDE FLOOR**	70 1/2"	110 1/2"	SEE NOTE #4	SEE NOTE #4	SEE NOTE #4	SEE NOTE #4
144" WIDE FLOOR**	59 1/2"	93 1/2"	SEE NOTE #4	SEE NOTE #4	SEE NOTE #4	SEE NOTE #4
160" WIDE FLOOR**	54"	85"	116"	SEE NOTE #4	SEE NOTE #4	SEE NOTE #4
184" WIDE FLOOR**	47 1/2"	75"	102"	SEE NOTE #4	SEE NOTE #4	SEE NOTE #4
MIN. PIER CAPACITY	3004 LBS.	4507 LBS.	6009 LBS.	7511 LBS.	9013 LBS.	10,516 LBS.

24" X 24" PIER FOOTER SPACINGS*
(MIN. 576 SQ.IN)

MAXIMUM I-BEAM PIER SPACING



FLOOR WIDTH	MAXIMUM PIER SPACING (SOIL BEARING CAPACITY)					
	1000 (PSF)	1500 (PSF)	2000 (PSF)	2500 (PSF)	3000 (PSF)	3500 (PSF)
120" WIDE FLOOR**	95 1/2"	SEE NOTE #4	SEE NOTE #4	SEE NOTE #4	SEE NOTE #4	SEE NOTE #4
144" WIDE FLOOR**	81"	SEE NOTE #4	SEE NOTE #4	SEE NOTE #4	SEE NOTE #4	SEE NOTE #4
160" WIDE FLOOR**	74"	115"	SEE NOTE #4	SEE NOTE #4	SEE NOTE #4	SEE NOTE #4
184" WIDE FLOOR**	65"	101"	SEE NOTE #4	SEE NOTE #4	SEE NOTE #4	SEE NOTE #4
MIN. PIER CAPACITY	4000 LBS	6000 LBS	8000 LBS.	10,000 LBS.	12,000 LBS.	14,000 LBS.

NOTE: UNIT WIDTHS WITH ** INCLUDES A 6" OVERHANG ON BOTH SIDES MAXIMUM.

FOR TYPICAL PIERS SEE PAGE SU-01-0021

NOTES:

1. PRE-FABRICATED PIER PADS MAY BE USED AS AN ALTERNATE TO THE CONCRETE FOOTINGS SPECIFIED IN THE JACOBSEN HOMES SET-UP MANUAL.
2. THE PRE-FABRICATED PIER PADS ARE TO BE INSTALLED PER THE MANUFACTURERS INSTALLATION INSTRUCTIONS AND MEET THE MINIMUM PIER CAPACITIES SHOWN ABOVE.
3. ALL OTHER REQUIREMENTS ARE TO BE ADHERED TO AS SPECIFIED IN THE JACOBSEN HOMES INSTALLATION INSTRUCTIONS.
4. MAX. PIER SPACING 8' FOR UNITS WITH 8" I-BEAMS / 10' FOR UNITS WITH 10" OR 12" I-BEAMS (24" MAX. FROM ENDS).



JACOBSEN HOMES

P.O. BOX 368
SAFETY HARBOR, FLORIDA 34695
PHONE (813) 726-1138

NOTICE:

THESE SPECIFICATIONS AND DRAWINGS ARE ORIGINAL, PROPRIETARY, AND CONFIDENTIAL MATERIALS OF JACOBSEN MANUFACTURING INC. SUCH MATERIALS ARE PROVIDED TO THE RECIPIENT FOR SPECIFIC PURPOSES AND MUST BE KEPT CONFIDENTIAL AND SECRET FROM OTHERS.

DRAWN BY: D.M.T.

DATE: 09-22-01


REV. LETTER:

DRAWING TITLE:
PRE-FAB. 17 X 25 & 24" PIER PAD SPACING

DRAWING NUMBER: SU-01-0025

ADDITIONAL PERIMETER BLOCKING

(THIS BLOCKING IS IN ADDITION TO BLOCKING REQUIRED IN THIS MANUAL)




TYP. FIREPLACES ON SIDEWALL OR MARRIAGE WALL

HOST BEAM NOTE


PERIMETER BLOCKING REQUIRED AT 48" O.C. MAX.



UNDER EACH SIDE OF ALL EXTERIOR DOORS LOCATED ON SIDEWALLS



2 OR MORE 46 1/2" WINDOWS
PIERS REQUIRED AT EACH END
AND BETWEEN EACH OPENING




RECESSED AREAS REQUIRE PIERS SPACED 64" O.C. MAX.
(18" OR LESS IN DEPTH)


EACH END OF RECESSED AREAS





RECESSED AREAS W/SIDE BAY REQUIRE PIERS SPACED 64" O.C. MAX.
THIS ALSO APPLIES TO ALL ENDWALL BAY WINDOWS
UNLESS SUPPORTED BY A FRAME MEMBER



54" OR 60" TUB AT SIDEWALL OR MARRIAGE WALL



GARDEN TUB AT SIDEWALL OR MARRIAGE WALL



CABINETS ALONG SIDEWALL OR MARRIAGE WALL
(APPLIES TO BATH CABINETS 80" OR GREATER IN LENGTH)
(SAME BLOCKING MAY BE USED FOR MULTIPLE 46 1/2" WINDOWS)


SPECIAL BLOCKING NOTE FOR 15'-4" (184") WIDE FLOOR SECTIONS

PERIMETER BLOCKING IS REQUIRED (MARRIAGE AND SIDEWALLS) 64" ON CENTER MAX. SPACING

NOTE: LEVEL FLOOR SYSTEM FIRST (SIDEWALL TO SIDEWALL OR MARRIAGE WALL) BEFORE INSTALLING PERIMETER BLOCKS

NOTES:

1. ADDITIONAL BLOCKING REQUIRED AS INDICATED ABOVE (USE 16" X 16" PIER PADS).
2. LOCATE BLOCKING UNDER PERIMETER JOIST OR WITHIN 8" OF END OF 16" O.C. JOISTS.
3. COLUMN PIERS ARE IN ADDITION TO REQUIRED PIERS UNDER FULL-HEIGHT MATING WALLS.
4. PERIMETER BLOCKING IS REQUIRED UNDER TILE FLOORS (MARRIAGE & SIDEWALLS) 64" O.C. MAX.
5. PIERS USED FOR PERIMETER SUPPORT MUST BE INSTALLED WITH THE LONG DIMENSION PARALLEL TO THE PERIMETER RAIL.
6. WHEN PERIMETER BLOCKING IS REQUIRED ANY MATING LINE OPEN SPAN GREATER THAN 10', MUST HAVE INTERMEDIATE PIERS PLACED AT MAX. 10' O.C. EXCEPT 15'-4" WIDE, SEE SPECIAL NOTE.



JACOBSEN HOMES

P.O. BOX 368
SAFETY HARBOR, FLORIDA 34695
PHONE (813) 726-1138

NOTICE:

THESE SPECIFICATIONS AND DRAWINGS ARE ORIGINAL, PROPRIETARY, AND CONFIDENTIAL MATERIALS OF JACOBSEN MANUFACTURING INC. SUCH MATERIALS ARE PROVIDED TO THE RECIPIENT FOR SPECIFIC PURPOSES AND MUST BE KEPT CONFIDENTIAL AND SECRET FROM OTHERS.

DRAWN BY:

O.A.

DATE:

4-12-00

REV. LETTER:

C

DRAWING TITLE:


ADDITIONAL BLOCKING

DRAWING NUMBER:


SU-01-0005

(09-30-08)

SITE PLAN EXAMPLE / WORKSHEET



Use this example to draw your own site plan. Show all existing buildings and any other homes on this property and show the distances between them. Also show where the roads or roads are around the property. This site plan can also be used for the 911 Addressing department if you include the distance from the driveway to the nearest property line.



>> [Print as PDF](#) <<

COMM NW COR NE1/4, RUN S		HENRY SHARON N		12-6S-16-03816-303		Columbia County 2010 R	
1316.46 FT FOR POB, CONT S		859 SW ROANOKE TERR				CARD 001 of 001	
656.97 FT, E 666.56 FT, N		FT WHITE, FL 32038		PRINTED 5/04/2010 20:15		BY JEFF	
656.96 FT, W 668.85 FT TO POB.				APPR 2/16/2004 TW			

BUSE	AE?	HTD AREA	.000 INDEX	12616.02 TUST	TRACES UNR	PUSE	000000 VACANT
MOD	BATH	EFF AREA	29.614 E-RATE	.000 INDX	STR 12- 6S-16E		
EXW	FIKT	RCN		AYB	MKT AREA 02		0 BLDG
%	BDRM	%GOOD	BLDG VAL	EYB	(PUD1		0 XFOB
RSTR	RMS					AC	52,304 LAND
RCVR	UNTS	3 FIELD CK:				NTCD	0 AG
%	C-W%	3 LOC: 236 GOLDENROD GLN SW FORT WHITE				APPR CD	0 MKAG
INTW	HGHT	3				CNDO	52,304 JUST
%	PMTR	3				SUBD	0 CLAS
FLOR	STYS	3				BLK	
%	ECON	3				LOT	0 SOHD
HTTP	FUNC	3				MAP#	0 ASSD
A/C	SPCD	3					

When recorded, mail to:

Name: Sharon N. Henry

Address: 859 SW Roanoke Terrace

City/State/Zip Code: Ft. White, FL 32038

Inst 200812021147 Date 11/21/2008 Time: 2:31 PM
Doc Stamp-Deed 0.70
CC, P. DeWitt Cason, Columbia County Page 1 of 3 B 1162 P 1677

Space above this line for Recorder's use

QUITCLAIM DEED

KNOW ALL MEN BY THESE PRESENTS:

That I(we), Clive and Paulette Singh,
the undersigned, for the consideration of Ten Dollars (\$10.00), and other valuable considerations, do
hereby release, remise, and forever quitclaim unto Sharon N. Henry

all right, title and interest in that certain Property situated in Columbia County,
State of Florida, and described as follows:

SEE ATTACHMENT "EXHIBIT A"

IN WITNESS WHEREOF, I(we) have hereunto set my(our) hand(s) and seal this 7 day of
November, 2008

Clive H. Singh

Printed Name of Releasor

Paulette E. Singh

Printed Name of Releasor

Clive Singh

Signature of Releasor

Paulette Singh

Signature of Releasor

Barbara A Saunders

Printed Name of Witness (If required by State Laws)

Barbara A Saunders

Signature of Witness (If required by State Laws)

Exhibit "A"


PARCEL 3

COMMENCE AT THE NORTHWEST CORNER OF THE NE 1/4 OF SECTION 12, TOWNSHIP 6 SOUTH, RANGE 16 EAST, COLUMBIA COUNTY, FLORIDA AND RUN THENCE S 00°03'14" E ALONG THE WEST LINE OF THE EAST 1/2 OF SAID SECTION 7, 1316.46 FEET TO THE POINT OF BEGINNING, THENCE CONTINUE S 00°03'14" E ALONG SAID WEST LINE, 656.97 FEET, THENCE S 89°38'15" E, 666.56 FEET, THENCE N 00°08'47" E, 656.96 FEET, THENCE N 89°38'15" W, 668.85 FEET TO THE POINT OF BEGINNING. SAID LANDS BEING SUBJECT TO A CUL-DE-SAC EASEMENT FOR INGRESS AND EGRESS IN THE NORTHEAST CORNER THEREOF. SAID LANDS BEING A PART OF THE NE 1/4 OF SECTION 12. CONTAINING 10.07 ACRES, MORE OR LESS.

60-FT. ROAD EASEMENTS

A STRIP OF LAND 60 FEET IN WIDTH BEING 30 FEET EACH SIDE OF A CENTERLINE DESCRIBED AS FOLLOWS:
COMMENCE AT THE NORTHWEST CORNER OF THE NE 1/4 OF SECTION 12, TOWNSHIP 6 SOUTH, RANGE 16 EAST, COLUMBIA COUNTY, FLORIDA AND RUN THENCE S 00°03'14" E ALONG THE WEST LINE OF THE EAST 1/2 OF SAID SECTION 7, 22.91 FEET TO THE SOUTH LINE OF ICHETUCKNEE ROAD (A COUNTY MAINTAINED GRADED ROAD, THENCE N 89°26'50" E ALONG SAID SOUTH LINE OF ICHETUCKNEE ROAD, 561.07 FEET, THENCE N 89°05'20" E STILL ALONG SAID SOUTH LINE OF ICHETUCKNEE ROAD, 785.95 FEET TO THE POINT OF BEGINNING, THENCE S 00°20'48" W, 1319.95 FEET TO REFERENCE POINT "A", THENCE CONTINUE S 00°20'48" W, 572.72 FEET TO REFERENCE POINT "B", THENCE CONTINUE S 00°20'48" W, 743.49 FEET TO REFERENCE POINT "C", THENCE N 89°38'15" W, 664.25 FEET TO THE CENTERPOINT OF A CUL-DE-SAC HAVING A RADIUS OF 50 FEET AND THE POINT OF TERMINATION. ALSO BEGIN AT REFERENCE POINT "A" AND RUN THENCE N 89°38'15" W, 668.85 FEET TO THE CENTERPOINT OF A CUL-DE-SAC HAVING A RADIUS OF 50 FEET AND THE POINT OF TERMINATION. ALSO BEGIN AT REFERENCE POINT "B" AND RUN THENCE S 89°38'15" E, 1300.53 FEET TO REFERENCE POINT "D", THENCE CONTINUE S 89°38'15" E, 1300.06 FEET TO REFERENCE POINT "E", THENCE N 00°20'48" E, 671.46 FEET TO THE CENTERPOINT OF A CUL-DE-SAC HAVING A RADIUS OF 50 FEET AND THE POINT OF TERMINATION. ALSO BEGIN AT REFERENCE POINT "D" AND RUN THENCE N 00°20'48" E, 671.46 FEET TO THE CENTERPOINT OF A CUL-DE-SAC HAVING A RADIUS OF 50 FEET AND THE POINT OF TERMINATION. ALSO BEGIN AT REFERENCE POINT "E" AND RUN THENCE S 00°20'48" W, 671.46 FEET TO THE CENTERPOINT OF A CUL-DE-SAC HAVING A RADIUS OF 50 FEET AND THE POINT OF TERMINATION. SAID EASEMENTS BEING A PART OF THE NE 1/4 OF SECTION 12 AND THE NW 1/4 OF SECTION 7, TOWNSHIP 6 SOUTH, RANGE 17 EAST.

64




42

42' X 64' X 40'
2,240 SQUARE FEET

Model TNR-7642

600 Packard Court ■ Safety Harbor, Florida 34695 ■ Telephone (727) 726-1138

2010
(ALL SIZES ARE APPROX.)
DESIGNED FOR ZONES II & III



JACOBSEN

MOBILE HOME INSTALLER AFFIDAVIT

As per Florida Statutes Section 320.8249 Mobile Home Installers License

Any person who engages in mobile home installation shall obtain a mobile home installer's license from the Bureau of Mobile Home and Recreational Vehicle Construction, of the Department of Highway Safety and Motor Vehicles pursuant to this section. Said license shall be renewed annually, and each licensee shall pay a fee of \$150

I, Ronnie Norris, license number TH/1025/145/1

state that the installation of the manufactured home for owner

Sharon Henry at
911 Address: 236 SW Goldenrod Cir City Ft White

will be done under my supervision.

Signed: Ronnie Norris
Mobile Home Installer

Sworn to and described before me this 28 day of May 2010

Shirley M Bennett
Notary public

Shirley M Bennett Personally known ✓
Notary Name

DL ID _____





COLUMBIA COUNTY BUILDING DEPARTMENT
135 NE Hernando Ave, Suite B-21, Lake City, FL 32055
Phone: 386-758-1008 Fax: 386-758-2160

MOBILE HOME INSTALLERS AGENT AUTHORIZATION

I, Ronnie Norris, give this authority and I do certify that the below
Installers Name

referenced person(s) listed on this form is/are under my direct supervision and control and
is/are authorized to purchase permits, call for inspections and sign on my behalf.

Printed Name of Authorized Person	Signature of Authorized Person	Agents Company Name
Wendy Grennell	Wendy Grennell	

I, the license holder, realize that I am responsible for all permits purchased, and all work done
under my license and I am fully responsible for compliance with all Florida Statutes, Codes, and
Local Ordinances.

I understand that the State Licensing Board has the power and authority to discipline a license
holder for violations committed by him/her or by his/her authorized person(s) through this
document and that I have full responsibility for compliance granted by issuance of such permits.

Ronnie Norris
License Holders Signature (Notarized)

1H/1025/18/15-28-10
License Number Date

NOTARY INFORMATION:

STATE OF: Florida COUNTY OF: Columbia

The above license holder, whose name is Ronnie Norris,
personally appeared before me and is known by me or has produced identification
(type of I.D.) _____ on this 28 day of May, 2010.

Shirley M. Bennett
NOTARY'S SIGNATURE



Sharon Henry

App # 1006-37

**PAT LYNCH
LYNCH DRILLING CORP.**

P. O. BOX 934
BRANFORD, FL 32008
(386) 935-1076 PHONE
(386) 935-1199 FAX

DATE: 6-14-2010

CUSTOMER: Sharon Henry

LOCATION: 12-065-16-03816-303
SW Golden Rod Glen
Columbia County

WE WILL CONSTRUCT A 4' WATER WELL COMPLETE WITH 4" BLACK
WATER WELL STEEL CASING, IHP SUBMERSIBLE PUMP (20GPM) WITH 1 1/4 "
GALVANIZED DROP PIPE, AND AN 81 GALLON CAPTIVE AIR TANK (21.9
GALLON DRAWDOWN)

* well drilled 04-09-2010 * as per specs -
WELL WILL BE COMPLETE AT THE WELL SITE. WE DO NOT INCLUDE
ELECTRICAL NOR PLUMBING CONNECTIONS FROM THE WELL TO THE
HOME AND/OR POWER POLE.

ANY VARIATIONS OF THE ABOVE ARE SUBJECT TO APPROVAL FROM THE
CUSTOMER AND/OR CONTRACTOR PRIOR TO COMMENCEMENT OF THE
INDIVIDUAL JOB.

THANK YOU

Pat Lynch
6-14-2010

NOT RESPONSIBLE FOR THE QUALITY OF WATER

Sharon Henry
App # 1006-37

COLUMBIA COUNTY 9-1-1 ADDRESSING

P. O. Box 1787, Lake City, FL 32056-1787

PHONE (386) 758-1123 * FAX: (386) 758-1365 * Email: ron_croft@columbiacountyfla.com

Addressing Maintenance

The purpose of this program is to ensure that all addresses in Columbia County are accurate and up-to-date. This program is designed to provide a systematic approach to addressing maintenance, including the collection, verification, and updating of address information. The program is based on the Florida Department of Transportation's (FDOT) Addressing Manual, which is the standard for addressing in Florida. The program is designed to ensure that all addresses in Columbia County are accurate and up-to-date, and that the information is available to the public in a timely and efficient manner. The program is designed to ensure that all addresses in Columbia County are accurate and up-to-date, and that the information is available to the public in a timely and efficient manner.

DATE REQUESTED: 6/11/2010 DATE ISSUED: 6/11/2010

ENHANCED 9-1-1 ADDRESS:

236 SW GOLDENROD

GLN

FORT WHITE FL 32038

PROPERTY APPRAISER PARCEL NUMBER:

12-6S-16-03816-303

Remarks:

LOT 3 TUSTENUGGEE TRAILS S/D UNREC

Address Issued By:


Columbia County 9-1-1 Addressing / GIS Department

NOTICE: THIS ADDRESS WAS ISSUED BASED ON LOCATION INFORMATION RECEIVED FROM THE REQUESTER. SHOULD, AT A LATER DATE, THE LOCATION INFORMATION BE FOUND TO BE IN ERROR, THIS ADDRESS IS SUBJECT TO CHANGE.

1750

SUBCONTRACTOR VERIFICATION FORM

APPLICATION NUMBER _____

CONTRACTOR

Ronnie Norris

PHONE

386-623-7716

THIS FORM MUST BE SUBMITTED PRIOR TO THE ISSUANCE OF A PERMIT

In Columbia County one permit will cover all trades doing work at the permitted site. It is **REQUIRED** that we have records of the subcontractors who actually did the trade specific work under the permit. Per Florida Statute 440 and Ordinance 89-6, a contractor shall require all subcontractors to provide evidence of workers' compensation or exemption, general liability insurance and a valid Certificate of Competency license in Columbia County.

Any changes, the permitted contractor is responsible for the corrected form being submitted to this office prior to the start of that subcontractor beginning any work. Violations will result in stop work orders and/or fines.

ELECTRICAL 234 ✓	Print Name <u>Michael Conner</u> License #: <u>ER13013192</u>	Signature <u>Michael Conner</u> Phone #: <u>758-2233</u>
MECHANICAL/A/C	Print Name _____ License #: _____	Signature _____ Phone #: _____
PLUMBING/GAS 629 ✓	Print Name <u>Ronnie D. Norris</u> License #: <u>IH/1025145/1</u>	Signature <u>Ronnie Norris</u> Phone #: <u>623-7716</u>
ROOFING	Print Name _____ License #: _____	Signature _____ Phone #: _____
SHEET METAL	Print Name _____ License #: _____	Signature _____ Phone #: _____
FIRE SYSTEM/SPRINKLER	Print Name _____ License #: _____	Signature _____ Phone #: _____
SOLAR	Print Name _____ License #: _____	Signature _____ Phone #: _____

Specialty License	License Number	Sub-Contractor's Printed Name	Sub-Contractor's Signature
MASON			
CONCRETE FINISHER			
FRAMING			
INSULATION			
STUCCO			
DRYWALL			
PLASTER			
CABINET INSTALLER			
PAINTING			
ACOUSTICAL CEILING			
GLASS			
CERAMIC TILE			
FLOOR COVERING			
ALUM/VINYL SIDING			
GARAGE DOOR			
METAL BLDG ERECTOR			

F. S. 440.103 Building permits; identification of minimum premium policy.—Every employer shall, as a condition to applying for and receiving a building permit, show proof and certify to the permit issuer that it has secured compensation for its employees under this chapter as provided in ss. 440.10 and 440.38, and shall be presented each time the employer applies for a building permit.

Jun 16 10 05:29p Wendy Grennell

06-16-'10 15:27 FROM-Atlantic / Prime

3867551031
1-800-859-3708

P.1

Jun 11 10 08:26a
CJ 10 10 08 26
06-11-'10 10:08Wendy Grennell
WENDY GRENELL
WENDY GRENELL

3867551031

P.2

Sharon Henry

SUBCONTRACTOR VERIFICATION FORM

APPLICATION NUMBER

1006-37

CONTRACTOR

Ronnie Norris

PHONE

386-623-

7716

THIS FORM MUST BE SUBMITTED PRIOR TO THE ISSUANCE OF A PERMIT

In Columbia County one permit will cover all trades doing work at the permitted site. It is **REQUIRED** that we have records of the subcontractors who actually did the trade specific work under the permit. Per Florida Statute 440 and Ordinance 89-6, a contractor shall require all subcontractors to provide evidence of workers' compensation or exemption, general liability insurance and a valid Certificate of Competency license in Columbia County.

Any changes, the permitted contractor is responsible for the corrected form being submitted to this office prior to the start of that subcontractor beginning any work. Violations will result in stop work orders and/or fines.

ELECTRICAL	Print Name _____ License #: _____	Signature _____ Phone #: _____
MECHANICAL A/C 113 ✓	Print Name <u>Robert Grant</u> License #: <u>CAC1814931</u>	Signature <u>Robert Grant</u> Phone #: <u>800-859-3708</u>
PLUMBING/ GAS ✓	Print Name <u>Ronnie D. Norris</u> License #: <u>I# 1025145/1</u>	Signature <u>Ronnie D. Norris</u> Phone #: <u>623-7716</u>
ROOFING	Print Name _____ License #: _____	Signature _____ Phone #: _____
SHEET METAL	Print Name _____ License #: _____	Signature _____ Phone #: _____
FIRE SYSTEM/ SPRINKLER	Print Name _____ License #: _____	Signature _____ Phone #: _____
SOLAR	Print Name _____ License #: _____	Signature _____ Phone #: _____

MASON			
CONCRETE FINISHER			
FRAMING			
INSULATION			
STUCCO			
DRYWALL			
PLASTER			
CABINET INSTALLER			
PAINTING			
ACOUSTICAL CEILING			
GLASS			
CERAMIC TILE			
FLOOR COVERING			
ALUM/VINYL SIDING			
GARAGE DOOR			
METAL BLDG ERECTOR			

F. S. 440.103 Building permits; identification of minimum premium policy.—Every employer shall, as a condition to applying for and receiving a building permit, show proof and certify to the permit issuer that it has secured compensation for its employees under this chapter as provided in ss. 440.10 and 440.38, and shall be presented each time the employer applies for a building permit.

Contractor Permit Subcontractor Form 6/09

CERTIFICATE OF COMPLETION

M/H OCCUPANCY

COLUMBIA COUNTY, FLORIDA

Department of Building and Zoning Inspection

This Certificate of Occupancy is issued to the below named permit holder for the building and premises at the below named location, and certifies that the work has been completed in accordance with the Columbia County Building Code.

Parcel Number 12-6S-16-03816-303

Building permit No. 000028672

Permit Holder RONNIE NORRIS

Owner of Building SHARON HENRY

Location: 236 SW GOLDENROD GLEN, FT. WHITE, FL

Date: 07/19/2010



Sharon Henry

Building Inspector

POST IN A CONSPICUOUS PLACE
(Business Places Only)