



March 16, 2021

Josh Sparks
Sparks Construction
426 SW Commerce Drive, Suite 130-J
Lake City, FL 32025

SUBJECT: ELEVATION LETTER
Parcel No. 16-4S-17-08382-379
153 Travis Glen, Lake City, Florida

To Whom It May Concern:

Parcel No. 16-4S-17-08382-379 is located in Flood Zone X. The property naturally slopes to the north toward a County maintained stormwater pond. The residential structure will be elevated on a concrete pad. Stormwater will flow around the structure to the north into the pond which flows to the west through a ditch, when it overflows.


Requirements for Structure to Be Protected from the Base Flood Event:

The finished floor elevation for the foundation of the structure shall be at 105.0 feet NAVD and above the highest adjacent natural grade at the proposed building site. Any disturbed area around the proposed structure shall be graded to direct all runoff to the north.

Sincerely,

Terry R. White, Jr., P.E.
Water Resources Engineer

I certify that the finished floor elevation listed above will protect the structure against water damage from a base flood event, as defined in Article 8 of the Land Development Regulations.



Digitally signed by Terry R White
Date: 2021.03.16 11:31:35-04'00'

Terry R. White, Jr., P.E.

3/16/21

Date