



Affine Engineering and Surveying, Inc.

Date: 6/7/2022

Ms. Ida Fallet

352.942.4713

Re: **Elevation Letter– Lot 1 Hawk's Landing (PB 9, PGS 165-167).**

SUBJECT:

FINISH FLOOR HEIGHT VERIFICATION

To whom it may concern,

During a field survey conducted 6/3/2022 on Lot 1, Hawk's Landing Plat – Parcel 31-4S-17-08915-101, the finish floor of the existing structure was measured. According to the plat of Hawk's Landing the minimum floor elevation is 94.00 feet. Based on the field survey, it was found that the Finish Floor of the modular building is at elevation 97.06 feet. Elevations are referenced to BM #6 as shown on the plat having an elevation of 92.72 feet (NAVD88 datum).



6.7.2022

Victor O. Marrero, PE, PSM

Florida PSM 6586