

State Licensing
Board

Attorney
said was
Legal

11-26-06

Charles Peeler Construction

owner Shirley Hitson (Emerald Cove Lot 5)

On Nov. 21st I inspected the above mentioned house. As I inspected the Electrical part of my inspection, I noticed that a Number 6 Aluminum wire was used to hook-up the stove. Columbia County Building Dept. does not allow Aluminum wire in a house, (only the service entrance cable). After talking to the Electrician he agreed if we could pass this inspection, he would not use Aluminum wire again, he also stated that it is code. We realize that

this practice is according to code but we discourage this type of use. We have called and spoke with the State Liciencing Board attorney + he said that it was legal. Joe Hiltiwanger also spoke with James Patton (Director of Department Bussiness and Professional Regulation, and He said that it was o.k. as long as the Amperage was o.k. I also spoke with Russ Lampert (DBPR) to bring him up to speed on our situation, and He did not have a problem. Columbia County Building Dept., ~~and~~ will allow this use this time only.

Harry Dick