

# 39110



---

**Britt Surveying and Mapping, LLC**  
2086 SW Main Blvd Ste 112 • Lake City, FL 32025  
386-752-7163 P • 386-752-5573 F • [www.brittsurvey.com](http://www.brittsurvey.com)

01/15/2020

Permit #39110

L-26295

Re: Lot 52 May-Fair Unit 3

Trent Giebeig Construction

To Whom It May Concern:

The top of the stem wall elevation is found to be 160.5 feet on said lot 52. The lowest adjacent grade is found to be 158.6 feet, and the highest adjacent grade is found to be 159.5 feet. The building permit shows the minimum floor elevation to be 160 feet. The elevations shown hereon are based on plat datum.

Sincerely,

  
L. Scott Britt  
LS 5757