

43318

D
G **Daniel & Gore, LLC**
Professional Surveying and Mapping

P.O. Box 1501
Lake City, Florida 32056

May 2, 2022

Aaron Simque Homes
333 SW Rosemary Drive
Lake City, FL 32025

Subject: Lot 144, Preserve at Laurel Lake, Unit 1

Dear Aaron:

Daniel & Gore, LLC has performed a vertical survey on Lot 144, Preserve at Laurel Lake, Unit 1, Columbia County, Florida from a benchmark being a 60d nail at the common lot line between Lots 8 & 9 (elevation – 116.12', NGVD 1929) and have determined the following:

- The Subdivision plat requires the minimum finish floor elevation to be 118.0'.
- The elevation of the concrete foundation is at 118.5', being 0.5' above the minimum finish floor requirement.

If you have any questions, please call me.

Sincerely,



Scott Daniel, PSM

