



Project Summary

Entire House

Crystal Air & Water, Inc

31

Job:
Date: Aug 27, 2024
By:

6424 NW 18th Drive, Gainesville, FL 32653 Phone: 352-333-0460 Fax: 352-378-7867 Email: info@crystalairwater.com Web: www.acpenguin.com License: CMC1249394

Project Information

For: Joyce Collins & William Braun, Owner Builder
471 SW Stewart Loop, Lake City, FL 32024

Notes:



Design Information

Weather: Gainesville Rgnl, FL, US

Winter Design Conditions

Outside db 33 °F
Inside db 68 °F
Design TD 35 °F

Summer Design Conditions

Outside db 92 °F
Inside db 75 °F
Design TD 17 °F
Daily range M
Relative humidity 50 %
Moisture difference 47 gr/lb

Heating Summary

Structure 18336 Btuh
Ducts (R-6.0) 7470 Btuh
Central vent (0 cfm)
(none) 0 Btuh
Humidification 0 Btuh
Piping 0 Btuh
Equipment load 25805 Btuh

Sensible Cooling Equipment Load Sizing

Structure 13852 Btuh
Ducts (R-6.0) 9744 Btuh
Central vent (0 cfm)
(none) 0 Btuh
Blower 0 Btuh
Use manufacturer's data n
Rate/swing multiplier 0.97
Equipment sensible load 22864 Btuh

Infiltration

Method Simplified
Construction quality Average
Fireplaces 0

Latent Cooling Equipment Load Sizing

Structure 3572 Btuh
Ducts 2052 Btuh
Central vent (0 cfm)
(none) 0 Btuh
Equipment latent load 5624 Btuh
Equipment Total Load (Sen+Lat) 28488 Btuh
Req. total capacity at 0.75 SHR 2.5 ton

	Heating	Cooling
Area (ft²)	1860	1860
Volume (ft³)	16758	16758
Air changes/hour	0.38	0.20
Equiv. A/VF (cfm)	106	56

Heating Equipment Summary

Make Trane
Trade TRANE
Model 4TWR6036N1
AHRI ref 209068075
Efficiency 7.5 HSPF2
Heating input 35200 Btuh @ 47°F
Heating output 28 °F
Temperature rise 1153 cfm
Actual air flow 0.045 cfm/Btuh
Air flow factor 0 in H2O
Static pressure
Space thermostat
Capacity balance point = 26 °F
Backup:
Input = 7 kW, Output = 24328 Btuh, 100 AFUE

Cooling Equipment Summary

Make Trane
Trade TRANE
Cond 4TWR6036N1
Coil TEM6A0B30H21++TDR
AHRI ref 209068075
Efficiency 12.0 EER2, 16 SEER2
Sensible cooling 25950 Btuh
Latent cooling 8650 Btuh
Total cooling 34600 Btuh
Actual air flow 1153 cfm
Air flow factor 0.049 cfm/Btuh
Static pressure 0 in H2O
Load sensible heat ratio 0.81

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.




wrightsoft™

Right-Suite® Universal 2023.23.0.05 RSU65034

R:\Wrightsoft\ackbox\paulrup Calc = MJ8 Front Door faces: N

2024-Sep-16 08:55:57

Page 1



Page 1
Right-Suite® Universal 2023
23.0.05 RSU65034
2024-Sep-16 08:56:28
R:\Wrightsoft\tackledbox,paul.rup



Manual S Compliance Report

Entire House

Crystal Air & Water, Inc

Job:
Date: Aug 27, 2024
By:

6424 NW 18th Drive, Gainesville, FL 32653 Phone: 352-333-0460 Fax: 352-378-7867 Email: info@crystalairwater.com Web: www.acpenguin.com License: CMC1246384

Project Information

For: Joyce Collins & William Braun, Owner Builder
471 SW Stewart Loop, Lake City, FL 32024

Cooling Equipment

Design Conditions

Outdoor design DB:	91.9°F	Sensible gain:	23596	Btuh	Entering coil DB:	78.0°F
Outdoor design WB:	76.2°F	Latent gain:	5624	Btuh	Entering coil WB:	64.0°F
Indoor design DB:	75.0°F	Total gain:	29220	Btuh		
Indoor RH:	50%	Estimated airflow:	1153	cfm		

Manufacturer's Performance Data at Actual Design Conditions

Equipment type:	Split ASHP		
Manufacturer:	Trane	Model:	4TWR6036N1+TEM6A0B30H21++TDR
Actual airflow:	1153	cfm	
Sensible capacity:	25950	Btuh	110% of load
Latent capacity:	8650	Btuh	154% of load
Total capacity:	34600	Btuh	118% of load SHR: 75%

Heating Equipment

Design Conditions

Outdoor design DB:	33.4°F	Heat loss:	25805	Btuh	Entering coil DB:	66.6°F
Indoor design DB:	68.0°F					

Manufacturer's Performance Data at Actual Design Conditions

Equipment type:	Split ASHP		
Manufacturer:	Trane	Model:	4TWR6036N1+TEM6A0B30H21++TDR
Actual airflow:	1153	cfm	
Output capacity:	35200	Btuh	136% of load
Supplemental heat required:	0	Btuh	
			Capacity balance: 26 °F
			Economic balance: -99 °F

Backup equipment type:	Elec strip		
Manufacturer:		Model:	
Actual airflow:	1153	cfm	
Output capacity:	7.1	kW	94% of load Temp. rise: 50 °F

Meets all requirements of ACCA Manual S.



Right-Suite® Universal 2023.23.0.05 RSU65034
R:\Wrightsoft\labeledbox\paul.rup Calc = MJ8 Front Door faces: N

2024-Sep-16 08:55:57

Page 1



Duct System Summary

Entire House

Crystal Air & Water, Inc

Job:
Date: Aug 27, 2024
By:

6424 NW 18th Drive, Gainesville, FL 32653 Phone: 352-333-0460 Fax: 352-378-7867 Email: info@crystalairwater.com Web: www.acpenguin.com License: CMC1246384

Project Information

For: Joyce Collins & William Braun, Owner Builder
471 SW Stewart Loop, Lake City, FL 32024

External static pressure	Heating	Cooling
Pressure losses	0 in H ₂ O	0 in H ₂ O
Available static pressure	0 in H ₂ O	0 in H ₂ O
Supply / return available pressure	0.000 / 0.000 in H ₂ O	0.000 / 0.000 in H ₂ O
Lowest friction rate	0 in/100ft	0 in/100ft
Actual air flow	1153 cfm	1153 cfm
Total effective length (TEL)		1413 ft

Supply Branch Detail Table

Name	Design (Btuh)	Htg (cfm)	Clg (cfm)	Design FR	Diam (in)	H x W (in)	Duct Matl	Actual Ln (ft)	Ftg.Eqv Ln (ft)	Trunk
Room10	c 2179	64	107	0	0	0x 0	VIFx	24.0	570.0	st1A
Room10A	c 2179	64	106	0	0	0x 0	VIFx	30.0	635.0	st1A
Room12	c 1721	55	84	0	0	0x 0	VIFx	17.0	355.0	st1
Room13	c 167	8	8	0	0	0x 0	VIFx	19.3	485.0	st1
Room3	h 1817	167	89	0	0	0x 0	VIFx	54.0	1045	st1B
Room4	h 3377	179	165	0	0	0x 0	VIFx	55.3	980.0	st1B
Room5	h 362	34	18	0	0	0x 0	VIFx	50.1	915.0	st1B
Room6	c 2628	117	128	0	0	0x 0	VIFx	37.4	765.0	st1A
Room6A	c 2628	117	128	0	0	0x 0	VIFx	41.0	830.0	st1A
Room6B	c 2628	117	128	0	0	0x 0	VIFx	37.0	700.0	st1A
Room6C	c 2628	117	128	0	0	0x 0	VIFx	14.0	420.0	st1
Room7	h 783	63	38	0	0	0x 0	VIFx	5.0	160.0	st1
Room8	c 182	9	9	0	0	0x 0	VIFx	10.3	225.0	st1
Room9	h 317	43	15	0	0	0x 0	VIFx	16.4	290.0	st1

Supply Trunk Detail Table

Name	Trunk Type	Htg (cfm)	Clg (cfm)	Design FR	Veloc (fpm)	Diam (in)	H x W (in)	Duct Material	Trunk
st1B	Peak AVF	380	272	0	0	0	12 x 0	RectFbg	st1A
st1A	Peak AVF	858	870	0	0	0	12 x 0	RectFbg	st1
st1	Peak AVF	1153	1153	0	0	0	12 x 0	RectFbg	

Bold/italic values have been manually overridden



Right-Suite® Universal 2023.23.0.05 RSJ65034

2024-Sep-16 08:55:57

Page 1

R:\Wrightsoft\backdoor\paul.rup Calc = MJ8 Front Door faces: N

Return Branch Detail Table

Name	Grille Size (in)	Htg (cfm)	Clg (cfm)	TEL (ft)	Design FR	Veloc (fpm)	Diam (in)	H x W (in)	Stud/Joist Opening (in)	Duct Matl	Trunk
rb4	0x 0	297	363	313.5	0	0	0	0x 0		VIFx	rt2
rb6	0x 0	188	243	218.6	0	0	0	0x 0		VIFx	rt2
rb1	0x 0	380	272	247.8	0	0	0	0x 0		VIFx	rt2
rb8	0x 0	215	228	198.5	0	0	0	0x 0		VIFx	rt2
rb7	0x 0	72	47	0	0	0	0	0x 0		VIFx	

Return Trunk Detail Table

Name	Trunk Type	Htg (cfm)	Clg (cfm)	Design FR	Veloc (fpm)	Diam (in)	H x W (in)	Duct Material	Trunk
rt2	PeakAVF	1081	1106	0	0	0	12 x 0	RectFbg	rt1
rt1	PeakAVF	1081	1106	0	0	0	12 x 0	RectFbg	



ENERGY STAR Single-Family New Homes National HVAC Design Report, Version 3 / 3.1 /3.2 (Rev. 12)

HVAC Designer Responsibilities:

- Complete one National HVAC Design Report for each system design for a house plan, created for either the specific plan configuration (i.e., elevation, option, orientation, & county) of the home to be certified or for a plan that is intended to be built with different configurations (i.e., different elevations, options, and/or orientations). Visit www.energystar.gov/newhomeshvacdesign and see Footnote 2 for more information.
- Obtain efficiency features (e.g., window performance, insulation levels, and infiltration rate) from the builder or Rater.³
- Provide the completed National HVAC Design Report to the builder or credentialed HVAC contractor and to the Rater.

1. Design Overview

1.1 Designer name: _____ Designer company: Crystal Air & Water, Inc Date: Aug 27, 2024
1.2 Select which party you are providing these design services to: ☒ Builder or ☐ Credentialed HVAC contractor
1.3 Name of company you are providing these design services to (if different than Item 1.1): _____ or Owner Builder
1.4 Area that system serves: ☒ Whole-house ☐ Upper-level ☐ Lower-level ☐ Other
1.5 Is cooling system for a temporary occupant load? ☐ Yes ☒ No
1.6 House plan: _____ Check box to indicate whether the system design is site-specific or part of a group:
☒ Site-specific design. Option(s) & elevation(s) modeled: _____ Configuration modeled: _____
☐ Group design. Group #: 0 out of 0 total groups for this house plan.

2. Dwelling Unit Mechanical Ventilation System Design ("Vent System") & Inlets in Return Duct

Designer
Verified

Airflow:

2.1 Ventilation airflow design rate & run-time meet the requirements of ASHRAE 62.2-2010 or later ☐
2.2 Ventilation airflow rate required by 62.2 for a continuous system: 0 CFM -
2.3 Design for this system: Vent. airflow rate: _____ CFM Run-time per cycle: 0 minutes Cycle time: 0 minutes -

System Type & Controls:

2.4 Specified system type: ☐ Supply ☐ Exhaust ☒ Balanced -
2.5 Specified control location: _____ (e.g., Master bath, utility room) -
2.6 Specified controls allow the system to operate automatically, without occupant intervention. ☐
2.7 Specified controls include a readily-accessible ventilation override and a label has also been specified if its function is not obvious (e.g., a label is required for a toggle wall switch, but not for a switch that's on the ventilation equipment). ☐
2.8 For any outdoor air inlet designed to connect to a ducted return of the HVAC system, specified controls automatically restrict airflow using a motorized damper during ventilation off-cycle and occupant override. ☐
2.9 The fan of the specified system is rated ≤ 3 sones if intermittent and ≤ 1 sone if continuous, or exempted ☐

Efficiency:

2.10 If Vent System controller operates the HVAC fan, then HVAC fan operation is intermittent and either the fan type in Item 4.7 is ECM/ICM or the controls will reduce the run-time by accounting for HVAC system heating or cooling hours. ☐
2.11 If bathroom fans are specified as part of the system, then they are ENERGY STAR certified ☐

Air Inlet Location: (Complete this section if system has a specified air inlet location; otherwise check "N/A") ☐ N/A

2.12 Inlet pulls ventilation air directly from outdoors and not from attic, crawlspace, garage, or adjacent dwelling unit ☐
2.13 Inlet is ≥ 2 ft. above grade or roof deck; ≥ 10 ft. of stretched-string distance from known contamination sources (e.g., stack, vent, exhaust, vehicles) not exiting the roof, and ≥ 3 ft. from known sources exiting the roof ☐

3. Room-by-Room Heating & Cooling Loads

3.1 Room-by-room loads calculated using: ☒ Unabridged ACCA Manual J v8 ☐ 2013 ASHRAE Fundamentals ☐ Other per AHJ -
3.2 Indoor design temperatures used in loads are 70°F for heating and 75°F for cooling ☐
3.3 Outdoor design temperatures used in loads: (See Footnote 17 and energystar.gov/hvacdesign/temps)
County & State, or US Territory, selected: Alachua, FL Cooling season: 92°F Heating season: 33°F -
3.4 Number of occupants used in loads: 9 -
3.5 Conditioned floor area used in loads: 1860 Sq. Ft. -
3.6 Window area used in loads: 172 Sq. Ft. -
3.7 Predominant window SHGC used in loads: 0.57 -
3.8 Infiltration rate used in loads: Summer: 0.20 Winter: 0.38 -
3.9 Mechanical ventilation rate used in loads: 0 CFM -

Loads At Design Conditions (kBtu/h)

	N	NE	E	SE	S	SW	W	NW	
Cooling	3.10 Sensible heat gain (By orientation)	22.9	25.9	26.7	25.7	22.9	25.2	26.0	25.4
	3.11 Latent heat gain (Not by orientation)	5.6							
	3.12 Total heat gain (By orientation)	28.5	31.6	32.4	31.4	28.5	30.8	31.6	31.1
	3.13 Maximum - minimum total heat gain (Item 3.12) across orientations =	3.9 kBtu/h				Variation is ≤ 6 kBtu/h			
Heating	3.14 Total heat loss (Not by orientation)	25.8							



ENERGY STAR Single-Family New Homes National HVAC Design Report, Version 3 / 3.1 / 3.2 (Rev. 12)

4. Heating & Cooling Equipment Selection										Designer Verified	
4.1 Equipment selected per ACCA Manual S (see Footnote 25 & 26).										<input type="checkbox"/>	
Air Conditioner / Heat Pump (Complete if air conditioner or heat pump will be installed; otherwise check "N/A")										<input type="checkbox"/> N/A	
4.2 Equipment type: <input type="checkbox"/> Cooling-only air conditioner or <input checked="" type="checkbox"/> Cooling & heating heat pump										-	
4.3 Condenser manufacturer & model: Trane 4TWR6036N1										-	
4.4 Evaporator / fan coil manufacturer & model: Trane TEM6A0B30H21++TDR										-	
4.5 AHRI reference #: 209068075										-	
4.6 AHRI listed efficiency: 12 / 16 EER / SEER Air-source heat pump: 7.5 HSPF Ground-source heat pump: COP										-	
4.7 Evaporator fan type: <input type="checkbox"/> PSC <input type="checkbox"/> ECM/ICM <input checked="" type="checkbox"/> Other:										-	
4.8 Compressor type: <input checked="" type="checkbox"/> Single-speed <input type="checkbox"/> Two-speed <input type="checkbox"/> Variable-speed										-	
4.9 Latent capacity at design conditions, from OEM expanded performance data: 0 kBtu/h										-	
4.10 Sensible capacity at design conditions, from OEM expanded performance data: 0 kBtu/h										-	
4.11 Total capacity at design conditions, from OEM expanded performance data: 0 kBtu/h										-	
4.12 Air-source heat pump capacity: At 17°F: 22.2 kBtu/h At 47°F: 35.2 kBtu/h <input type="checkbox"/> N/A										-	
4.13 Cooling sizing % = Total capacity (Item 4.11) divided by maximum total heat gain (Item 3.12): 0 %										-	
4.14 Complete this item if Condition B Climate will be used to select sizing limit in Item 4.15. Otherwise, check "N/A": <input checked="" type="checkbox"/> N/A										-	
4.14.1 Load sensible heat ratio = Max. sensible heat gain (Item 3.10) / Max. total heat gain (Item 3.12) = 83%										-	
4.14.2 HDD / CDD ratio (Visit energystar.gov/hvacdesign temps to determine this value for the design location) = 0.2										-	
4.15 Check box of applicable cooling sizing limit from chart below:										-	
Equipment Type (Per Item 4.2) & Climate Condition (Per Item 4.14)		Compressor Type (Per Item 4.8)									
		Single-Speed		Two-Speed		Variable-Speed					
For Cooling-Only Equipment or For Cooling Mode of Heat Pump in Condition A Climate		<input type="checkbox"/>	Recommended: 90 - 115% Allowed: 90 - 130%	<input type="checkbox"/>	Recommended: 90 - 120% Allowed: 90 - 140%	<input type="checkbox"/>	Recommended: 90 - 130% Allowed: 90 - 160%				
For Cooling Mode of Heat Pump in Condition B Climate		<input type="checkbox"/>	90% - 100%, plus 15 kBtu/h	<input type="checkbox"/>	90% - 100%, plus 15 kBtu/h	<input type="checkbox"/>	90% - 100%, plus 15 kBtu/h				
4.16 Cooling sizing % (4.13) is within cooling sizing limit (4.15) <input type="checkbox"/>											
Furnace (Complete if furnace will be installed; otherwise check "N/A") <input checked="" type="checkbox"/> N/A											
4.17 Furnace manufacturer & model:										-	
4.18 Listed efficiency: AFUE										-	
4.19 Total capacity: kBtu/h										-	
4.20 Heating sizing % = Total capacity (Item 4.19) divided by total heat loss (Item 3.14): 0%										-	
4.21 Check box of applicable heating sizing limit from chart below:										-	
When Used for Heating Only					When Paired With Cooling						
<input type="checkbox"/> 100 - 140%					<input type="checkbox"/> Recommended: 100 - 140% Allowed: 100 - 400%						
4.22 Heating sizing % (4.20) is within heating sizing limit (4.21) <input type="checkbox"/>											
5. Duct Design (Complete if heating or cooling equipment will be installed with ducts; otherwise check "N/A") <input type="checkbox"/> N/A											
5.1 Duct system designed for the equipment selected in Section 4, per ACCA Manual D <input checked="" type="checkbox"/>											
5.2 Design HVAC fan airflow: Cooling mode 1153 CFM Heating mode 1153 CFM										-	
5.3 Design HVAC fan speed setting (e.g., low, medium, high): Cooling mode Medium Heating mode Medium										-	
5.4 Design total external static pressure (corresponding to the mode with the higher airflow in Item 5.2): 0 INWC										-	
5.5 Room-by-room design airflows documented below (which must sum to the mode with the higher airflow in Item 5.2)										-	
Room Name		Design Airflow (CFM)		Room Name		Design Airflow (CFM)		Room Name		Design Airflow (CFM)	
1	Room1	0		12	Room8	9		23			
2	Room10	213		13	Room9	15		24			
3	Room11	0		14				25			
4	Room12	84		15				26			
5	Room13	8		16				27			
6	Room2	0		17				28			
7	Room3	89		18				29			
8	Room4	165		19				30			
9	Room5	18		20				31			
10	Room6	514		21				32			
11	Room7	38		22				Total for all rooms			1153



ENERGY STAR Single-Family New Homes National HVAC Design Report, Version 3 / 3.1 /3.2 (Rev. 12)

HVAC Designer Responsibilities:

- Complete one National HVAC Design Report for each system design for a house plan, created for either the specific plan configuration (i.e., elevation, option, orientation, & county) of the home to be certified or for a plan that is intended to be built with different configurations (i.e., different elevations, options, and/or orientations). Visit www.energystar.gov/newhomeshvacdesign and see Footnote 2 for more information.
- Obtain efficiency features (e.g., window performance, insulation levels, and infiltration rate) from the builder or Rater.³
- Provide the completed National HVAC Design Report to the builder or credentialed HVAC contractor and to the Rater.

1. Design Overview

1.1 Designer name: _____ Designer company: Crystal Air & Water, Inc. Date: Aug 27, 2024
1.2 Select which party you are providing these design services to: ☒ Builder or ☐ Credentialed HVAC contractor
1.3 Name of company you are providing these design services to (if different than Item 1.1): _____ or Owner Builder
1.4 Area that system serves: ☒ Whole-house ☐ Upper-level ☐ Lower-level ☐ Other
1.5 Is cooling system for a temporary occupant load? ☐ Yes ☒ No
1.6 House plan: _____ Check box to indicate whether the system design is site-specific or part of a group:
☒ Site-specific design. Option(s) & elevation(s) modeled:
☐ Group design. Group #: 0 out of 0 total groups for this house plan. Configuration modeled: _____

2. Dwelling Unit Mechanical Ventilation System Design ("Vent System") & Inlets in Return Duct

Designer
Verified

Airflow:

21 Ventilation airflow design rate & run-time meet the requirements of ASHRAE 62.2-2010 or later ☐
22 Ventilation airflow rate required by 62.2 for a continuous system: 0 CFM -
23 Design for this system: Vent. airflow rate: _____ CFM Run-time per cycle: 0 minutes Cycle time: 0 minutes -

System Type & Controls:

24 Specified system type: ☐ Supply ☐ Exhaust ☒ Balanced -
25 Specified control location: _____ (e.g., Master bath, utility room) -
26 Specified controls allow the system to operate automatically, without occupant intervention. ☐
27 Specified controls include a readily-accessible ventilation override and a label has also been specified if its function is not obvious (e.g., a label is required for a toggle wall switch, but not for a switch that's on the ventilation equipment). ☐
28 For any outdoor air inlet designed to connect to a ducted return of the HVAC system, specified controls automatically restrict airflow using a motorized damper during ventilation off-cycle and occupant override. ☐
Sound: 29 The fan of the specified system is rated ≤ 3 sones if intermittent and ≤ 1 sone if continuous, or exempted ☐

Efficiency:

210 If Vent System controller operates the HVAC fan, then HVAC fan operation is intermittent and either the fan type in Item 4.7 is ECM/ICM or the controls will reduce the run-time by accounting for HVAC system heating or cooling hours. ☐
211 If bathroom fans are specified as part of the system, then they are ENERGY STAR certified ☐

Air Inlet Location: (Complete this section if system has a specified air inlet location; otherwise check "N/A") ☐ N/A

212 Inlet pulls ventilation air directly from outdoors and not from attic, crawlspace, garage, or adjacent dwelling unit ☐
213 Inlet is ≥ 2 ft. above grade or roof deck; ≥ 10 ft. of stretched-string distance from known contamination sources (e.g., stack, vent, exhaust, vehicles) not exiting the roof, and ≥ 3 ft. from known sources exiting the roof ☐

3. Room-by-Room Heating & Cooling Loads

3.1 Room-by-room loads calculated using: ☒ Unbridged ACCA Manual J v8 ☐ 2013 ASHRAE Fundamentals ☐ Other per AHJ -
3.2 Indoor design temperatures used in loads are 70°F for heating and 75°F for cooling ☐
3.3 Outdoor design temperatures used in loads: (See Footnote 17 and energystar.gov/hvacdesign/temps)
County & State, or US Territory, selected: Alachua, FL Cooling season: 92 °F Heating season: 33 °F -
3.4 Number of occupants used in loads: 9 -
3.5 Conditioned floor area used in loads: 1860 Sq. Ft. -
3.6 Window area used in loads: 172 Sq. Ft. -
3.7 Predominant window SHGC used in loads: 0.57 -
3.8 Infiltration rate used in loads: Summer: 0.20 Winter: 0.38 -
3.9 Mechanical ventilation rate used in loads: 0 CFM -

Loads At Design Conditions (kBtu/h)		N	NE	E	SE	S	SW	W	NW	
Cooling	3.10 Sensible heat gain (By orientation)	22.9	25.9	26.7	25.7	22.9	25.2	26.0	25.4	-
	3.11 Latent heat gain (Not by orientation)	5.6								-
	3.12 Total heat gain (By orientation)	28.5	31.6	32.4	31.4	28.5	30.8	31.6	31.1	-
	3.13 Maximum - minimum total heat gain (Item 3.12) across orientations =				3.9			Variation is ≤ 6 kBtu/h		<input checked="" type="checkbox"/>
Heating	3.14 Total heat loss (Not by orientation)	25.8								-



ENERGY STAR Single-Family New Homes National HVAC Design Report, Version 3 / 3.1 / 3.2 (Rev. 12)

4. Heating & Cooling Equipment Selection										Designer Verified	
4.1 Equipment selected per ACCA Manual S (see Footnote 25 & 26).										<input type="checkbox"/>	
Air Conditioner / Heat Pump (Complete if air conditioner or heat pump will be installed; otherwise check "N/A")										<input type="checkbox"/> N/A	
4.2 Equipment type: <input type="checkbox"/> Cooling-only air conditioner or <input checked="" type="checkbox"/> Cooling & heating heat pump										-	
4.3 Condenser manufacturer & model: Trane 4TWR6036N1										-	
4.4 Evaporator / fan coil manufacturer & model: Trane TEM6A0B30H21++TDR										-	
4.5 AHRI reference #: 209068075										-	
4.6 AHRI listed efficiency: 12 / 16 EER / SEER Air-source heat pump: 7.5 HSPF Ground-source heat pump: COP										-	
4.7 Evaporator fan type: <input type="checkbox"/> PSC <input type="checkbox"/> ECM/ICM <input checked="" type="checkbox"/> Other:										-	
4.8 Compressor type: <input checked="" type="checkbox"/> Single-speed <input type="checkbox"/> Two-speed <input type="checkbox"/> Variable-speed										-	
4.9 Latent capacity at design conditions, from OEM expanded performance data:										0 kBtu/h	
4.10 Sensible capacity at design conditions, from OEM expanded performance data:										0 kBtu/h	
4.11 Total capacity at design conditions, from OEM expanded performance data:										0 kBtu/h	
4.12 Air-source heat pump capacity: At 17°F: 222 kBtu/h At 47°F: 352 kBtu/h										<input type="checkbox"/> N/A	
4.13 Cooling sizing % = Total capacity (Item 4.11) divided by maximum total heat gain (Item 3.12): 0 %										-	
4.14 Complete this item if Condition B Climate will be used to select sizing limit in Item 4.15. Otherwise, check "N/A":										<input checked="" type="checkbox"/> N/A	
4.14.1 Load sensible heat ratio = Max. sensible heat gain (Item 3.10) / Max. total heat gain (Item 3.12) = 83%										-	
4.14.2 HDD / CDD ratio (Visit energystar.gov/hvacdesign to determine this value for the design location) = 0.2										-	
4.15 Check box of applicable cooling sizing limit from chart below:										-	
Equipment Type (Per Item 4.2) & Climate Condition (Per Item 4.14)		Compressor Type (Per Item 4.8)									
		Single-Speed		Two-Speed		Variable-Speed					
For Cooling-Only Equipment or For Cooling Mode of Heat Pump in Condition A Climate		<input type="checkbox"/>	Recommended: 90 – 115% Allowed: 90 – 130%	<input type="checkbox"/>	Recommended: 90 – 120% Allowed: 90 – 140%	<input type="checkbox"/>	Recommended: 90 – 130% Allowed: 90 – 160%				
For Cooling Mode of Heat Pump in Condition B Climate		<input type="checkbox"/>	90% - 100%, plus 15 kBtu/h	<input type="checkbox"/>	90% - 100%, plus 15 kBtu/h	<input type="checkbox"/>	90% - 100%, plus 15 kBtu/h				
4.16 Cooling sizing % (4.13) is within cooling sizing limit (4.15)										<input type="checkbox"/>	
Furnace (Complete if furnace will be installed; otherwise check "N/A")										<input checked="" type="checkbox"/> N/A	
4.17 Furnace manufacturer & model:										-	
4.18 Listed efficiency: AFUE										-	
4.19 Total capacity: kBtu/h										-	
4.20 Heating sizing % = Total capacity (Item 4.19) divided by total heat loss (Item 3.14): 0%										-	
4.21 Check box of applicable heating sizing limit from chart below:										-	
When Used for Heating Only					When Paired With Cooling						
<input type="checkbox"/> 100 - 140%					<input type="checkbox"/> Recommended: 100 – 140% Allowed: 100 – 400%						
4.22 Heating sizing % (4.20) is within heating sizing limit (4.21)										<input type="checkbox"/>	
5. Duct Design (Complete if heating or cooling equipment will be installed with ducts; otherwise check "N/A")										<input type="checkbox"/> N/A	
5.1 Duct system designed for the equipment selected in Section 4, per ACCA Manual D										<input checked="" type="checkbox"/>	
5.2 Design HVAC fan airflow: Cooling mode 1153 CFM Heating mode 1153 CFM										-	
5.3 Design HVAC fan speed setting (e.g., low, medium, high): Cooling mode Medium Heating mode Medium										-	
5.4 Design total external static pressure (corresponding to the mode with the higher airflow in Item 5.2): 0 INWC										-	
5.5 Room-by-room design airflows documented below (which must sum to the mode with the higher airflow in Item 5.2)										-	
Room Name		Design Airflow (CFM)		Room Name		Design Airflow (CFM)		Room Name		Design Airflow (CFM)	
1	Room1	0		12	Room8	9		23			
2	Room10	213		13	Room9	15		24			
3	Room11	0		14				25			
4	Room12	84		15				26			
5	Room13	8		16				27			
6	Room2	0		17				28			
7	Room3	89		18				29			
8	Room4	165		19				30			
9	Room5	18		20				31			
10	Room6	514		21				32			
11	Room7	38		22				Total for all rooms			1153