

CAROL CHADWICK, P.E.

*Civil Engineer*

1208 S.W. Fairfax Glen

Lake City, FL 32025

307.680.1772

ccpewyo@gmail.com

www.carolchadwickpe.com

April 20, 2020

Matthew Erking

Erking Construction Group

matthew1@erkinghomes.com

re: ELEVATION LETTER – 8566 SE COUNTY ROAD 245, LAKE CITY, FL

Permit #38869

As requested, I inspected the building site for the proposed construction at the above referenced site. The site was graded so that all runoff is directed away from the structure. A swale was constructed across the driveway to allow precipitation drain to the south side of the lot from the front of the home. The disturbed area surrounding the home had been seeded to prevent erosion and sedimentation.

I certify that the minimum finished floor elevation listed above will protect the structure against water damage from a base flood event, as defined in Article 8 of the Land Development Regulations.

Should you have any questions, please don't hesitate to contact me.

Respectfully,



Carol Chadwick, PE  
cn=Carol Chadwick, PE,  
o=This item has been  
electronically signed and  
sealed by Carol Chadwick, PE  
using a digital signature., ou,  
email=ccpewyo@gmail.com,  
c=US  
2020.04.20 19:42:46 -04'00'

Carol Chadwick, P.E.

Photo 1. Driveway showing swale for drainage to the south side of the site.



Photo 2. Grading showing positive drainage from the front of the home.



Photo 3. Grading showing positive drainage from the back of the home.

