

July 27, 2022

Pinellas County Florida

Reference: 190 ft Guyed Support Tower Construction (Lake City, Fl.)

To whom it may concern:

The attached calculations and drawings have been reviewed by RGM Engineers, Inc. The calculations and drawings provided are acceptable and the design meets or exceeds the requirements of the 2020 FBC 7^{h} edition for wind load of minimum of 130 mph and exposure of C.

If I can be of any further assistance, please feel free to contact me at 904-814-7633.

Thank you,

Robert G. Morgen Jr. P.E. #58118

THIS ITEM HAS HIPE PLECTRONICALLY SIGNPED A STALKEE MY ROBERT O'ANORTH, M., P. & O'THE NATE DISCLATION OF THIS INCOMENT USENG A SHA AL THENTECHNOLOGIE WINTED COTTES OF THEN THEN THAT ARE NOT CONSIDERED AND AN ANALY AND THE ADD THE STAL AUTHONICATION CODE MUST DE VIEWHER STAL AUTHONICATION CODE MUST DE VIEWHER AND ANY THA MORE CODES



2022.07.2 7 07:50:36 -04'00'