

JOB NO.: 75-25
DATE TESTED: 1-1-55

ENGINEERING & TESTING LABORATORY
P.O. Box 1925, Lake City, FL 32056-1925
2907 Spring Glen Road • Jacksonville, FL 32207



(P. 2937) Drive Cylinder

REPORT OF IN-PLACE DENSITY TEST

(D-2922) Nuclear

THOD: ✓ (D-2922) N Steward Loop

PROJECT: Ch. 1. Crawford

CLIENT: Stacy SAC

GENERAL CONTRACTOR: _____

OIL USE (SEE NOTE): 1

TECHNICIAN: Don Berg

MODIFIED (ASTM D-1557): _____

— 100 —

TEST NO.	TEST LOCATION	DEPTH ELEV. LIFT	PROCTOR NO.	WET DENS. LBS. CU FT.	DRY DENS. LBS. CU FT.	MOIST PERCENT	% MAX DENS.
65	9'E Center NW Corner of Rd	13"	1	111.4	106.3	4.8	101
9'E	21.5' Center NW Corner of Rd	13"	1	114.2	106.1	7.6	101
9 N B	10' W from H.S. Corner of Rd	14"	1	109.5	106.3	3.0	101

REMARKS:

PROCTOR

SOIL DESCRIPTION

PROCTOR VALUE

OPT. MOIST.

NOTE: 1. Building Fill 2. Trench Backfill 3. Base Course 4. Subbase/Stabilized Subgrade 5. Embankment 6. Subgrade/Natural Soil 7. Other
The test results presented in this report are specific only to the samples tested at the time of testing. The tests were performed in accordance with generally accepted methods and standards. Since material conditions can vary between test location and change with time, sound judgment should be exercised with regard to the use and interpretation of the data.