

15 JUNE 2021

TROY CREWS, BUILDING OFFICIAL
COLUMBIA COUNTY BUILDING DEPARTMENT
COLUMBIA COUNTY COURTHOUSE ANNEX

RE: LUNDY 6 UNIT APARTMENT BUILDING
PERMIT Nr.: _____


DEAR SIR:

PLEASE BE ADVISED OF THE FOLLOWING CHANGE TO THE CONSTRUCTION
DOCUMENTS FOR THE ABOVE REFERENCED PROJECT:

IN LIEU OF THE CMU DEMISING PARTITION BETWEEN THE VARIOUS
UNITS/TENANTS, THE WALL SHALL BE CONSTRUCTED IN ACCORDANCE WITH
THE ATTACHED FRAME 2 HOUR RATED WALL. AT THE OWNERS DISCRETION,
THE STUDS MAY BE 2X6 IN LIEU OF 2X4 SHOWN. THE INTERIOR CAVITY
MAY BE FILLED WITH FIBERGLASS INSULATION.

SHOULD YOU HAVE ANY QUESTIONS, PLEASE CALL FOR ASSISTANCE.

REGARDS,
NICHOLAS PAUL GEISLER, ARCHITECT AR0007005



Digitally signed by: N. P. GEISLER
DN: CN = N. P. GEISLER C = US
O = AR0007005 OU = ARCHITECT
Date: 2021.06.15 16:21:52 -05'00'