

**Mark D. Duren and
Associates, Inc.**
Professional Surveyor and Mapper

1604 SW SISTERS WELCOME ROAD
Lake City, FL 32025
386-758-9831 Phone
386-758-8010 Fax
mddpsm@markduren.com
jldmddpsm@gmail.com

October 30, 2020

IE. Floor Elevation of dwelling under on tax Parcel No.24-4S-16-03114-121.

To Whom It May Concern,

A minimum floor elevation of 101.5 feet, the datum is not specified on the plat, was established for the above referenced parcel according to the record plat of "Cannon Creek Place", Plat Book 8, pages 31 – 34.

The elevation of the top of the concrete slab foundation of the main floor of the dwelling is 101.6 feet. The elevation was derived from a benchmark set by Britt Surveying and Mapping, LLC, According to Scott Britt, LS 5757, the benchmark is based on the "plat datum".



Mark D. Duren