



NFPS



PO BOX 3823
LAKE CITY, FL 32056



PHONE (386) 752-4675
FAX (386) 752-4674



www.nfps.net

DATE: Thursday, June 02, 2022

TO: Columbia County Building Department

FROM: James B. Smith, PSM – North Florida Professional Services

CC: Milton Smith

RE: Finished Floor Elevation – 152 SW White Ash Glen, Lake City, FL 32024

This is to certify that the following elevations of were obtained on the finished floor of a building constructed on Parcel # 04-4S-16-02439-115 at the address of 152 SW Ash Gln., Lake City, FL 32024

Permit # 44339 FFE: 117.71'

The required elevation is 117.00'

James B. Smith, PSM
Florida Certification No. 7355

