

March 6, 2025

Columbia County
Building & Zoning Department
135 NE Hernando Avenue
Lake City, FL 32055



Subject: Variations Letter – Equipment Slab Size (NSB)
Permit: 000051754
AT&T Site: Lulu (SBA 10579357)
Site Address: 120 SE Community Road, Lulu, FL 32061
APX Project: 24-0362.04

Dear Sir or Madam:

APX Engineering Group, LLC prepared constructions drawings for AT&T dated January 31, 2025 for their installation of proposed co-location equipment at the existing telecommunication facility located at the above-referenced site. This design indicates installing a combined slab-on-grade to support the equipment cabinet, backup power generator, and utility h-frame. However, individual slabs-on-grade were installed to support the equipment cabinet and backup power generator, respectively, and the utility h-frame was embedded into to existing soil. This variation continues to provide the minimum equipment support required by the Florida Building Code. Therefore, this variation is acceptable to us.

This letter has been prepared for the purpose of informing the County with respect to the specific installation described. It is intended for the exclusive use of the Columbia County and AT&T. The information, assumptions and recommendations contained in this letter should not be used by others for any purpose without express written authorization from APX.

If we can be of any further assistance, please do not hesitate to contact us directly.

Sincerely,

APX Engineering Group, LLC

Michael A. Phillips, P.E.
Chief Engineer
Florida License #68312