

FIELD DENSITY WORKSHEET

CLIENT Maronda Homes DATE 2-13-25
Cadence PROJECT NO. _____
 PROJECT NAME 279 SW ~~Cadence~~ Glen Lake City PERMIT NO. _____
 EARTH CONTRACTOR Forest Grove Lot 9 TESTED BY ce
 COMPACTION REQUIREMENT (%) 95 ☐ Standard Proctor ☒ Modified Proctor FIELD CONTACT _____
 TOTAL ON-SITE TIME _____ MILES FROM OFFICE _____
☐ Limerock ☐ Subgrade ☐ Pipe Backfill ☒ Building Pad ☐ Building Footing ☐ Other _____

TEST LOCATION	LAB PROCTOR		TEST DEPTH	PROBE DEPTH	% MOIST.	WET DENSITY (PCF)	DRY DENSITY (PCF)	% COMP.
	DENS.	OMC						
Approx 15' NE of SW corner	113.0	9.7	FLG	12"	43	115.3	110.5	97.8
CTR OF PAD)	1))	48	116.6	111.3	98.5
15' SW of NE corner)	1))	41	114.1	109.6	97.0

REMARKS _____

- * Density failed to meet minimum project requirement
- ** Retest indicates minimum density requirement was obtained.
- () Client is aware of unsatisfactory test results.