

**May 31, 2019**

James Waller  
217 SW Upstate Glen  
Lake City, FL 32024

**Subject: Permit # 38049 - Lot 49, Oaks of Lake City, Phase 1 - Elevation Letter**

Dear Mr. Waller:

Daniel & Gore, LLC has performed a vertical survey on Lot 49, Oaks of Lake City Phase 1, Columbia County, Florida from a benchmark being a concrete monument (P.R.M.) at the P.C. of Lot 75, Oaks of Lake City Phase 2 (elevation – 91.745', NAVD 1988) and have determined the following:

- The Subdivision plat requires the minimum finish floor elevation to be 81.0'.
- The top of the concrete foundation is at 86.8', being 5.8' above the minimum finish floor requirement.

If you have any questions, please call me.

Sincerely,



Scott Daniel, PSM