

**March 30, 2021**

Doug Edgey  
320 SW Elk Hunter Glen  
Ft. White, FL 32038

**Subject: Lot 9, Meadow Wood - Elevation Letter**

Dear Doug:

Daniel & Gore, LLC has performed a vertical survey on Lot 9, MEADOW WOOD, Columbia County, Florida from a benchmark being a concrete monument (P.R.M.) at the North line of Lot 3, Meadow Wood (elevation – 162.38', NAVD 1988) and have determined the following:

- The Subdivision plat requires the minimum finish floor elevation to be the higher of 163.0' or 8" above the highest adjacent grade.
- We have set a rebar & cap at the mid-point of the North line of Lot 9 with an elevation of 163.0' on the top of the cap.

If you have any questions, please call me.

Sincerely,

Scott Daniel, PSM

