

August 7, 2020

Aaron Simque Homes
333 SW Rosemary Drive
Lake City, FL 32025

Subject: Permit # 39456 - Lots 82 & 83, Preserve at Laurel Lake, Unit 1

Dear Aaron:

Daniel & Gore, LLC has performed a vertical survey on Lots 82 & 83, Preserve at Laurel Lake, Unit 1, Columbia County, Florida from a benchmark being a 60d nail at the common lot line between Lots 8 & 9 (elevation – 116.12', NGVD 1929) and have determined the following:

- The Subdivision plat requires the minimum finish floor elevation to be 118.2'.
- The elevation of the finish floor is at 119.2', being 1.0' above the minimum finish floor requirement.

If you have any questions, please call me.

Sincerely,



Scott Daniel, PSM

