

CAROL CHADWICK, P.E.

*Civil Engineer*

1208 S.W. Fairfax Glen

Lake City, FL 32025

307.680.1772

ccpewyo@gmail.com

www.carolchadwickpe.com

December 4, 2022

re: Idaho Timber Site Plan Fire Flow Report

Per the site plan, a new 40' by 154' open storage building will be constructed in an area currently covered with asphalt. The site is currently serviced by the City of Lake City water system. The fire hydrant locations are shown on the attached aerial. Water will need to be ported to the site because a portion of the property is outside the 500' buffer radius.

Please contact me at 307.680.1772 if you have any questions.

Respectfully,



Digitally signed by Carol Chadwick  
DN: c=US, o=Florida,  
dnQualifier=A01410D0000017EB6  
D924CE0005954C, cn=Carol  
Chadwick  
Date: 2022.12.04 19:34:42 -05'00'

Carol Chadwick, P.E.

