

COLUMBIA COUNTY BUILDING DEPARTMENT RESIDENTIAL CHECK LIST

MINIMUM PLAN REQUIREMENTS: FLORIDA BUILDING CODE RESIDENTIAL 2023 EFFECTIVE 1 JANUARY 2024 AND THE NATIONAL ELECTRICAL 2020 EFFECTIVE 1 JANUARY 2024

ALL REQUIREMENTS ARE SUBJECT TO CHANGE

ALL BUILDING PLANS MUST INDICATE COMPLIANCE WITH THE CURRENT FLORIDA BUILDING CODES RESIDENTIAL AND THE NATIONAL ELECTRICAL CODE. ALL PLANS OR DRAWINGS SHALL PROVIDE CALCULATIONS AND DETAILS THAT HAVE THE SEAL AND SIGNATURE OF A CERTIFIED ARCHITECT OR ENGINEER REGISTERED IN THE STATE OF FLORIDA, OR ALTERNATE METHODOLOGIES, APPROVED BY THE STATE OF FLORIDA BUILDING COMMISSION FOR ONE-AND-TWO FAMILY DWELLINGS, FBC 1609.1 THRU 1609.6.

FOR DESIGN PURPOSES THE FOLLOWING BASIC WIND SPEEDS ARE PER FLORIDA BUILDING CODE FIGURE 1609.3(1)
THROUGH 1809.3(4) ULTIMATE DESIGN WIND SPEEDS FOR RISK CATEGORY AND BUILDINGS AND OTHER
STRUCTURES Revised 7/1/20

Designers name and signature shall be on all documents and a licensed architect or engineer, signature and official embossed seal

Total (Sq. Ft.) under roof 1587

Submit Online at-http://www.columbiacountyfla.com/BuildingandZoning.asp

GENERAL REQUIREMENTS:

APPLICANT - PLEASE CHECK ALL APPLICABLE BOXES BEFORE SUBMITTAL

2 All drawings must be clear, concise, drawn to scale, details that are not used shall be marked void

shall be affixed to the plans and documents as per the FLORIDA BUILDING CODES BUILDING 107.1.

1 Two (2) complete sets of plans containing the following:

3 Condition space (Sq. Ft.) 1311

Site Plan information including:
4 Dimensions of lot or parcel of land

5	Dimensions of all building set backs			
6	Location of all other structures (include square footage of structures) on parcel, existing or proposed well and septic tank and all utility easements.	1		
7	Provide a full legal description of property.	Ņ	10,080,000	
w	ind-load Engineering Summary, calculations and any details are required,			
100	GENERAL REQUIREMENTS: APPLICANT - PLEASE CHECK ALL APPLICABLE BOXES BEFORE SUBMITTAL	Items to include- Each Box shall be Circled as Applicable		
8	Plans or specifications must show compliance with FBCR Chapter 3	Yes	No	NA.
		Select Fr	om Drop	down
9	Basic wind speed (3-second gust), miles per hour			
10	(Wind exposure - if more than one wind exposure is used, the wind exposure and applicable wind direction shall be indicated)			
11				
12	The applicable internal pressure coefficient, Components and Cladding	V	†	
13	The design wind pressure in terms of psf (kN/m²), to be used for the design of exterior component, cladding materials not specifally designed by the registered design professional.	V		
E	evations Drawing including;			٠
14	All side views of the structure	1-V		1
15	Roof pitch	-V		
16		-\/		
17		1-1		
18		i englis		
19		I-V		
20	Building height from the established grade to the roofs highest peak	W	ad afilless	

Items to Include-Each Box shall be

Circled as

Applicable Select From Drop down

Flo	or Framing System: First and/or second story	1 1	- 1
	Floor truss package shall including layout and details, signed and sealed by Florida Registered Professional Engineer		
	Show conventional floor joist type, size, span, spacing and attachment to load bearing walls,	- 1	
11	stem walls and/or priers	- I- T	
12	Girder type, size and spacing to load bearing walls, stem wall and/or priers	-	Treatment
13	Attachment of joist to girder		
14	Wind load requirements where applicable	-	
45	Show required under-floor crawl space	-	
46	Show required amount of ventilation opening for under-floor spaces		
47	Show required covering of ventilation opening		
48	Show the required access opening to access to under-floor spaces	L L	
	Show the sub-floor structural panel sheathing type, thickness and fastener schedule on the edges &		
49	intermediate of the areas structural panel sheathing	-	
50	Show Draftstopping, Fire caulking and Fire blocking	- 1	
51	Show fireproofing requirements for garages attached to living spaces, per FBCR section 302.6	1. 1	
52	Provide live and dead load rating of floor framing systems (psf).		
54	Provide live and dead load facing of floor framing systems (psr).		
FB	CR CHAPTER 6 WOOD WALL FRAMING CONSTRUCTION	Charles V.	
	CENERAL PROJECTION.	CONTRACTOR STREET	o Include-
	GENERAL REQUIREMENTS:		ox shall be
150	APPLICANT - PLEASE CHECK ALL APPLICABLE BOXES BEFORE SUBMITTAL	a literature de la constitución	cled as
		-	olicable
		elect from	Drop do
53	Stud type, grade, size, wall height and oc spacing for all load bearing or shear walls		
54	Fastener schedule for structural members per table FBC 2304.10.1 are to be shown	-V	
55	Show wood structural panel's sheathing attachment to studs, joist, trusses, rafters and structural members, showing fastener schedule attachment on the edges & intermediate of the areas structural	-V	
56	panel sheathing Show all required connectors with a max uplift rating and required number of connectors and oc spacing for continuous connection of structural walls to foundation and roof trusses or rafter systems	-V	
57	Show sizes, type, span lengths and required number of support jack studs, king studs for shear wall opening and girder or header per FBC 2304.3.	-V.	
58	Indicate where pressure treated wood will be placed		Annual Annual
	Show all wall structural panel sheathing, grade, thickness and show fastener schedule for structural	T- , 1	
59	panel sheathing edges & intermediate areas	1	
60	A detail showing gable truss bracing, wall balloon framing details or/and wall hinge bracing detail	L V	
F	BC :ROOF SYSTEMS:		
61	Truss design drawing shall meet section FBC 2303.1 Wood trusses	-V T	
62	Include a layout and truss details, signed and sealed by Florida Professional Engineer	-1/	
63	Show types of connector's assemblies' and resistance uplift rating for all trusses and rafters	-17	
64	Show gable ends with rake beams showing reinforcement or gable truss and wall bracing details	-	
65	Provide dead load rating of trusses	1	
03	Frovide dead load facility of trusses	1-V 1	
F	BC 2304.4:Conventional Roof Framing Layout		
66	Rafter and ridge beams sizes, span, species and spacing	-	
67	Connectors to wall assemblies' include assemblies' resistance to uplift rating	-	
68	Valley framing and support details		
69	Provide dead load rating of rafter system	- /	
FI	SC 2304 8 POOF SHEATHING	1.	
miliand	C 2304.8 ROOF SHEATHING		
70	Include all materials which will make up the roof decking, identification of structural panel sheathing, grade, thickness	-V	
71	Show fastener Size and schedule for structural panel sheathing on the edges & intermediate areas	-1/	
	First product of the		TARGET SHOW THE PARTY OF

Dimensioned area plan showing rooms, attached garage, breeze ways, covered porches,	·/		
deck, balconies Raised floor surfaces located more than 30 inches above the floor or grade			
All exterior and interior shear walls indicated	/		
All Catchor and interior shear wants increase			
Silical Wall Opening Silovin (Williams, Doors and Care)		i i i i i i i i i i i i i i i i i i i	
bedroom (net clear opening shown) and Show compliance with Section FBCR 312.2.1 where the opening of an operable window is located more than 72 inches above the finished grade or surface below, the lowest part of the clear opening of the window shall be a minimum of 24 inches above the finished floor of the room in which the window is located. Glazing between the floor and 24	V		
Safety glazing of glass where needed	-		
	-		
Show stairs with dimensions (width, tread and riser and total run) details of guardrails, Handrails	-		
Identify accessibility of bathroom (see FBCR SECTION 320)			
APPLICANT PLEASE CHECK ALL APPLICABLE BOXES BEFORE SUBMITTAL	Items to Include- Each Box shall be Circled as Applicable		
	COLORO CONTRACTOR INC.	A22535440 (60-b)	MR. J. M. STOTE ST
CR 403: Foundation Plans Location of all load-bearing walls footings indicated as standard, monolithic, dimensions, size	COLORO CONTRACTOR INC.	pplica	ble
Location of all load-bearing walls footings indicated as standard, monolithic, dimensions, size and type of reinforcing.	А	pplica	ble
Location of all load-bearing walls footings indicated as standard, monolithic, dimensions, size and type of reinforcing. All posts and/or column footing including size and reinforcing	А	pplica	ble
Location of all load-bearing walls footings indicated as standard, monolithic, dimensions, size and type of reinforcing. All posts and/or column footing including size and reinforcing Any special support required by soil analysis such as piling.	А	pplica	ble
Location of all load-bearing walls footings indicated as standard, monolithic, dimensions, size and type of reinforcing. All posts and/or column footing including size and reinforcing Any special support required by soil analysis such as piling. Assumed load-bearing valve of soil Pound Per Square Foot	Select	pplica	ble
Location of all load-bearing walls footings indicated as standard, monolithic, dimensions, size and type of reinforcing. All posts and/or column footing including size and reinforcing Any special support required by soil analysis such as piling.	Select	pplica	ble
Location of all load-bearing walls footings indicated as standard, monolithic, dimensions, size and type of reinforcing. All posts and/or column footing including size and reinforcing Any special support required by soil analysis such as piling. Assumed load-bearing valve of soil Pound Per Square Foot Location of horizontal and vertical steel, for foundation or walls (include # size and type) For structures with foundation which establish new electrical utility companies service connection a Concrete Encased Electrode will be required within the foundation to serve as an grounding electrode system. Per the National Electrical Code article 250.52.3	Select	pplica	ble
Location of all load-bearing walls footings indicated as standard, monolithic, dimensions, size and type of reinforcing. All posts and/or column footing including size and reinforcing Any special support required by soil analysis such as piling. Assumed load-bearing valve of soil Pound Per Square Foot Location of horizontal and vertical steel, for foundation or walls (include # size and type) For structures with foundation which establish new electrical utility companies service connection a Concrete Encased Electrode will be required within the foundation to serve as an grounding electrode system. Per the National Electrical Code article 250.52.3	Select	pplica	ble
Location of all load-bearing walls footings indicated as standard, monolithic, dimensions, size and type of reinforcing. All posts and/or column footing including size and reinforcing Any special support required by soil analysis such as piling. Assumed load-bearing valve of soil Pound Per Square Foot Location of horizontal and vertical steel, for foundation or walls (include # size and type) For structures with foundation which establish new electrical utility companies service connection a Concrete Encased Electrode will be required within the foundation to serve as an grounding electrode system.	Select	pplica	ble
Location of all load-bearing walls footings indicated as standard, monolithic, dimensions, size and type of reinforcing. All posts and/or column footing including size and reinforcing Any special support required by soil analysis such as piling. Assumed load-bearing valve of soil Pound Per Square Foot Location of horizontal and vertical steel, for foundation or walls (include # size and type) For structures with foundation which establish new electrical utility companies service connection a Concrete Encased Electrode will be required within the foundation to serve as an grounding electrode system. Per the National Electrical Code article 250.52.3 CR 506: CONCRETE SLAB ON GRADE Show Va per retarder (6mil. Polyethylene with joints overlaid 6 inches and sealed) Show control joints, synthetic fiber reinforcement or welded fire fabric reinforcement and Supports	Select	pplica	ble
Location of all load-bearing walls footings indicated as standard, monolithic, dimensions, size and type of reinforcing. All posts and/or column footing including size and reinforcing Any special support required by soil analysis such as piling. Assumed load-bearing valve of soil Pound Per Square Foot Location of horizontal and vertical steel, for foundation or walls (include # size and type) For structure: with foundation which establish new electrical utility companies service connection a Concrete Encased Electrode will be required within the foundation to serve as an grounding electrode system. Per the National Electrical Code article 250.52.3 CR 506: CONCRETE SLAB ON GRADE Show Va per retarder (6mil. Polyethylene with joints overlaid 6 inches and sealed)	Select	pplica	ble
Location of all load-bearing walls footings indicated as standard, monolithic, dimensions, size and type of reinforcing. All posts and/or column footing including size and reinforcing Any special support required by soil analysis such as piling. Assumed load-bearing valve of soil Pound Per Square Foot Location of horizontal and vertical steel, for foundation or walls (include # size and type) For structures with foundation which establish new electrical utility companies service connection a Concrete Encased Electrode will be required within the foundation to serve as an grounding electrode system. Per the National Electrical Code article 250.52.3 CR 506: CONCRETE SLAB ON GRADE Show Vapor retarder (6mil. Polyethylene with joints overlaid 6 inches and sealed) Show control joints, synthetic fiber reinforcement or welded fire fabric reinforcement and Supports CR 318: PROTECTION AGAINST TERMITES Indicate on the foundation plan if soil treatment is used for subterranean termite prevention or Submit other approved termite protection methods. Protection shall be provided by registered termiticides	Select	pplica	ble
Location of all load-bearing walls footings indicated as standard, monolithic, dimensions, size and type of reinforcing. All posts and/or column footing including size and reinforcing Any special support required by soil analysis such as piling. Assumed load-bearing valve of soil Pound Per Square Foot Location of horizontal and vertical steel, for foundation or walls (include # size and type) For structures with foundation which establish new electrical utility companies service connection a Concrete Encased Electrode will be required within the foundation to serve as an grounding electrode system. Per the National Electrical Code article 250.52.3 CR 506: CONCRETE SLAB ON GRADE Show Va per retarder (6mil. Polyethylene with joints overlaid 6 inches and sealed) Show control joints, synthetic fiber reinforcement or welded fire fabric reinforcement and Supports CR 318: PROTECTION AGAINST TERMITES Indicate on the foundation plan if soil treatment is used for subterranean termite prevention or Submit other approved termite protection methods. Protection shall be provided by registered	Select	pplica	ble
	All exterior and interior shear walls indicated Shear wall opening shown (Windows, Doors and Garage doors) Show compliance with Section FBCR 310 Emergency escape and rescue opening shown in each bedroom (net clear opening shown) and Show compliance with Section FBCR 312.2.1 where the opening of an operable window is located more than 72 inches above the finished grade or surface below, the lowest part of the clear opening of the window shall be a minimum of 24 inches above the finished floor of the room in which the window is located. Glazing between the floor and 24 inches shall be fixed or have openings through which a 4-inch-diameter sphere cannot pass. Safety glazing of glass where needed Fireplaces types (gas appliance) (vented or non-vented) or wood burning with Hearth (see chapter 10 and chapter 24 of FBCR) Show stairs with dimensions (width, tread and riser and total run) details of guardrails, Handrails Identify accessibility of bathroom (see FBCR SECTION 320) materials placed within opening or onto/into exterior walls, soffits or roofs shall be roval number and mfg. installation information submitted with the plans Florida product approval form) GENERAL REQUIREMENTS:	All exterior and interior shear walls indicated Shear wall opening shown (Windows, Doors and Garage doors) Show compliance with Section FBCR 310 Emergency escape and rescue opening shown in each bedroom (net clear opening shown) and Show compliance with Section FBCR 312.2.1 where the opening of an operable window is located more than 72 inches above the finished grade or surface below, the lowest part of the clear opening of the window shall be a minimum of 24 inches above the finished floor of the room in which the window is located. Glazing between the floor and 24 inches shall be fixed or have openings through which a 4-inch-diameter sphere cannot pass. Safety glazing of glass where needed Fireplaces types (gas appliance) (vented or non-vented) or wood burning with Hearth (see chapter 10 and chapter 24 of FBCR) Show stairs with dimensions (width, tread and riser and total run) details of guardrails, Handrails Identify accessibility of bathroom (see FBCR SECTION 320)	All exterior and interior shear walls indicated Shear wall opening shown (Windows, Doors and Garage doors) Show compliance with Section FBCR 310 Emergency escape and rescue opening shown in each bedroom (net clear opening shown) and Show compliance with Section FBCR 312.2.1 where the opening of an operable window is located more than 72 inches above the finished grade or surface below, the lowest part of the clear opening of the window shall be a minimum of 24 inches above the finished floor of the room in which the window is located. Glazing between the floor and 24 inches shall be fixed or have openings through which a 4-inch-diameter sphere cannot pass. Safety glazing of glass where needed Fireplaces types (gas appliance) (vented or non-vented) or wood burning with Hearth (see chapter 10 and chapter 24 of FBCR) Show stairs with dimensions (width, tread and riser and total run) details of guardrails, Handrails Identify accessibility of bathroom (see FBCR SECTION 320)

Floor Plan Including:

ROOF ASSEMBLIES FRC Chapter 9		-, -, -,
72 Include all materials which will make up the roof assembles covering	I-V	
72 Include all materials which will make up the roof assembles covering 73 Submit Florida Product Approval numbers for each component of the roof assembles covering	ng -	<u>, </u>

FBC Energy Chapter 4

Residential construction shall comply with this code by using the following compliance methods in the FBC Chapter 4, Residential buildings compliance methods. Two of the required forms are to be submitted, N1100.1.1.1 As an alternative to the computerized Compliance Method A, the Alternate Residential Point System Method hand calculation, Alternate Form 600 A, may be used. All requirements specific to this calculation are located in Sub appendix C to Appendix G. Buildings complying by this alternative shall meet all mandatory requirements of this chapter. Computerized versions of the Alternate Residential Point System Method shall not be acceptable for code compliance.

	GENERAL REQUIREMENTS: PPLICANT - PLEASE CHECK ALL APPLICABLE BOXES BEFORE SUBMITTAL Circled a Applicab	
	¥1111111111111111111111111111111111111	elect from Drop Down
74	Show the insulation R value for the following areas of the structure	
	Attic space	-V/
76	Exterior wall cavity	I- V
77	Crawl space	
H	VAC information	
78	Submit two copies of a Manual J sizing equipment or equivalent computation study	I-V . I
79	Exhaust fans shown in bathrooms Mechanical exhaust capacity of 50 cfm intermittent or 20 cfm continuous required	- /
80	Show clothes dryer route and total run of exhaust duct	1.0
Pli	umbing Fixture layout shown	
	All fixtures waste water lines shall be shown on the foundationplan	- /
82	Show the location of water heater	1-0
THE RESIDENCE OF	ivate Potable Water	
	Pump motor horse power	I- V ,
	Reservoir pressure tank gallon capacity	(- V
85	Rating of cycle stop valve if used	
Ele	ectrical layout shown including	
86	Show Switches, receptacles outlets, lighting fixtures and Ceiling fans	I- V 1
87	Show all 120-volt, single phase, 15- and 20-ampere branch circuits outlets required to be protected by Ground-Fault Circuit Interrupter (GFCI) Article 210.8 A	- V
88	Show the location of smoke detectors & Carbon monoxide detectors	I- V.
89	Show service panel, sub-panel, location(s) and total ampere ratings	1- 1
90	On the electrical plans identify the electrical service overcurrent protection device for the main electrical service. This device shall be installed on the exterior of structures to serve as a disconnecting means for the utility company electrical service. Conductors used from the exterior disconnecting means to a panel or sub panel shall have four-wire conductors, of which one conductor shall be used as an equipment ground. Indicate if the utility company service entrance cable will be of the overhead or underground type.	
91	For structures with foundation which establish new electrical utility companies service connection a Concrete Encased Electrode will be required within the foundation to serve as an Grounding electrode system. Per the National Electrical Code article 250.52.3 Appliances and HVAC equipment and disconnects	V
92	Show all 120-volt, single phase, 15- and 20-ampere branch circuits supplying outlets installed in dwelling unit family rooms, dining rooms, living rooms, parlors, libraries, dens, bedrooms, sunrooms, recreation rooms, closets, hallways, or similar rooms or areas shall be protected by a listed Combination arc-fault circuit interrupter, Protection device.	- 🗸

Notice Of Commencement:

A notice of commencement form RECORDED in the Columbia County Clerk Office is required to be filed with the Building Department BEFORE ANY INSPECTIONS can be performed.

GENERAL REQUIREMENTS: APPLICANT – PLEASE CHECK ALL APPLICABLE BOXES BEFORE SUBMITTAL

Items to Include-Each Box shall be Circled as Applicable

IT	EMS 95, 96, & 98 Are Required After APPROVAL from the ZONING DEPT.	Select from Dro	p down
93	Building Permit Application A current Building Permit Application is to be completed, by following the Checklist all supporting documents must be submitted.	-	
94	Parcel Number The parcel number (Tax ID number) from the Property Appraisers Office (386) 758-1083 is required. A copy of property deed is also required. www.columbiacountyfla.com.	-/	
95	Environmental Health Permit or Sewer Tap Approval A copy of a approved Columbia County Environmental Health (386) 758-1058	-	
96	City of Lake City A City Water and/or Sewer letter. Call 386-752-2031		
97	Toilet facilities shall be provided for all construction sites	<u> </u>	
98	Town of Fort White (386) 497-2321 If the parcel in the application for building permit is within the Corporate city limits of Fort White, an approval land use development letter issued by the Town of Fort is required to be submitted with the application for a building permit.	-	
99	Flood Information: All projects within the Floodway of the Suwannee or Santa Fe Rivers shall require permitting through the Suwannee River Water Management District, before submitting a application to this office. Any project located within a flood zone where the base flood elevation (100 year flood) has been established shall meet the requirements of Section 8.5.2 of the Columbia County Land Development Regulations. Any project located within a flood zone where the base flood elevation has not been established (Zone A) shall meet the requirements of Section 8.5.3 of the Columbia County Land Development Regulations (Municode.com)	-	
100	FIRM Flood Maps show the property is in a AE, Floodway, and AH flood zones. Additionally One Foot Rise letters are required for AE and AH zones. In the Floodway Flood zones a Zero Rise letter is required.	ı. - ı.	
101		0 -	
102	Driveway Connection: A Right-of-way application must be applied for with all new structures. If drive is confirmed to be existing, a fee may not be applied. If it is determined a connection is necessary, the fee is \$150.00. If the project is to be located on an F.D.O.T. maintained road, then an F.D.O.T. access permit is required. If the project is to be located on an F.D.O.T. maintained road, then an F.D.O.T. access permit is required.		
103	911 Address: An application for a 911 address must be applied for and received through the Columbia County Office of 911 Addressing Department poline.	1-/	

Ordinance Sec. 90-75. - Construction debris. (e) It shall be unlawful for any person to dispose of or discard solid waste, including construction or demolition debris at any place within the county other than on an authorized disposal site or at the county's solid waste facilities. The temporary storage, not to exceed seven days of solid waste (excluding construction and demolition debris) on the premises where generated or vegetative trash pending disposition as authorized by law or ordinance, shall not be deemed a violation of this section. The temporary storage of construction and demolition debris on the premises where generated or vegetative trash pending disposition as authorized by law or ordinance shall not be deemed in violation of this section; provided, however, such construction and demolition debris must be disposed of in accordance with this article prior to the county's issuance of a certificate of occupancy for the premises. The burning of lumber from a construction or demolition project or vegetative trash when done so with legal and proper permits from the authorized agencies and in accordance with such agencies' rules and regulations, shall not be deemed a violation of this section. No person shall bury, throw, place, or deposit, or cause to be buried, thrown, placed, or deposited, any solid waste, special waste, or debris of any kind into or on any of the public streets, road right-of-way, highways, bridges, alleys, lanes, thoroughfares, waters, canals, or vacant lots or lands within the county. No person shall bury any vegetative trash on any of the public streets, road right-of-way, highways, bridges, lanes, thoroughfares, waters, canals, or lots less than ten acres in size within the county.