

Florida Building Code, 8th Edition (2023) - Energy Conservation

EnergyGauge Summit® Fla/Com-2023, Effective Date: Dec 31, 2023

C407: FBC Total Building Performance Compliance Option

Compliance applying the requirements of Sections C402.5, C403.2, C404, C405.2, C405.4, C405.5, C407 and C408. The building energy cost shall be equal to or less than 85 percent of the standard reference design building.

Check List

Applications for compliance with the Florida Building Code, Energy Conservation shall include:

- ☒ The full compliance report generated by the software that contains the project summary, compliance summary, certifications and detailed component compliance reports.
- ☒ The compliance report must include the full input report generated by the software as contiguous part of the compliance report.
- ☒ Boxes appropriately checked in the Mandatory Section of the compliance report.

PROJECT SUMMARY

Short Desc: Rainbolt Tech

Description: Renovation for Rainbolt Tech

Owner: Rainbow Tech

Address1: 162 SW Spencer Ct

City: Lake City

Address2:

State: FL

Zip: 32024

Type: Office

Class: Renovation to existing building

Jurisdiction: LAKE CITY, COLUMBIA COUNTY, FL (221200)

Conditioned Area: 7603 SF

Conditioned & UnConditioned Area: 7603 SF

No of Stories: 1

Area entered from Plans 7603 SF

Permit No:

Max Tonnage 5

If different, write in: _____

Compliance Summary			
Component	Design	Criteria	Result
Gross Energy Cost (in \$)	3192.00	3493.00	PASSED
LIGHTING CONTROLS			PASSES
EXTERNAL LIGHTING			No Entry
HVAC SYSTEM			PASSES
PLANT			No Entry
WATER HEATING SYSTEMS			PASSES
PIPING SYSTEMS			PASSES
Met all required compliance from Check List?			Yes No/NA
<p>IMPORTANT MESSAGE Info 5009 -- -- -- An input report of this design building must be submitted along with this Compliance Report</p>			

CERTIFICATIONS

I hereby certify that the plans and specifications covered by this calculation are in compliance with the Florida Energy Code

Prepared By: *Rachel Miller*
Rachel Miller

Building _____
Official: _____

Date: 5/16/2024

Date: _____

I certify that this building is in compliance with the FLorida Energy Efficiency Code

Owner Agent: _____

Date: _____

If Required by Florida law, I hereby certify (*) that the system design is in compliance with the Florida Energy Efficiency Code

Architect: Nicholas Geisler

Reg No: AR0007005 Signature _____

Electrical Designer: Nicholas Geisler

Reg No: AR0007005 Signature _____

Lighting Designer: Nicholas Geisler

Reg No: AR0007005 Signature _____

Mechanical Designer: Nicholas Geisler

Reg No: AR0007005 Signature _____

Plumbing Designer: Nicholas Geisler

Reg No: AR0007005 Signature _____

(*) Signature is required where Florida Law requires design to be performed by registered design professionals per C103.1.1.1.2

Rachel Miller

Certified Energy Rater #1494

Project: Rainbolt Tech
 Title: Renovation for Rainbolt Tech
 Type: Office
 (WEA File: FL_JACKSONVILLE_INTL_ARPT.tn3)

Building End Uses

	1) Proposed	2) Baseline
Total	204.10	262.80
	\$3,192	\$4,110
ELECTRICITY(MBtu/kWh/\$)	204.10	262.80
	59783	76957
	\$3,192	\$4,110
AREA LIGHTS	29.10	49.70
	8535	14559
	\$456	\$777
MISC EQUIPMT	73.20	73.20
	21438	21438
	\$1,145	\$1,145
PUMPS & MISC	0.30	0.30
	76	82
	\$4	\$4
SPACE COOL	48.00	66.50
	14058	19482
	\$751	\$1,040
SPACE HEAT	8.10	12.00
	2378	3508
	\$127	\$187
VENT FANS	45.40	61.10
	13298	17888
	\$710	\$955

Credits Applied: None

Passing Criteria = 3493

Design (including any credits) = 3192

Passing requires Proposed Building cost to be at most 85% of
 Baseline cost. This Proposed Building is at 77.7%

PASSES

External Lighting Compliance						
Description	Category	Tradable?	Allowance (W/Unit)	Area or Length or No. of Units (Sqft or ft)	ELPA (W)	CLP (W)
					None	

Project: Rainbolt Tech
Title: Renovation for Rainbolt Tech
Type: Office
(WEA File: FL_JACKSONVILLE_INTL_ARPT.tm3)

Lighting Controls Compliance

Acronym	ID	Description	Area (sq.ft)	Compliance
<u>Corridor</u>	5	<u>Corridor (Corridor)</u>	720	COMPLIANCE: PASSES REQUIRED: All of 7 ; one of 9 CONTROLS IN SPACE: 7-Occupant Sensor Auto OFF (Full or Partial) 9-Time-Switch: Auto Full Off or Scheduled Off
<u>Foyer</u>	5	<u>Foyer (Corridor)</u>	379	COMPLIANCE: PASSES REQUIRED: All of 7 ; one of 9 CONTROLS IN SPACE: 7-Occupant Sensor Auto OFF (Full or Partial) 9-Time-Switch: Auto Full Off or Scheduled Off
<u>Gym</u>	16	<u>Gym (Office - Open Plan)</u>	636	COMPLIANCE: PASSES REQUIRED: All of 1 ; one of 3 ; one of 8 9 CONTROLS IN SPACE: 1-Manual (Local Control) 3-Occupant Sensor (50%) 8-Occupant Sensor Auto Full OFF
<u>Men</u>	6	<u>Men (Toilet and Washroom)</u>	105	COMPLIANCE: PASSES REQUIRED: All of 3 ; one of 8 CONTROLS IN SPACE: 3-Occupant Sensor (50%) 8-Occupant Sensor Auto Full OFF
<u>Women</u>	6	<u>Women (Toilet and Washroom)</u>	150	COMPLIANCE: PASSES REQUIRED: All of 3 ; one of 8 CONTROLS IN SPACE: 3-Occupant Sensor (50%) 8-Occupant Sensor Auto Full OFF

<u>Stairway</u>	<u>4 Stairway (Stair - Active Traffic)</u>	<u>197</u> COMPLIANCE: PASSES REQUIRED: All of 8 ; one of 3 CONTROLS IN SPACE: 3-Occupant Sensor (50%) 8-Occupant Sensor Auto Full OFF
<u>Office 1</u>	<u>17 Office 1 (Office - Enclosed)</u>	<u>253</u> COMPLIANCE: PASSES REQUIRED: All of 1 ; one of 2 3 ; one of 8 CONTROLS IN SPACE: 1-Manual (Local Control) 3-Occupant Sensor (50%) 8-Occupant Sensor Auto Full OFF
<u>Office 2</u>	<u>17 Office 2 (Office - Enclosed)</u>	<u>256</u> COMPLIANCE: PASSES REQUIRED: All of 1 ; one of 2 3 ; one of 8 CONTROLS IN SPACE: 1-Manual (Local Control) 3-Occupant Sensor (50%) 8-Occupant Sensor Auto Full OFF
<u>Office 3</u>	<u>17 Office 3 (Office - Enclosed)</u>	<u>205</u> COMPLIANCE: PASSES REQUIRED: All of 1 ; one of 2 3 ; one of 8 CONTROLS IN SPACE: 1-Manual (Local Control) 3-Occupant Sensor (50%) 8-Occupant Sensor Auto Full OFF
<u>Office 4</u>	<u>17 Office 4 (Office - Enclosed)</u>	<u>150</u> COMPLIANCE: PASSES REQUIRED: All of 1 ; one of 2 3 ; one of 8 CONTROLS IN SPACE: 1-Manual (Local Control) 3-Occupant Sensor (50%) 8-Occupant Sensor Auto Full OFF
<u>Office 5</u>	<u>17 Office 5 (Office - Enclosed)</u>	<u>137</u> COMPLIANCE: PASSES REQUIRED: All of 1 ; one of 2 3 ; one of 8 CONTROLS IN SPACE: 1-Manual (Local Control) 3-Occupant Sensor (50%) 8-Occupant Sensor Auto Full OFF
<u>Office 6</u>	<u>17 Office 6 (Office - Enclosed)</u>	<u>107</u> COMPLIANCE: PASSES REQUIRED: All of 1 ; one of 2 3 ; one of 8 CONTROLS IN SPACE: 1-Manual (Local Control) 3-Occupant Sensor (50%) 8-Occupant Sensor Auto Full OFF

Office 7**17 Office 7 (Office - Enclosed)**

125 COMPLIANCE: PASSES
REQUIRED:
All of |1|; one of |2|3|; one of |8|
CONTROLS IN SPACE:
1-Manual (Local Control)
3-Occupant Sensor (50%)
8-Occupant Sensor Auto Full OFF

Office 8**17 Office 8 (Office - Enclosed)**

200 COMPLIANCE: PASSES
REQUIRED:
All of |1|; one of |2|3|; one of |8|
CONTROLS IN SPACE:
1-Manual (Local Control)
3-Occupant Sensor (50%)
8-Occupant Sensor Auto Full OFF

Office 9**17 Office 9 (Office - Enclosed)**

136 COMPLIANCE: PASSES
REQUIRED:
All of |1|; one of |2|3|; one of |8|
CONTROLS IN SPACE:
1-Manual (Local Control)
3-Occupant Sensor (50%)
8-Occupant Sensor Auto Full OFF

Office 10**17 Office 10 (Office - Enclosed)**

170 COMPLIANCE: PASSES
REQUIRED:
All of |1|; one of |2|3|; one of |8|
CONTROLS IN SPACE:
1-Manual (Local Control)
3-Occupant Sensor (50%)
8-Occupant Sensor Auto Full OFF

Bath**6 Bath (Toilet and Washroom)**

61 COMPLIANCE: PASSES
REQUIRED:
All of |3|; one of |8|
CONTROLS IN SPACE:
3-Occupant Sensor (50%)
8-Occupant Sensor Auto Full OFF

Breakroom**17 Breakroom (Office - Enclosed)**

238 COMPLIANCE: PASSES
REQUIRED:
All of |1|; one of |2|3|; one of |8|
CONTROLS IN SPACE:
1-Manual (Local Control)
3-Occupant Sensor (50%)
8-Occupant Sensor Auto Full OFF

<u>Conference</u>	15 <u>Conference (Conference/meeting (Multiple Functions))</u>	339 COMPLIANCE: PASSES REQUIRED: All of 1 ; one of 2 3 ; one of 8 CONTROLS IN SPACE: 1-Manual (Local Control) 3-Occupant Sensor (50%) 8-Occupant Sensor Auto Full OFF
<u>Corridor</u>	5 <u>Corridor (Corridor)</u>	1,198 COMPLIANCE: PASSES REQUIRED: All of 7 ; one of 9 CONTROLS IN SPACE: 7-Occupant Sensor Auto OFF (Full or Partial) 9-Time-Switch: Auto Full Off or Scheduled Off
<u>Cubicle 1</u>	16 <u>Cubicle 1 (Office - Open Plan)</u>	196 COMPLIANCE: PASSES REQUIRED: All of 1 ; one of 3 ; one of 8 9 CONTROLS IN SPACE: 1-Manual (Local Control) 3-Occupant Sensor (50%) 9-Time-Switch: Auto Full Off or Scheduled Off
<u>Cubicle 2</u>	16 <u>Cubicle 2 (Office - Open Plan)</u>	183 COMPLIANCE: PASSES REQUIRED: All of 1 ; one of 3 ; one of 8 9 CONTROLS IN SPACE: 1-Manual (Local Control) 3-Occupant Sensor (50%) 8-Occupant Sensor Auto Full OFF
<u>Lounge</u>	12 <u>Lounge (Lobby (General) - Reception and Waiting)</u>	329 COMPLIANCE: PASSES REQUIRED: All of 3 ; one of 9 CONTROLS IN SPACE: 3-Occupant Sensor (50%) 9-Time-Switch: Auto Full Off or Scheduled Off
<u>Men</u>	6 <u>Men (Toilet and Washroom)</u>	41 COMPLIANCE: PASSES REQUIRED: All of 3 ; one of 8 CONTROLS IN SPACE: 3-Occupant Sensor (50%) 8-Occupant Sensor Auto Full OFF

<u>Office 11</u>	<u>17 Office 11 (Office - Enclosed)</u>	<u>150</u> COMPLIANCE: PASSES REQUIRED: All of 1 ; one of 2 3 ; one of 8 CONTROLS IN SPACE: 1-Manual (Local Control) 3-Occupant Sensor (50%) 8-Occupant Sensor Auto Full OFF
<u>Office 12</u>	<u>17 Office 12 (Office - Enclosed)</u>	<u>84</u> COMPLIANCE: PASSES REQUIRED: All of 1 ; one of 2 3 ; one of 8 CONTROLS IN SPACE: 1-Manual (Local Control) 3-Occupant Sensor (50%) 8-Occupant Sensor Auto Full OFF
<u>Office 13</u>	<u>17 Office 13 (Office - Enclosed)</u>	<u>87</u> COMPLIANCE: PASSES REQUIRED: All of 1 ; one of 2 3 ; one of 8 CONTROLS IN SPACE: 1-Manual (Local Control) 3-Occupant Sensor (50%) 8-Occupant Sensor Auto Full OFF
<u>Office 14</u>	<u>17 Office 14 (Office - Enclosed)</u>	<u>84</u> COMPLIANCE: PASSES REQUIRED: All of 1 ; one of 2 3 ; one of 8 CONTROLS IN SPACE: 1-Manual (Local Control) 3-Occupant Sensor (50%) 8-Occupant Sensor Auto Full OFF
<u>Office 15</u>	<u>17 Office 15 (Office - Enclosed)</u>	<u>137</u> COMPLIANCE: PASSES REQUIRED: All of 1 ; one of 2 3 ; one of 8 CONTROLS IN SPACE: 1-Manual (Local Control) 3-Occupant Sensor (50%) 8-Occupant Sensor Auto Full OFF
<u>Office 16</u>	<u>17 Office 16 (Office - Enclosed)</u>	<u>80</u> COMPLIANCE: PASSES REQUIRED: All of 1 ; one of 2 3 ; one of 8 CONTROLS IN SPACE: 1-Manual (Local Control) 3-Occupant Sensor (50%) 8-Occupant Sensor Auto Full OFF

<u>Office 17</u>	<u>17 Office 17 (Office - Enclosed)</u>	<u>80</u> COMPLIANCE: PASSES REQUIRED: All of 1 ; one of 2 3 ; one of 8 CONTROLS IN SPACE: 1-Manual (Local Control) 3-Occupant Sensor (50%) 8-Occupant Sensor Auto Full OFF
<u>Office 18</u>	<u>17 Office 18 (Office - Enclosed)</u>	<u>80</u> COMPLIANCE: PASSES REQUIRED: All of 1 ; one of 2 3 ; one of 8 CONTROLS IN SPACE: 1-Manual (Local Control) 3-Occupant Sensor (50%) 8-Occupant Sensor Auto Full OFF
<u>Office 19</u>	<u>17 Office 19 (Office - Enclosed)</u>	<u>269</u> COMPLIANCE: PASSES REQUIRED: All of 1 ; one of 2 3 ; one of 8 CONTROLS IN SPACE: 1-Manual (Local Control) 3-Occupant Sensor (50%) 8-Occupant Sensor Auto Full OFF
<u>Women</u>	<u>6 Women (Toilet and Washroom)</u>	<u>41</u> COMPLIANCE: PASSES REQUIRED: All of 3 ; one of 8 CONTROLS IN SPACE: 3-Occupant Sensor (50%) 8-Occupant Sensor Auto Full OFF
		<div>PASSES</div>

Project: Rainbolt Tech Title: Renovation for Rainbolt Tech Type: Office (WEA File: FL_JACKSONVILLE_INTL_ARPT.tm3)							
System Report Compliance							
AH-1/AH-2	System 1	Constant Volume Air Cooled Split System < 65000 Btu/hr					No. of Units 1
Component	Category	Capacity	Eff Design	Eff Criteria	Integrated Eff-Design	Integrated Eff-Criteria	Compliance
Cooling System	Air Conditioners Air Cooled Split System 45000 - 65000 Btu/h Cooling Capacity	60000	14.30	13.80	7.50		PASSES
Heating System	Electric Furnace	51195	1.00	1.00			PASSES
Air Handling System -Supply	Air Handler (Supply) - Constant Volume	1500	0.80	0.82			PASSES
DS-1/DS-2	5 Ton Multi-head Ductless Minisplit	Constant Volume Air Cooled Split System < 65000 Btu/hr					No. of Units 1
Component	Category	Capacity	Eff Design	Eff Criteria	Integrated Eff-Design	Integrated Eff-Criteria	Compliance
Cooling System	Air Conditioners Air Cooled Split System 45000 - 65000 Btu/h Cooling Capacity	60000	19.00	13.80	7.50		PASSES
Heating System	Heat Pumps Air Cooled (Heating Mode) Split System < 65000 Btu/h Cooling Capacity	60000	8.50	7.50			PASSES
Air Handling System -Supply	Air Handler (Supply) - Constant Volume	1500	0.80	0.82			PASSES
							PASSES

Plant Compliance								
Description	Installed No	Size	Design Eff	Min Eff	Design IPLV	Min IPLV	Category	Compliance
								None

Project: Rainbolt Tech

Title: Renovation for Rainbolt Tech

Type: Office

(WEA File: FL_JACKSONVILLE_INTL_ARPT.tm3)

Water Heater Compliance

Description	Type	Category	Design Eff	Min Eff	Design Loss	Max Loss	Compliance
Water Heater 1	Electric Storage water heater	<= 12 [kW]	0.92	0.92			PASSES
							PASSES

Project: Rainbolt Tech

Title: Renovation for Rainbolt Tech

Type: Office

(WEA File: FL_JACKSONVILLE_INTL_ARPT.tm3)

Piping System Compliance

Category	Pipe Dia [inches]	Is Runout?	Operating Temp [F]	Ins Cond [Btu-in/hr .SF.F]	Ins Thick [in]	Req Ins Thick [in]	Compliance
Domestic and Service Hot Water Systems	0.75	False	105.00	0.28	1.00	0.50	PASSES
							PASSES

Mandatory Requirements (as applicable)

Requirements compiled by US Department of Energy and Pacific Northwest National Laboratory. Adopted for FBC with permission. Not all may be applicable

Topic	Section	Component	Description	Yes	N/A	Exempt
1. To be checked by Designer or Engineer						
6037 Post Construction	C401.3	Envelope	A thermal envelope certificate will be supplied and completed by an approved third party.	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
6031 Fenestration	C402.4.1	Envelope	The vertical fenestration area <= 30 percent of the gross above-grade wall area.	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
6033 Fenestration	C402.4.1	Envelope	The skylight area <= 3 percent of the gross roof area.	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
6036 Fenestration	C402.4.1.1	Envelope	Vertical Fenestration Area Allowance: A maximum of 40 percent of gross above-grade wall area is permitted to be vertical fenestration area provided in buildings not greater than two stories above grade, >= 50 percent of the conditioned floor area is within a daylight zone, in buildings three or more stories above grade, not less than 25 percent of the net floor area is within a daylight zone, daylight responsive controls are installed, and glazing assemblies within the scope of NFRC 200 have visible transmittance >= 1.1 times SHGC.	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
6038 Fenestration	C402.4.1.2	Envelope	A maximum of 6 percent of roof area is permitted to be skylight area provided daylight responsive controls are installed in daylight zones under skylights.	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>

6039 Fenestration	C402.4.2	Envelope	<p>In enclosed spaces > 2,500 ft2 directly under a roof with ceiling heights > 15 ft. and used as an office, lobby, atrium, concourse, corridor, storage, gymnasium/exercise center, convention center, automotive service, manufacturing, non-refrigerated warehouse, retail store, distribution/sorting area, transportation, or workshop, the following requirements apply: (a) the daylight zone under skylights is \leq half the floor area; (b) the skylight area to daylight zone is \geq 3 percent with a skylight VT \geq 0.40; or a minimum skylight effective aperture \geq 1 percent.</p> <p>[]- Exception 1:C402.4.2: Buildings in climate zones 6 through 8.</p> <p>[]- Exception 2:C402.4.2: Spaces where the proposed general lighting power densities < 0.5 W/ft2.</p> <p>[]- Exception 3:C402.4.2: Areas with obstructions that block direct beam sunlight on \geq 1/2 of the roof over the enclosed area for more than 1,500 daytime hours per year between 8 am and 4 pm.</p> <p>[]- Exception 4:C402.4.2: Spaces where the daylight zone under rooftop monitors is > 50 percent of the enclosed space floor area.</p> <p>[]- Exception 5:C402.4.2: Spaces where the total area net of daylight zones adjacent to vertical fenestration < 2,500 s.f. and where the lighting is controlled.</p> <p>[]- Exception 6:C402.4.2: Requirement does not apply.</p>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
6032 Fenestration	C402.4.3	Envelope	Vertical fenestration Maximum U-factor and SHGC value.	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
6034 Fenestration	C402.4.3	Envelope	Skylight SHGC value.	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
6040 Fenestration	C402.4.5	Envelope	U-factor of opaque swinging and nonswinging doors associated with the building thermal envelope meets requirements.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6046 Post Construction	C402.5.11	Envelope	<p>Operable openings > 40 ft2 will be interlocked with heating and cooling systems to setback setpoint temperatures within 10 minutes of opening.</p> <p>[]- Exception 1:C402.5.11: Separately zoned areas.</p> <p>[]- Exception 2:C402.5.11: Warehouses with overhead doors for occupancy.</p> <p>[]- Exception 3:C402.5.11: Entrance doors located in exterior wall as part of a vestibule.</p>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
6056 HVAC	C403.2.1	Mechanical	<p>HVAC systems and equipment design loads calculated in accordance with ANSI/ASHRAE/ACCA Standard 183 or by an approved equivalent computational procedure</p> <p>[]- Exception 1:C403.2.1: Mechanical systems are designed by a registered engineer</p>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

6096 HVAC	C403.2.12.1	Mechanical	<p>HVAC fan systems at design conditions do not exceed allowable fan system motor nameplate hp or fan system bhp.</p> <p>[]- Exception 1:C403.2.12.1: Hospital and laboratory systems that utilize flow control devices on exhaust and/or return.</p> <p>[]- Exception 2:C403.2.12.1: Individual exhaust fans with motor nameplate horsepower less than or equal 1 hp.</p> <p>[]- Exception 3:C403.2.12.1: Requirement does not apply.</p>	<input checked="" type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>
6055 HVAC	C403.2.12.2	Mechanical	<p>HVAC fan motors not oversized beyond allowable limits.</p> <p>[]- Exception 1:C403.2.12.2: Fans equipped with electronic speed control devices</p> <p>[]- Exception 2:C403.2.12.2: Fans with fan nameplate electrical input power < 0.89 kW</p> <p>[]- Exception 3:C403.2.12.2: Fan system complying with Section C403.2.12.1 motor nameplate hp (Option 1).</p> <p>[]- Exception 4:C403.2.12.2: Fans with motor nameplate horsepower < 1 hp (746 W).</p> <p>[]- Exception 5:C403.2.12.2: Requirement does not apply.</p>	<input checked="" type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>
6141 SYSTEM_SPECIF	C403.2.12.3	Mechanical	<p>Fans have a fan energy index (FEI) >= 1.00. Variable volume fans will have an FEI >= 0.95 at the design point of operation.</p> <p>[]- Exception 1:C403.2.12.3: Single not embedded fans with motor nameplate horsepower of less than 1 hp (0.89 kW).</p> <p>[]- Exception 2:C403.2.12.3: Embedded fans with motor nameplate horsepower exceeding 5 hp (4.1 kW).</p> <p>[]- Exception 3:C403.2.12.3: Multiple fans in series or parallel have a combined motor nameplate horsepower of less or equal 5 hp and are operated functionally as a single fan.</p> <p>[]- Exception 4:C403.2.12.3: Fans integral to equipment listed under Section C403.2.3.</p> <p>[]- Exception 5:C403.2.12.3: Fans included in equipment having certified seal for air or energy performance of the equipment package.</p> <p>[]- Exception 6:C403.2.12.3: Ceiling fans.</p> <p>[]- Exception 7:C403.2.12.3: Fans for gases at temperatures above 425F.</p> <p>[]- Exception 8:C403.2.12.3: Fans for operation in explosive atmospheres.</p> <p>[]- Exception 9:C403.2.12.3: Reversible fans for tunnel ventilation.</p> <p>[]- Exception 10:C403.2.12.3: Fans not covered by AMCA 208.</p> <p>[]- Exception 11:C403.2.12.3: Fans intended to operate only during emergency conditions.</p>	<input checked="" type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>

6057 HVAC	C403.2.2	Mechanical	<p>HVAC systems and equipment capacity does not exceed calculated loads.</p> <p>[]- Exception 1:C403.2.2: Required standby equipment with proper controls per code.</p> <p>[]- Exception 2:C403.2.2: Multiple units of the same type of equipment with sequencing controls.</p> <p>[]- Exception 3:C403.2.2: Living spaces in commercial buildings shall be sized in accordance with Section R403.7.1.1 and its exceptions</p>	<input checked="" type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>
6087 HVAC	C403.2.7	Mechanical	<p>Exhaust air energy recovery on systems meeting Table C403.7.4(1) and C403.7.4(2).</p> <p>[]- Exception 1:C403.2.7: Where energy recovery systems are prohibited by the Florida Building Code, Mechanical</p> <p>[]- Exception 2:C403.2.7: Laboratory fume hood systems</p> <p>[]- Exception 3:C403.2.7: Systems serving spaces that are heated to less than 60°F (15.5°C) and are not cooled</p> <p>[]- Exception 4:C403.2.7: Where more than 60 percent of the outdoor heating energy is provided from site-recovered or site solar energy</p> <p>[]- Exception 5:C403.2.7: Heating energy recovery in Climate Zones 1 and 2</p> <p>[]- Exception 6:C403.2.7: Cooling energy recovery in Climate Zones 3C, 4C, 5B, 5C, 6B, 7 and 8</p> <p>[]- Exception 7:C403.2.7: Systems requiring dehumidification that employ energy recovery in series with the cooling coil</p> <p>[]- Exception 8:C403.2.7: Where the largest source of air exhausted at a single location at the building exterior is less than 75 percent of the design outdoor air flow rate.</p> <p>[]- Exception 9:C403.2.7: Systems expected to operate less than 20 hours per week at the outdoor air percentage covered by Table C403.2.7(1).</p> <p>[]- Exception 10:C403.2.7: Systems exhausting toxic, flammable, paint or corrosive fumes or dust.</p> <p>[]- Exception 11:C403.2.7: Commercial kitchen hoods used for collecting and removing grease vapors and smoke</p>	<input type="checkbox"/> <input checked="" type="checkbox"/> <input type="checkbox"/>
6047 HVAC	C403.3.2	Mechanical	<p>Economizer operation will not increase heating energy use during normal operation.</p> <p>[]- Exception 1:C403.3.2: Economizers on VAV systems.</p>	<input type="checkbox"/> <input checked="" type="checkbox"/> <input type="checkbox"/>

6093 HVAC	C403.3.3, C403.3.3.1, C403.3.3.2, C403.3.3.3, C403.3.3.4, C403.3.3.5	Mechanical	<p>Air economizers provided where required, meet the requirements for design capacity, control signal, ventilation controls, high-limit shut-off, integrated economizer control, and provide a means to relieve excess outside air during operation.</p> <p>[]- Exception 1:C403.3_C403.3.2: Buildings located in Climate Zones 1A and 1B.</p> <p>[]- Exception 2:C403.3_C403.3.2: Individual DX fan cooling units have a capacity is < 54 kBtu/h (15.8 kW) or total chilled water system capacity < minimum specified in Table C403.3(1).</p> <p>[]- Exception 3:C403.3_C403.3.2: Where more than 25 % of the air supplied to spaces that are designed to be humidified above 35°F (1.7°C) dewpoint temperature to satisfy process needs</p> <p>[]- Exception 4:C403.3_C403.3.2: Systems that serve residential spaces where the system capacity is < 270 kBtu/h</p> <p>[]- Exception 5:C403.3_C403.3.2: Systems expected to operate less than 20 hours per week</p> <p>[]- Exception 6:C403.3_C403.3.2: System serves supermarket areas with open refrigerated casework.</p> <p>[]- Exception 7:C403.3_C403.3.2: Where the minimum code required cooling efficiency of the HVAC unit rated with an IPLV, IEER or SEER is increased by at least 17 %.</p> <p>[]- Exception 8:C403.3_C403.3.2: Chilled-water cooling systems that are passive (without a fan) capacity is < the minimum specified in Table C403.3(1).</p> <p>[]- Exception 9:C403.3_C403.3.2: Systems that include a heat recovery system in accordance with Section C403.4.5</p> <p>[]- Exception 10:C403.3_C403.3.2: Economizers on VAV systems cause zone-level heating to increase due to a reduction in supply air temperature.</p>	<input type="checkbox"/> <input checked="" type="checkbox"/> <input type="checkbox"/>
6042 HVAC	C403.3.4, C403.3.4.1, C403.3.4.2, C403.3.1	Mechanical	<p>Water economizers provided where required, meet the requirements for design capacity, maximum pressure drop and integrated economizer control.</p> <p>[]- Exception 1:C403.2.12.5_C403.2.12.5.1_C403.2.12.5.2: Modulating fan control not required for chilled water and evaporative cooling units with fan motors of < 1 hp where the units are not used to provide ventilation air and the indoor fan cycles with the load.</p> <p>[]- Exception 2:C403.2.12.5_C403.2.12.5.1_C403.2.12.5.2: Requirement does not apply.</p>	<input type="checkbox"/> <input checked="" type="checkbox"/> <input type="checkbox"/>
6053 HVAC	C403.4.2.3.1	Mechanical	<p>Hydronic heat pump systems connected to a common water loop meet heat rejection and heat addition requirements.</p> <p>[]- Exception 1:C403.4.2.3.1: A deadband of less than 20°F is allowed where a temperature optimization controller is used.</p>	<input type="checkbox"/> <input checked="" type="checkbox"/> <input type="checkbox"/>

6144 Mandatory Additior	C406.6	Project	Dedicate outdoor air system efficiency energy credit - Building equipped with independent ventilation system designed to provide 100-percent outdoor air to each individual occupied space, as specified by the IMC. The ventilation system is capable of total energy recovery and includes HVAC system controls that manage temperature resets at least 25 percent of delta design supply-air / room-air temp.	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
2. To be checked by Plan Reviewer						
6004 Plan Review	C103.2	Mechanical	Plans, specifications, and/or calculations provide all information with which compliance can be determined for the mechanical and service water heating systems and document where exceptions to the standard are claimed. Load calculations per acceptable engineering standards and handbooks. Hot water system sized per manufacturer's sizing guide.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6011 Plan Review	C103.2	Interior Lighting	Plans, specifications, and/or calculations provide all information with which compliance can be determined for the interior lighting and electrical systems and equipment and document where exceptions to the standard are claimed. The information provided should include lighting controls per sections C405.2 and C405.3.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6023 Plan Review	C103.2	Exterior Lighting	Plans, specifications, and/or calculations provide all information with which compliance can be determined for the exterior lighting and electrical systems and equipment and document where exceptions to the standard are claimed. The information provided should include Exterior lighting power requirements (Mandatory) per section C405.4.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6001 Plan Review	C103.2, C103.2.1	Envelope	Plans and/or specifications provide all information with which compliance can be determined for the building envelope and document where exceptions to the standard are claimed.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6081 HVAC	C402.2.6	Mechanical	Thermally ineffective panel surfaces of sensible heating panels have insulation $\geq R-3.5$. []- Exception 1:C402.2.6: Heated slabs on grade insulated in accordance with Section C402.2.5 []- Exception 2:C402.2.6: Requirement does not apply.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6100 HVAC	C403.2.13	Mechanical	Systems that heat outside the building envelope are radiant heat systems controlled by an occupancy sensing device or timer switch. []- Exception 1:C403.12.1: Requirement does not apply.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6068 HVAC	C403.2.4.1.3	Mechanical	Reset static pressure setpoint for DDC controlled VAV boxes reporting to central controller based on the zones requiring the most pressure. []- Exception 1:C403.4.1.3: Requirement does not apply.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

6107 HVAC	C403.2.4.2	Mechanical	<p>Each zone equipped with setback controls using automatic time clock or programmable control system.</p> <p>[]- Exception 1:C403.2.4.2: Zones operated continuously.</p> <p>[]- Exception 2:C403.2.4.2: Zones have a full HVAC load demand not exceeding 6,800 Btu/h (2 kW) and having a readily accessible manual shutoff switch.</p> <p>[]- Exception 3:C403.2.4.2: Requirement does not apply.</p>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6123 HVAC	C403.2.4.4	Mechanical	<p>Zone isolation devices and controls installed where applicable.</p> <p>[]- Exception 1:C403.2.4.4: Exhaust and outdoor air connections having fan systems 5000 cfm or smaller.</p> <p>[]- Exception 2:C403.2.4.4: Exhaust airflow less than 10% of design.</p> <p>[]- Exception 3:C403.2.4.4: Zones and systems intended to operate continuously or are inoperative when all other zones are inoperative.</p> <p>[]- Exception 4:C403.2.4.4: Requirement does not apply.</p>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6124 HVAC	C403.2.4.7	Mechanical	<p>Fault detection and diagnostics installed with air-cooled unitary DX units or VRF units having economizers.</p> <p>[]- Exception 1:C403.2.4.7: Requirement does not apply.</p>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6125 HVAC	C403.2.5	Mechanical	<p>Hot water boilers supplying heat via one- or two-pipe systems include outdoor setback control.</p> <p>[]- Exception 1:C403.2.5: Requirement does not apply.</p>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6089 HVAC	C403.2.6	Mechanical	<p>Natural or mechanical ventilation is provided in accordance with International Mechanical Code Chapter 4. Mechanical ventilation has capability to reduce outdoor air supply to minimum per IMC Chapter 4.</p> <p>[]- Exception 1:C403.2.2: Requirement does not apply.</p>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6090 HVAC	C403.2.6.1	Mechanical	<p>Demand control ventilation provided for spaces >500 ft2 and >=25 people/1000 ft2 occupant density and served by systems with air side economizer, auto modulating outside air damper control, or design airflow >3,000 cfm.</p> <p>[]- Exception 1:C403.2.6.1: Systems with energy recovery complying with Section C403.2.7.</p> <p>[]- Exception 2:C403.2.6.1: Multiple-zone systems without DDC.</p> <p>[]- Exception 3:C403.2.6.1: Multiple-zone systems with design outdoor air of less than 1200 cfm.</p> <p>[]- Exception 4:C403.2.6.1: Spaces where the supply airflow rate minus any makeup or outgoing transfer air requirement is < 1,200 cfm</p> <p>[]- Exception 5:C403.2.6.1: Ventilation provided for process loads only</p> <p>[]- Exception 6:C403.2.6.1: Requirement does not apply.</p>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

6098 HVAC	C403.4.2	Mechanical	The heating of fluids in hydronic systems that have been previously mechanically cooled, and the cooling of fluids that have been previously mechanically heated are limited in accordance with Sections C403.4.2.1-C403.4.2.3. Single boiler systems >500 kBtu/h have multistaged or modulating burner. []- Exception 1:C403.4.2: Requirement does not apply.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6142 HVAC	C403.4.2.3.2	Mechanical	Closed-circuit cooling tower within heat pump loop have either automatic bypass valve or lower leakage positive closure dampers. Open-circuit tower within heat pump loop have automatic valve to bypass all heat pump water flow around the tower. Open- or closed-circuit cooling towers used in conjunction with a separate heat exchanger have heat loss by shutting down the circulation pump on the cooling tower loop. Open- or closed circuit cooling towers have a separate heat exchanger to isolate the cooling tower from the heat pump loop, and heat loss is controlled by shutting down the circulation pump on the cooling tower loop. []- Exception 1:C403.4.2.3.2: Heat pump system must reject heat throughout the year. []- Exception 2:C403.4.2.3.2: Requirement does not apply.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6116 HVAC	C403.4.2.5	Mechanical	System turndown requirement met through multiple single-input boilers, one or more modulating boilers, or a combination of single-input and modulating boilers. Boiler shall comply with the turndown ratio specified in Table C403.4.2.5.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6071 HVAC	C403.4.2.6	Mechanical	Chilled water plants with multiple chillers have capability to reduce flow automatically through the chiller plant when a chiller is shut down. Boiler plants with multiple boilers have the capability to reduce flow automatically through the boiler plant when a boiler is shut down.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6099 HVAC	C403.4.3.1	Mechanical	Fan systems with total system motor capacity >=5 hp associated with heat rejection equipment configured to automatically modulate the fan speed to control the leaving fluid temperature or condensing temp/pressure of heat rejection device. []- Exception 1:C403.4.3.1: Fans serve multiple refrigerant or fluid cooling circuits. []- Exception 2:C403.4.3.1: Condenser fans serve flooded condensers. []- Exception 3:C403.4.3.1: Requirement does not apply.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6120 HVAC	C403.4.3.4	Mechanical	Open-circuit cooling towers having water cooled chiller systems and multiple or variable speed condenser pumps, are designed so that tower cells can run in parallel with larger of flow criteria. []- Exception 1:C403.4.3.4: Requirement does not apply.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

6103 HVAC	C403.6.1	Mechanical	<p>Hydronic and multizone HVAC system controls are VAV fans driven by mechanical or electrical variable speed drive per Table C403.4.1.1.</p> <p>[]- Exception 1:C403.4.4: Zones or supply air systems where $\geq 75\%$ of the energy for reheating or for providing warm air in mixing systems is provided from a site-recovered or site-solar energy source</p> <p>[]- Exception 2:C403.4.4: Zones where special humidity levels are required to satisfy process needs</p> <p>[]- Exception 3:C403.4.4: Zones with a peak supply air of ≤ 300 cfm (142 L/s) and where the flow rate is $< 10\%$ of the total fan system supply airflow rate.</p> <p>[]- Exception 4:C403.4.4: Zones where the volume of air to be reheated, recooled or mixed is \leq the minimum ventilation requirements of Chapter 4 of the Florida Building Code, Mechanical</p> <p>[]- Exception 5:C403.4.4: Zones or supply air systems with thermostatic and humidistatic controls capable of preventing reheating, recooling, mixing or simultaneous supply of air that has been previously cooled</p> <p>[]- Exception 6:C403.4.4: Requirement does not apply.</p>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6122 HVAC	C404.2.1	Mechanical	<p>Gas-fired water-heating equipment installed in new buildings: where a singular piece of water-heating equipment $\geq 1,000$ kBtu/h serves the entire building, thermal efficiency ≤ 92 Et. Where multiple pieces of water-heating equipment serve the building with combined rating $\leq 1,000$ kBtu/h, the combined input-capacity-weighted-average thermal efficiency ≤ 90 Et. Exclude input rating of equipment in individual dwelling units and equipment ≤ 100 kBtu/h</p> <p>[]- Exception 1:C404.2.1: 25 percent or more of the annual service water heating requirement is provided by on-site renewable energy or site-recovered energy.</p> <p>[]- Exception 2:C404.2.1: Water heaters installed in individual dwelling units shall not be required to be included in the total input rating of service waterheating equipment</p> <p>[]- Exception 3:C404.2.1: Water heaters with an input rating of $\leq 100,000$ Btu/h (29.3 kW) not required to be included in the total input rating of service water-heating equipment</p> <p>[]- Exception 4:C404.2.1: Requirement does not apply.</p>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6114 HVAC	C404.4	Mechanical	<p>All piping insulated in accordance with section details and Table C403.12.3.</p> <p>[]- Exception 1:C404.4: Requirement does not apply.</p>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6019 HVAC	C404.5, C404.5.1, C404.5.2	Mechanical	<p>Heated water supply piping conforms to pipe length and volume requirements. Refer to section details.</p> <p>[]- Exception 1:C404.5_C404.5.1_C404.5.2: Requirement does not apply.</p>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

6022 HVAC	C404.6.3	Mechanical	Pumps that circulate water between a heater and storage tank have controls that limit operation from startup to ≤ 5 minutes after end of heating cycle. []- Exception 1:C404.6.3: Requirement does not apply.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6026 HVAC	C404.7	Mechanical	Demand recirculation water systems have controls that start the pump upon receiving a signal from the action of a user of a fixture or appliance and limits the temperature of the water entering the cold-water piping to 104°F. []- Exception 1:C404.7: Requirement does not apply.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6048 Plan Review	C405.5.2	Project	Group R-2 dwelling units have separate electrical meters. []- Exception 1:C405.5.2: Requirement does not apply.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6030 Plan Review	C406	Project	Plans, specifications, and/or calculations provide all information with which compliance can be determined for the additional energy efficiency package options.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6084 HVAC	C408.2.2.2	Mechanical	HVAC hydronic heating and cooling coils have means to balance and have pressure test connections. []- Exception 1:C408.2.2.2: Pumps with pump motors of 5 hp (3.7 kW) or less. []- Exception 2:C408.2.2.2: Where throttling results in no greater than 5 percent of the nameplate horsepower draw above that required if the impeller were trimmed.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3. To be checked by Inspector						
6016 Insulation	C104	Envelope	Installed above-grade wall insulation type and R-value consistent with insulation specifications reported in plans.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6006 Insulation	C104, C303.1.1	Envelope	Installed roof insulation type and R-value consistent with insulation specifications reported in plans. For some ceiling systems, verification may need to occur during Framing Inspection.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6008 Insulation	C104.2.1	Envelope	Installed slab-on-grade insulation type and R-value consistent with insulation specifications reported in plans.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6007 Insulation	C303.1, C303.1.1	Envelope	Roof insulation installed per manufacturer's instructions and is labeled with R-value or insulation certificate providing R-value and other relevant data. Blown or poured loose-fill insulation is installed only where the roof slope is > 3 in 12.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6035 Fenestration	C303.1.3	Envelope	Fenestration products rated in accordance with NFRC certified and as to performance labels or certificates provided. []- Exception 1:C303.1.3: Default values are used.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6020 Insulation	C303.2	Envelope	Above-grade wall insulation installed per manufacturer's instructions.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6005 Insulation	C303.2, C303.2.1	Envelope	Below-grade wall insulation installed per manufacturer's instructions.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

6013 Insulation	C303.2, C303.2.1	Envelope	Slab edge insulation installed per manufacturer's instructions and the Florida Building Code, Building.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6027 Insulation	C303.2, C402.2.4	Envelope	<p>Floor insulation installed per manufacturer's instructions. Cavity or structural slab insulation installed in permanent contact with underside of decking or structural slabs.</p> <p>[]- Exception 1:C303.2_C402.2.4: All perimeter framing fully insulated at metal or wood framed prescriptive levels.</p> <p>[]- Exception 2:C303.2_C402.2.4: Concrete floor slab insulation turns up and contacts underside of floor under wall assembly.</p> <p>[]- Exception 3:C303.2_C402.2.4: Requirement does not apply.</p>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6015 Insulation	C303.2.1	Envelope	Exterior insulation protected against damage, sunlight, moisture, wind, landscaping and equipment maintenance activities.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6002 Insulation	C402.1.3	Envelope	Installed below-grade wall insulation type and R-value consistent with insulation specifications reported in plans.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6061 Insulation	C402.1.3	Envelope	<p>Non-swinging opaque doors have R-4.75 insulation.</p> <p>[]- Exception 1:C402.1.3: Requirement does not apply.</p>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6012 Insulation	C402.2.2	Envelope	<p>Skylight curbs are insulated to the level of roofs with insulation above deck or R-5, whichever is less.</p> <p>[]- Exception 1:C402.2.1.5: Unit skylight curbs included as a component of a skylight listed and labeled per NFRC 100.</p> <p>[]- Exception 2:C402.2.1.5: Requirement does not apply.</p>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6064 Insulation	C402.2.2	Envelope	<p>Roof assembly meets minimal thermal resistance installed between roof framing or in a continuous fashion on the roof assembly as stipulated in Table C402.1.3. Requirements for above deck insulation, minimum thickness, suspended ceilings, staggered joints and skylight curbs will be met.</p> <p>[]- Exception 1:C402.2.1: Requirement does not apply.</p>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6024 Insulation	C402.2.3	Envelope	Installed floor insulation type and R-value consistent with insulation specifications reported in plans.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6021 Insulation	C402.2.5, C402.2.5.1	Envelope	<p>Slab edge insulation depth/length. Slab insulation extending away from building is covered by pavement or ≥ 10 inches of soil.</p> <p>[]- Exception 1:C402.2.5_C402.2.5.1: Requirement does not apply.</p>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6051 Insulation	C402.2.6	Envelope	<p>Radiant panels and associated components, designed for heat transfer from the panel surfaces to the occupants or indoor space are insulated with a minimum of R-3.5.</p> <p>[]- Exception 1:C402.2.6: Heated slab-on-grade.</p> <p>[]- Exception 2:C402.2.6: Requirement does not apply.</p>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

6014 Insulation	C402.3	Envelope	<p>High-albedo roofs satisfy one of the following: 3-year-aged solar reflectance ≥ 0.55 (0.63 for Climate Zone 1A) and thermal emittance ≥ 0.75 or 3-year-aged solar reflectance index ≥ 64.0 (75 for Climate Zone 1A). []- Exception 1:C402.3: Roof Over Conditioned Space With No Cooling.</p> <p>[]- Exception 2:C402.3: Ballasted Roof.</p> <p>[]- Exception 3:C402.3: Vegetated Roof (75% coverage).</p> <p>[]- Exception 4:C402.3: Shaded or Covered Roof (75% coverage).</p> <p>[]- Exception 5:C402.3: Asphaltic Membrane Roof.</p> <p>[]- Exception 6:C402.3: Steep Sloped Roof.</p>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6028 Fenestration	C402.4.3	Envelope	Installed skylight U-factor and SHGC consistent with label specifications and as reported in plans.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6025 Fenestration	C402.4.3, C402.4.3.4	Envelope	Installed vertical fenestration U-factor and SHGC consistent with label specifications and as reported in plans.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6043 Air Leakage	C402.5	Envelope	Building envelope contains a continuous air barrier that has been tested and deemed to limit air leakage ≤ 0.40 cfm/ft ² of the building thermal envelope area at a pressure differential of 0.3 inch water gauge (75 Pa).	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6044 Air Leakage	C402.5.1	Envelope	<p>The building envelope contains a continuous air barrier that is sealed in an approved manner and either constructed or tested in an approved manner. Air barrier penetrations are sealed in an approved manner.</p> <p>[]- Exception 1:C402.5.1: Requirement does not apply.</p>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6003 Air Leakage	C402.5.1.1	Envelope	All sources of air leakage in the building thermal envelope are sealed, caulked, gasketed, weather stripped or wrapped with moisture vapor-permeable wrapping material to minimize air leakage.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6062 Air Leakage	C402.5.1.2.1	Envelope	<p>The building envelope contains a continuous air barrier that is sealed in an approved manner and material permeability ≤ 0.004 dfm/ft². Air barrier penetrations are sealed in an approved manner.</p> <p>[]- Exception 1:C402.5.1.2.1: Requirement does not apply.</p>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6065 Air Leakage	C402.5.1.2.2	Envelope	<p>The building envelope contains a continuous air barrier that is sealed in an approved manner and average assembly air leakage ≤ 0.04 cfm/ft². Air barrier penetrations are sealed in an approved manner.</p> <p>[]- Exception 1:C402.5.1.2.2: Requirement does not apply.</p>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

6052 Air Leakage	C402.5.4	Envelope	<p>Factory-built fenestration and doors are labeled as meeting air leakage requirements.</p> <p>[]- Exception 1:C402.5.4: Field fabricated fenestration assemblies.</p> <p>[]- Exception 2:C402.5.4: Fenestration in buildings that comply with air leakage requirements with a whole building air leakage test.</p> <p>[]- Exception 3:C402.5.4: Doors that comply with special International Building Code requirements.</p>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6009 Air Leakage	C402.5.5, C402.5.11, 403.6	Envelope	<p>Stair and elevator shaft vents have motorized dampers that automatically close. Reference section C403.6 for operational details.</p>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6049 Air Leakage	C402.5.6	Envelope	<p>Weatherseals installed on all loading dock cargo door openings and provide direct contact along the top and sides of vehicles parked in the doorway.</p> <p>[]- Exception 1:C402.5.6: Requirement does not apply.</p>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6050 Air Leakage	C402.5.7	Envelope	<p>Vestibules are installed on all building entrances . Doors have self-closing devices.</p> <p>[]- Exception 1:C402.5.7: Building entrances with revolving doors.</p> <p>[]- Exception 2:C402.5.7: Doors not intended to be used as a building entrance.</p> <p>[]- Exception 3:C402.5.7: Doors opening directly from a sleeping unit or dwelling unit.</p> <p>[]- Exception 4:C402.5.7: Doors that open directly from a space &lt;=3000 ft2.</p> <p>[]- Exception 5:C402.5.7: Doors with air curtain.</p> <p>[]- Exception 6:C402.5.7: Existing door is being replaced and existing vestibules not removed.</p> <p>[]- Exception 7:C402.5.7: Requirement does not apply.</p>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6045 Air Leakage	C402.5.8	Envelope	<p>Recessed luminaires in thermal envelope to limit infiltration and be IC rated and labeled. Seal between interior finish and luminaire housing.</p> <p>[]- Exception 1:C402.5.10: Requirement does not apply.</p>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6086 HVAC	C403.2	Mechanical	HVAC equipment efficiency verified.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

6092 HVAC	C403.2.10	Mechanical	<p>HVAC piping insulation insulated in accordance with Table C403.2.10. Insulation exposed to weather is protected from damage and is provided with shielding from solar radiation.</p> <p>[]- Exception 1:C403.2.10: Factory-installed piping within HVAC equipment</p> <p>[]- Exception 2:C403.2.10: Factory-installed piping within room fan-coils and unit ventilators tested under AHRI 440.</p> <p>[]- Exception 3:C403.2.10: Piping that conveys fluids that have a design operating temperature range between 60 and 105°F.</p> <p>[]- Exception 4:C403.2.10: Fluid not heated or cooled.</p> <p>[]- Exception 5:C403.2.10: Strainers and valves associated with 1 inch or smaller piping.</p> <p>[]- Exception 6:C403.2.10: Underground piping with fluids no hotter than 60°F.</p> <p>[]- Exception 7:C403.2.10: Piping design for radiant heating systems</p> <p>[]- Exception 8:C403.2.10: Requirement does not apply.</p>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6171 HVAC	C403.2.12.4	Mechanical	<p>Motors for fans that are not less than 1/12 hp and less than 1 hp are electronically commutated motors or have a minimum motor efficiency of 70 percent. These motors have the means to adjust motor speed for either balancing or remote control.</p> <p>[]- Exception 1:C403.2.12.4: Motors in the airstream within fan coils and terminal units only provide heating to the space served.</p> <p>[]- Exception 2:C403.2.12.4: Motors in space-conditioning equipment that comply with Section C403.2.3 or C403.2.12.</p> <p>[]- Exception 3:C403.2.12.4: Motors that comply with Section C405.7.</p> <p>[]- Exception 4:C403.2.12.4: Requirement does not apply.</p>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6173 HVAC	C403.2.12.5.1	Mechanical	<p>Each DX cooling system \geq 65 kBtu and chiller water/evaporative cooling system with fans \geq 1/4 hp are designed to vary the indoor fan airflow as a function of load and comply with detailed requirements of this section.</p> <p>[]- Exception 1:C403.2.12.5.1: Modulating fan control is not required for chilled water and evaporative cooling units with fan motors of less than 1 hp where the units are not used to provide ventilation air and the indoor fan cycles with the load.</p> <p>[]- Exception 2:C403.2.12.5.1: Where the volume of outdoor air required to comply with the ventilation requirements of the IMC at low speed exceeds the air that would be delivered per Section C403.2.12.5</p> <p>[]- Exception 3:C403.2.12.5.1: Requirement does not apply.</p>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

6097 HVAC	C403.2.12.5.2	Mechanical	VAV fans have static pressure sensors located so controller setpoint <=1.2 w.c.. []- Exception 1:C403.2.12.5.2: Requirement does not apply.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6168 HVAC	C403.2.12.5.2	Mechanical	Static pressure sensors used to control VAV fans located such that the controller setpoint is <= 1.2 inches w.c.. Where this results in one or more sensors being located downstream of major duct splits, not less than one sensor located on each major branch. []- Exception 1:C403.2.12.5.2: Requirement does not apply.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6167 HVAC	C403.2.12.5.3	Mechanical	Systems with DDC of individual zones reporting to the central control panel configured to reset the static pressure setpoint based on zone requiring the most pressure. The DDC is capable of monitoring zone damper positions or have an alternative method of indicating the need for static pressure. See section for details. []- Exception 1:C403.2.12.5.3: Requirement does not apply.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6178 HVAC	C403.2.12.6	Mechanical	Large diameter fans where installed shall be tested and labeled in accordance with AMCA 230. []- Exception 1:C403.2.12.6: Requirement does not apply.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6155 HVAC	C403.2.14, C403.2.14.1, C403.2.14.2	Mechanical	Refrigeration equipment performance shall be determined in accordance with sections C403.2.14.1 and C403.2.14.2 for commercial refrigerators, freezers, refrigerator-freezers, walk-in coolers, walk-in freezers and refrigeration equipment. []- Exception 1:C403.5: Systems have working fluid in the refrigeration cycle that goes through both subcritical and supercritical states (transcritical). []- Exception 2:C403.5: Systems use ammonia refrigerant. []- Exception 3:C403.5: Requirement does not apply.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6102 HVAC	C403.2.3	Mechanical	PTAC and PTHP with sleeves 16 in. by 42 in. labeled for replacement only as per Footnote b to Tables C403.2.3(1) and C403.2.3(2). []- Exception 1:C403.3: Requirement does not apply.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6058 HVAC	C403.2.4.1	Mechanical	Heating and cooling to each zone is controlled by a thermostat control. Minimum one humidity control device per installed humidification/dehumidification system. []- Exception 1:C403.2.4.1: TRUE	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6059 HVAC	C403.2.4.1.1	Mechanical	Heat pump controls prevent supplemental electric resistance heat from coming on when not needed. []- Exception 1:C403.2.4.1.1: Requirement does not apply.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6060 HVAC	C403.2.4.1.2	Mechanical	Thermostatic controls have a 5 °F deadband. []- Exception 1:C403.2.4.1.2: Manual changeover thermostats. []- Exception 2:C403.2.4.1.2: Precision indoor temperature control required.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

6085 HVAC	C403.2.4.1.3	Mechanical	Temperature controls have setpoint overlap restrictions. []- Exception 1:C403.2.4.1.3: Requirement does not apply.	<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>
6108 HVAC	C403.2.4.2.1, C403.2.4.2.2	Mechanical	Automatic Controls: Setback to 55°F (heat) and 85°F (cool); 7-day clock, 2-hour occupant override, 10-hour backup []- Exception 1:C403.2.4.2.1_C403.2.4.2.2: Requirement does not apply.	<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>
6110 HVAC	C403.2.4.2.3	Mechanical	Systems include optimum start controls. []- Exception 1:C403.2.4.2.3: Requirement does not apply.	<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>
6088 Air Leakage	C403.2.4.3	Mechanical	Outdoor air and exhaust systems have motorized dampers that automatically shut when not in use and meet maximum leakage rates. Check gravity dampers where allowed. Reference section language for operational details. []- Exception 1:C403.2.4.3: Gravity dampers acceptable in buildings less than 3 stories. []- Exception 2:C403.2.4.3: Gravity dampers acceptable for exhaust and relief dampers in climate zones 0, 1, 2, or 3. []- Exception 3:C403.2.4.3: Gravity dampers acceptable in systems with outside or exhaust air flow rates less than or equal to 300 cfm. []- Exception 4:C403.2.4.3: Dampers no larger than 24 inches in any dimension are to have a leakage rate of 40 cfm/ft ² at 1.0 inch water gauge when tested with AMCA 500D. []- Exception 5:C403.2.4.3: Requirement does not apply.	<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>
6029 HVAC	C403.2.4.5	Mechanical	Snow/ice melting system and freeze protection systems have sensors and controls configured to limit service for pavement temperature above 50°F and outdoor temperature above 40°F. []- Exception 1:C403.12.2_C403.12.3: Requirement does not apply.	<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>
6170 HVAC	C403.2.4.8	Mechanical	HVAC systems serving guestrooms in Group R-1 buildings with < 50 guestrooms: Each guestroom is provided with controls that automatically manage temperature setpoint and ventilation (see sections C403.2.4.8.1 and C403.2.4.8.2). []- Exception 1:C403.2.4.8: Requirement does not apply.	<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>
6128 HVAC	C403.2.6.2	Mechanical	Enclosed parking garage ventilation has automatic contaminant detection and capacity to stage or modulate fans to 50% or less of design capacity. []- Exception 1:C403.2.6.2: Garages with no mechanical cooling or heating that have exhaust capacity < 8,000 cfm. []- Exception 2:C403.2.6.2: Garages with no mechanical cooling or heating that have a ratio of garage area ventilation to ventilation system motor nameplate hp exceed 1125 cfm/hp. []- Exception 3:C403.2.6.2: Requirement does not apply.	<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>

6169 HVAC	C403.2.7	Mechanical	Units that provide ventilation air to multiple zones and operate in combination with zone heating and cooling systems do not use heating or heat recovery to warm supply air to a temperature greater than 60°F when representative building loads or outdoor air temperatures indicate that the majority of zones require cooling. []- Exception 1:C403.7.3: Requirement does not apply.	<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>
6129 HVAC	C403.2.8	Mechanical	Kitchen exhaust systems comply with replacement air and conditioned supply air limitations, and satisfy hood rating requirements and maximum exhaust rate criteria. []- Exception 1:C403.2.8: Requirement does not apply.	<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>
6091 HVAC	C403.2.9	Mechanical	HVAC ducts and plenums insulated in accordance with C403.2.9.1 and constructed in accordance with C403.2.9.2, Sealed in accordance with C403.2.9.3. verification may need to occur during Foundation Inspection. []- Exception 1:C403.2.9_C403.2.9.1: Factory-installed as part of HVAC equipment. []- Exception 2:C403.2.9_C403.2.9.1: Where the design temperature difference between the inside and outside of the duct or plenum is less than 15°F. []- Exception 3:C403.2.9_C403.2.9.1: Runouts less than 10 feet (3048 mm) in length to air terminals or air outlets, the rated R-value of insulation need not exceed R-5. []- Exception 4:C403.2.9_C403.2.9.1: Backs of air outlets and outlet plenums exposed to unconditioned spaces need not exceed R-2. []- Exception 5:C403.2.9_C403.2.9.1: Return air ducts meeting all the requirements for building cavities that will be used as return air plenums []- Exception 6:C403.2.9_C403.2.9.1: Requirement does not apply.	<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>
6174 SYSTEM_SPECIF	C403.3.2	Mechanical	Equipment minimum efficiency:	<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>
6175 SYSTEM_SPECIF	C403.3.2	Mechanical	Equipment minimum efficiency:	<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>
6157 HVAC	C403.3.3.3	Mechanical	Air economizers automatically reduce outdoor air intake to the design minimum outdoor air quantity when outdoor air intake will not reduce cooling energy usage. See Table C403.3.3.3 for applicable device types and climate zones. []- Exception 1:C403.3.3.3: Requirement does not apply.	<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>
6158 HVAC	C403.3.3.4	Mechanical	System capable of relieving excess outdoor air during air economizer operation to prevent over pressurizing the building. The relief air outlet located to avoid recirculation into the building. []- Exception 1:C403.3.3.4: Requirement does not apply.	<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>

6159 HVAC	C403.3.3.5	Mechanical	Return, exhaust/relief and outdoor air dampers used in economizers have motorized dampers that automatically shut when not in use and meet maximum leakage rates. Reference section C403.2.4.3 for details. []- Exception 1:C403.3.3.5: Requirement does not apply.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6094 HVAC	C403.4.1.4	Mechanical	Heating for vestibules and air curtains with integral heating include automatic controls that shut off the heating system when outdoor air temperatures < 45F. Vestibule heating and cooling systems controlled by a thermostat in the vestibule with heating setpoint <= 60F and cooling setpoint <= 80F. []- Exception 1:C402.5.7: Buildings in Climate Zones 1 and 2. []- Exception 2:C402.5.7: Requirement does not apply.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6082 HVAC	C403.4.2.1	Mechanical	Three-pipe hydronic systems using a common return for hot and chilled water are not used.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6095 HVAC	C403.4.2.2	Mechanical	Two-pipe hydronic systems using a common distribution system have controls to allow a deadband >=15 °F, allow operation in one mode for at least 4 hrs before changeover, and have reset controls to limit heating and cooling supply temperature to <=30 °F.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6072 HVAC	C403.4.2.3.3	Mechanical	Two-position automatic valve interlocked to shut off water flow when hydronic heat pump with pumping system > 10 hp is off.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6172 HVAC	C403.4.3.2	Mechanical	Multiple-cell heat rejection equipment with variable speed fan drives are controlled to operate the maximum number of fans allowed and so that all fans operate at the same fan speed required for the instantaneous cooling duty. The minimum fan speed will be the minimum allowable speed of the fan drive system in accordance with the manufacturer's recommendations. []- Exception 1:C403.4.3.2: Requirement does not apply.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6118 SYSTEM_SPECIFI	C403.4.3.3	Mechanical	Centrifugal fan open-circuit cooling towers having combined rated capacity >= 1100 gpm meets minimum efficiency requirement: >=40.2 gpm/hp. []- Exception 1:C403.4.3.3: Centrifugal open-circuit cooling towers with external sound attenuation or that have ducted inlet or discharge. []- Exception 2:C403.4.3.3: Requirement does not apply.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6160 HVAC	C403.4.4	Mechanical	Supply air systems serving multiple zones have VAV systems with controls configured to reduce the volume of air that is reheated, recooled or mixed in each zone. See section for details. []- Exception 1:C403.6.1: Zones or systems with at least 75% of energy used for heating or warming air Systems that prevent reconditioning, mixing or simultaneous supply of air that has previously been mechanically cooled (including via economizers) or heated. []- Exception 2:C403.6.1: Requirement does not apply.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

6161 HVAC	C403.4.4.1	Mechanical	Single-duct VAV systems use terminal devices configured to reduce the supply of primary supply air before reheating or recooling takes place. []- Exception 1:C403.4.4.1: Requirement does not apply.	<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>
6162 HVAC	C403.4.4.2	Mechanical	Systems that have 1 warm air duct and 1 cool air duct use terminal devices configured to reduce the flow from one duct to a minimum before mixing of air from the other duct takes place. []- Exception 1:C403.4.4.1: Requirement does not apply.	<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>
6163 HVAC	C403.4.4.3	Mechanical	Individual dual-duct or mixing heating and cooling systems with a single fan and with total capacities > 90,000 Btu/h not equipped with air economizers. []- Exception 1:C403.4.4.1: Requirement does not apply.	<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>
6164 HVAC	C403.4.4.5	Mechanical	Multiple zone HVAC systems have supply air temperature reset controls based on building loads or outside temperatures. []- Exception 1:C403.4.4.5: Systems that prevent re-heating, re-cooling, or mixing of heated and cooled supply air. []- Exception 2:C403.4.4.5: Systems in which at least 75% of the energy for reheating is from site recovered or site solar energy resources. []- Exception 3:C403.4.4.5: Zones in climate zones 1A and 3A with less than 300 cfm design outside air. []- Exception 4:C403.4.4.5: Zones in climate zone 2A with with less than 10,000 cfm of design outside air. []- Exception 5:C403.4.4.5: Zones in climate zones 1A, 2A, and 3A with >= 80% outside air and employing exhaust air energy recovery. []- Exception 6:C403.4.4.5: Requirement does not apply.	<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>
6165 HVAC	C403.4.4.6	Mechanical	Multiple zone VAV systems with DDC of individual zone boxes have static pressure setpoint reset controls. []- Exception 1:C403.4.4.6: VAV systems that recirculate air from other zones without directly mixing it with outdoor air or dual-duct dual-fan VAV systems, or VAV systems with fan-powered terminal units. []- Exception 2:C403.4.4.6: Systems where the design exhaust airflow is more than 70% of design outdoor air intake flow. []- Exception 3:C403.4.4.6: Requirement does not apply.	<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>

6166 HVAC	C403.4.4.7	Mechanical	Parallel-flow fan-powered VAV air terminals have automatic controls configured to 1) turn off the terminal fan except when space heating is required or where required for ventilation, 2) turn on the terminal fan as the first stage of heating before the heating coil is activated, and 3) during heating for warmup or setback temperature control, either operate the terminal fan and heating coil without primary air or, reverse the terminal damper logic and provide heating from the central air handler by primary air. []- Exception 1:C403.4.4.7: Requirement does not apply.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6076 HVAC	C403.4.5	Mechanical	Condenser heat recovery system that can heat water to 85 °F or provide 60% of peak heat rejection is installed for preheating of service hot water. []- Exception 1:C403.4.5: Facility operates < 24/7. []- Exception 2:C403.4.5: Total installed heat capacity of water cooled systems <= 6 MMBtu/h of heat rejection. []- Exception 3:C403.4.5: Design SWH load <= 1 MMBtu/h. []- Exception 4:C403.4.5: Facilities using condenser heat recovery for space heating with heat recovery exceeding 30% of the peak water-cooled condenser load. []- Exception 5:C403.4.5: Facilities providing 60% of their service water heating from site-solar, site-recovered, or other energy sources.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6080 HVAC	C403.4.6	Mechanical	Hot gas bypass limited to: <=240 kBtu/h – 50%; <240 kBtu/h – 25%	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6101 HVAC	C404.2	Mechanical	Service water heating equipment meets efficiency requirements.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6113 HVAC	C404.3	Mechanical	Heat traps installed on supply and discharge piping of non-circulating systems. []- Exception 1:C404.3: Tank inlets/outlets associated with solar water heating systems. []- Exception 2:C404.3: Requirement does not apply.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6115 HVAC	C404.6.1	Mechanical	Controls are installed that limit the operation of a recirculation pump installed to maintain temperature of a storage tank. System return pipe is a dedicated return pipe or a cold water supply pipe. []- Exception 1:C404.6.1: Requirement does not apply.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6010 HVAC	C404.6.1, C404.6.2	Mechanical	Automatic time switches installed to automatically switch off the recirculating hot-water system or heat trace.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6126 HVAC	C404.9.1	Mechanical	Pool heaters are equipped with on/off switch and no continuously burning pilot light.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

6127 HVAC	C404.9.2	Mechanical	<p>Time switches are installed on all pool heaters and pumps.</p> <p>[]- Exception 1:C404.9.2: Where 24-hr pump operation required for public health.</p> <p>[]- Exception 2:C404.9.2: Solar and waste heat recovery pool heating pumps.</p> <p>[]- Exception 3:C404.9.2: Requirement does not apply.</p>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6130 HVAC	C404.9.3	Mechanical	<p>Vapor retardant pool covers are provided for heated pools and permanently installed spas.</p> <p>[]- Exception 1:C404.9.3: Pools deriving > 75% of the energy for heating (of not fewer than 3 months) from heat pump or site-recovered energy.</p> <p>[]- Exception 2:C404.9.3: Requirement does not apply.</p>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6054 Controls	C405.2.1, C405.2.1.1	Interior Lighting	<p>Occupancy sensors installed in classrooms/lecture/training rooms, conference/meeting/multipurpose rooms, copy/print rooms, lounges/breakrooms, enclosed offices, open plan office areas, restrooms, storage rooms, locker rooms, corridors, warehouse storage areas, and other spaces <= 300 sqft that are enclosed by floor-to-ceiling height partitions. Reference section language C405.2.1.2 for control function in warehouses and section C405.2.1.3 for open plan office spaces.</p> <p>[]- Exception 1:C405.2.1_C405.2.1.1: Automatic-on controls are allowed in corridors, stairways, restrooms, primary building entrance areas and lobbies, and areas where manual-on controls could impact safety or security.</p> <p>[]- Exception 2:C405.2.1_C405.2.1.1: Areas such as security or emergency areas that need continuous lighting.</p> <p>[]- Exception 3:C405.2.1_C405.2.1.1: Emergency egress lighting.</p> <p>[]- Exception 4:C405.2.1_C405.2.1.1: Lighting that is related to means of egress in stairways, ramps, corridors.</p> <p>[]- Exception 5:C405.2.1_C405.2.1.1: Requirement does not apply.</p>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6063 Controls	C405.2.1.2	Interior Lighting	<p>Occupancy sensors control function in warehouses: In warehouses, the lighting in aiseways and open areas is controlled with occupant sensors that automatically reduce lighting power by 50% or more within 20 minutes of when the areas are unoccupied. The occupant sensors control lighting in each aisleway independently and do not control lighting beyond the aisleway being controlled by the sensor. Lights not turned off by occupant sensors is done so by time-switch.</p> <p>[]- Exception 1:C402.5.1.2: Requirement does not apply.</p>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

6066 Controls	C405.2.1.3	Interior Lighting	<p>Occupant sensor control function in open plan office areas: Occupant sensor controls in open office spaces ≥ 300 sq.ft. have controls 1) configured so that general lighting can be controlled separately in control zones with floor areas ≤ 600 sq.ft. within the space, 2) general lighting in each zone permitted to turn on upon occupancy in control zone, 3) automatically turn off general lighting in all control zones within 20 minutes after all occupants have left the space, 4) are configured so that general lighting power in each control zone is reduced by $\leq 80\%$ of the full zone general lighting power within 20 minutes of all occupants leaving that control zone.</p> <p>[]- Exception 1:C405.2.1.3: Requirement does not apply.</p>	<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>
6067 Controls	C405.2.2, C405.2.2.1	Interior Lighting	<p>Each area not served by occupancy sensors (per C405.2.1.1) have time-switch controls and functions detailed in sections C405.2.2.1.</p> <p>[]- Exception 1:C405.2.2_C405.2.2.1: Luminaires requiring specific controls in accordance with C405.2.4.</p> <p>[]- Exception 2:C405.2.2_C405.2.2.1: Spaces with patient care.</p> <p>[]- Exception 3:C405.2.2_C405.2.2.1: Areas such as security or emergency areas that need continuous lighting.</p> <p>[]- Exception 4:C405.2.2_C405.2.2.1: Lighting that is related to means of egress in stairways, ramps, corridors, or emergency routes.</p> <p>[]- Exception 5:C405.2.2_C405.2.2.1: Shop and laboratory classrooms.</p>	<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>
6069 Controls	C405.2.3.1	Interior Lighting	<p>Spaces required to have light-reduction controls have a manual control that allows the occupant to reduce the connected lighting load in a reasonably uniform illumination pattern using one of the following or another approved method: (1) Continuous dimming of all luminaires from full output to less than 20 percent of full power, (2) Switching all luminaires to a reduced output of not less than 30 percent and not more than 70 percent of full power, or (3) Switching alternate luminaires or alternate rows of luminaires to achieve a reduced output of not less than 30 percent and not more than 70 percent of full power.</p> <p>[]- Exception 1:C405.2: Areas designated as security or emergency areas that are required to be continuously lighted.</p> <p>[]- Exception 2:C405.2: Interior exit stairways, interior exit ramps, and exit passageways.</p> <p>[]- Exception 3:C405.2: Emergency egress lighting that is normally off.</p>	<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>

6070 Controls	C405.2.4, C405.2.4.1, C405.2.4.2	Interior Lighting	<p>Daylight zones provided with individual controls that control the lights independent of general area lighting. See code section C405.2.3</p> <p>Daylight-responsive controls for applicable spaces, C405.2.3.1 Daylight responsive control function and section C405.2.3.2 Sidelit zone.</p> <p>[]- Exception 1:C405.2.4: Spaces where health patient care is directly provided.</p> <p>[]- Exception 2:C405.2.4: Lighting required to have specific application controls.</p> <p>[]- Exception 3:C405.2.4: Sidelit zones on first floor in Group A-2 and M occupancies.</p> <p>[]- Exception 4:C405.2.4: New buildings having total connected lighting power <= the adjusted interior lighting powered allowance (LPA adj, refer to section details and formula).</p> <p>[]- Exception 5:C405.2.4: Requirement does not apply.</p>	<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>
6074 Wattage	C405.2.5	Interior Lighting	<p>Additional interior lighting power allowed for special functions per the approved lighting plans and is automatically controlled and separated from general lighting.</p> <p>[]- Exception 1:C405.7: Air-over electric motors.</p> <p>[]- Exception 2:C405.7: Component sets of an electric motor.</p> <p>[]- Exception 3:C405.7: Liquid-cooled electric motors.</p> <p>[]- Exception 4:C405.7: Submersible electric motors.</p> <p>[]- Exception 5:C405.7: Inverter-only electric motors.</p> <p>[]- Exception 6:C405.7: Requirement does not apply.</p>	<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>
6077 Controls	C405.2.7	Exterior Lighting	<p>Automatic lighting controls for exterior lighting installed. Controls will be daylight controlled, set based on business operation time-of-day, or reduce connected lighting > 50%.</p> <p>[]- Exception 1:C405.2.7: Lighting for covered vehicle entrances and exits from buildings and parking structures where required for eye adaptation</p> <p>[]- Exception 2:C405.2.7: Lighting controlled from within dwelling units</p> <p>[]- Exception 3:C405.2.7: Requirement does not apply.</p>	<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>
6131 Wattage	C405.4.1	Exterior Lighting	<p>Exterior lighting power is consistent with what is shown on the approved lighting plans, demonstrating proposed watts are less than or equal to allowed watts.</p>	<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>
6132 Mandatory Additior	C406.10	Project	<p>Energy Monitoring - the building is equipped with an energy management system to monitor, record, and report energy consumption for electrical energy, by end-use category, contain meters, a data acquisition system and employ graphical reports.</p>	<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>

6133 Mandatory Additior	C406.11	Project	Fault Detection and Diagnostics - a fault detection and diagnostics system installed to monitor the HVAC operation and performance. Includes monitoring sensors and devices, sampling every 15 minutes, automatically report faults and provide recommendations for repair, and transmit recommendations to local authorized personnel.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6134 Mandatory Additior	C406.12	Project	Efficient Kitchen Equipment - the commercial kitchen has at least one fryer with all fryers, dishwashers, steam cookers and ovens complying with performance requirements of Tables C406.12(1) through C406.12(4).	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6185 Mandatory Additior	C406.2	Project	Equipment shall exceed the minimum efficiency requirements listed in Tables C403.2.3(1) through C403.2.3(7) by 10 %, in addition to the requirements of Section C403	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6135 Mandatory Additior	C406.2.1	Project	5% heating efficiency improvement - all HVAC and Plant heating equipment is 5% more efficient than required by 2021 IECC.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6136 Mandatory Additior	C406.2.2	Project	5% cooling efficiency improvement - all HVAC and Plant cooling equipment is 5% more efficient than required by 2021 IECC.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6137 Mandatory Additior	C406.2.3	Project	10% heating efficiency improvement - all HVAC and Plant heating equipment is 10% more efficient than required by 2021 IECC.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6138 Mandatory Additior	C406.2.4	Project	10% cooling efficiency improvement - all HVAC and Plant cooling equipment is 10% more efficient than required by 2021 IECC.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6139 Mandatory Additior	C406.3	Project	Reduced lighting power - this credit specifies that the connected lighting power is <= 10% more efficient than 2021 IECC requirements.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6140 Mandatory Additior	C406.4	Project	Enhanced Digital Lighting Controls - Interior lighting has the following enhanced lighting controls in accordance with Sections C405.2.1 through C405.2.3, Luminaires capable of continuous dimming and being addressed individually, at least 8 luminaires controlled in combination in a daylight zone, digital control system for fixtures with load shedding or occupancy sensors, Sequence of Operations documentation, and functional testing per Section C408.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6143 Mandatory Additior	C406.5	Project	On-site renewable energy credits - on-site renewable energy system supplies at least 1.71 Btuh or 0.5 watts per square foot of conditioned floor area OR provides at least 2 percent of the energy used within the building for mechanical and service water heating equipment and lighting regulated in Chapter 4.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6145 Mandatory Additior	C406.7.1	Project	Reduced energy use in service water heating - the hot water system contains waste heat recovery from service hot water, heat-recovery chillers, building equipment or process equipment or on-site renewable energy for water heating.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6146 Mandatory Additior	C406.7.3	Project	Reduced energy use in service water heating - the hot water heating system shall have a capacity weighted average fossil fuel water heating efficiency at least 95 thermal efficiency or 0.95 EF.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

6147 Mandatory Additor	C406.7.4	Project	Reduced energy use in service water heating - the hot water system is served by heat pump water heaters with a minimum Energy Factor of 3.0. The heat pump does not draw conditioned air from within the building.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6148 Mandatory Additor	C406.8	Project	Enhanced envelope performance - the building thermal envelope UA value is $\geq 15\%$ better than the total UA of the envelope specified by Section C402.1.5.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6149 Mandatory Additor	C406.9	Project	Reduced air infiltration energy - the measured air-leakage rate of the building envelope is lower than 0.25 cfm/ft ² . Comprehensive report documentation will be submitted to the code official and the building owner. []- Exception 1:C406.9: Building is greater than 250,000 square feet.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6083 HVAC	C408.2.2.1	Mechanical	Air outlets and zone terminal devices have means for air balancing. []- Exception 1:C408.2.2.1: Fans with fan motors of 1 hp (0.74 kW) or less. []- Exception 2:C408.2.2.1: Where throttling results in no greater than 1/3 hp fan horsepower draw above that required if the fan speed were adjusted []- Exception 3:C408.2.2.1: Requirement does not apply.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6153 Testing	C408.2.3.2	Mechanical	HVAC and service water heating control systems have been tested to ensure proper operation, calibration and adjustment of controls.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6104 SYSTEM_SPECIF	Table_C403.2.3b	Mechanical	Heat Rejection Equipment - Propeller or Axial Fan Open-Circuit Cooling Tower: Minimum Efficiency Requirement ≥ 40.2 gpm/hp .	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6105 SYSTEM_SPECIF	Table_C403.2.3b	Mechanical	Heat Rejection Equipment - Centrifugal Fan Open-Circuit Cooling Tower: Minimum Efficiency Requirement ≥ 20.0 gpm/hp.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6106 SYSTEM_SPECIF	Table_C403.2.3c	Mechanical	Heat Rejection Equipment - Propeller or Axial Fan Closed-Circuit Cooling Tower: Minimum Efficiency Requirement ≥ 16.1 gpm/hp.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6109 SYSTEM_SPECIF	Table_C403.2.3c	Mechanical	Heat Rejection Equipment - Centrifugal Fan Closed-Circuit Cooling Tower: Minimum Efficiency Requirement ≥ 7.0 gpm/hp	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6186 SYSTEM_SPECIF	Table_C403.2.3d	Mechanical	Heat Rejection Equipment - Propeller or Axial Fan Dry Coolers (air-cooled fluid coolers): Minimum Efficiency Requirement ≥ 4.5 gpm/hp	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6111 SYSTEM_SPECIFI	Table_C403.2.3h	Mechanical	Heat Rejection Equipment - Propeller or Axial Evaporative Condenser: Minimum Efficiency Requirement ≥ 134 kBtu/h-hp w/ Ammonia test fluid.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6112 SYSTEM_SPECIFI	Table_C403.2.3h	Mechanical	Heat Rejection Equipment - Centrifugal Evaporative Condenser: Minimum Efficiency Requirement ≥ 110 kBtu/h-hp w/ Ammonia test fluid.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6117 SYSTEM_SPECIFI	Table_C403.2.3h	Mechanical	Heat Rejection Equipment - Propeller or Axial Evaporative Condenser: Minimum Efficiency Requirement ≥ 160 kBtu/h-hp w/ R-448A test fluid.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

6119 SYSTEM_SPECIFI	Table_C403.2.3h	Mechanical	Heat Rejection Equipment - Centrifugal Evaporative Condenser: Minimum Efficiency Requirement ≥ 137 kBtu/h-hp w/ R-448A test fluid.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6121 SYSTEM_SPECIF	Table_C403.2.3h	Mechanical	Heat Rejection Equipment - Air-Cooled Condensers: Minimum Efficiency Requirement ≥ 176 kBtu/h-hp	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4. To be checked by Inspector at Project Completion and Prior to Issuance of Certificate of Occupancy						
6041 Fenestration	C402.4.2.2	Envelope	Skylights in office, storage, automotive service, manufacturing, non-refrigerated warehouse, retail store, and distribution/sorting area have a measured haze value < 90 percent tested per ASTM D1003 unless designed to exclude direct sunlight. []- Exception 1:C402.4.2.2: Skylights designed to exclude direct sunlight entering the occupied space by the use of fixed or automated baffles, geometry of skylight and well, or optical diffusers. []- Exception 2:C402.4.2.2: Requirement does not apply.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6179 Post Construction	C405.1	Project	At least 90% of dwelling unit permanently installed lighting shall have lamp efficacy ≤ 65 lm/W or luminaires with efficacy ≤ 45 lm/W or comply with C405.2.4 or C405.3. []- Exception 1:C405.1: Requirement does not apply.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6180 Post Construction	C405.11, C405.11.1	Project	50% of 15/20 amp receptacles installed in enclosed offices, conference rooms, copy rooms, break rooms, classrooms and workstations and $< 25\%$ of branch circuit feeders for modular furniture will have automatic receptacle control in accordance with C405.11.1. []- Exception 1:C405.11_C405.11.1: Requirement does not apply.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6181 Post Construction	C405.12	Project	Buildings with gross conditioned floor area $\geq 25,000$ ft ² will be equipped with a energy monitoring system in compliance with C405.12.1 through C405.12.5. []- Exception 1:C405.12: Requirement does not apply.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6079 Post Construction	C405.5.3	Project	Total voltage drop across the combination of feeders and branch circuits $\leq 5\%$. []- Exception 1:C405.5.3: Requirement does not apply.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

6073 Post Construction	C405.6	Project	<p>Low-voltage dry-type distribution electric transformers meet the minimum efficiency requirements of Table C405.6.</p> <p>[]- Exception 1:C405.6: Transformers meet the Energy Policy Act of 2005 special purposes exclusions.</p> <p>[]- Exception 2:C405.6: Transformers meet the Energy Policy Act of 2005 non-general purpose exclusions.</p> <p>[]- Exception 3:C405.6: Transformers meet the Energy Policy Act of 2005 exclusions with multiple voltage taps where the highest tap is >= 20% more than the lowest tap.</p> <p>[]- Exception 4:C405.6: Drive transformers.</p> <p>[]- Exception 5:C405.6: Rectifier transformers.</p> <p>[]- Exception 6:C405.6: Auto-transformers.</p> <p>[]- Exception 7:C405.6: Uninterruptible power system transformers.</p> <p>[]- Exception 8:C405.6: Impedance transformers.</p> <p>[]- Exception 9:C405.6: Regulating transformers.</p> <p>[]- Exception 10:C405.6: Sealed and nonventilating transformers.</p> <p>[]- Exception 11:C405.6: Machine tool transformers.</p> <p>[]- Exception 12:C405.6: Welding transformers.</p> <p>[]- Exception 13:C405.6: Grounding transformers.</p> <p>[]- Exception 14:C405.6: Testing transformers.</p> <p>[]- Exception 15:C405.6: Requirement does not apply.</p>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6075 Post Construction	C405.7	Project	<p>Electric motors meet the minimum efficiency requirements of Tables C405.7(1) through C405.7(4). Efficiency verified through certification under an approved certification program or the equipment efficiency ratings shall be provided by motor manufacturer (where certification programs do not exist).</p>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6078 Post Construction	C405.8.1, C405.8.2	Project	<p>Escalators and moving walks comply with ASME A17.1/CSA B44 and have automatic controls configured to reduce speed to the minimum permitted speed in accordance with ASME A17.1/CSA B44 or applicable local code when not conveying passengers.</p> <p>[]- Exception 1:C405.8.1_C405.8.2: A variable voltage drive system that reduces operating voltage in response to light loading is installed.</p> <p>[]- Exception 2:C405.9.1_C405.9.2: Requirement does not apply.</p>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6150 Post Construction	C408.1.1	Project	<p>Building operations and maintenance documents will be provided to the owner. Documents will cover manufacturers' information, specifications, programming procedures and means of illustrating to owner how building, equipment and systems are intended to be installed, maintained, and operated.</p>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

6151 Post Construction	C408.2.1	Mechanical	Commissioning plan developed by registered design professional or approved agency.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6152 Post Construction	C408.2.3.1	Mechanical	HVAC equipment, systems and system-to-system relationships have been tested to ensure proper operation. []- Exception 1:C408.2.3.1: Unitary or packaged HVAC equipment without supply air economizers.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6154 Post Construction	C408.2.3.3	Mechanical	Economizers have been tested to ensure proper operation.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6156 Post Construction	C408.2.4	Mechanical	Preliminary commissioning report completed and certified by registered design professional or approved agency.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6176 Post Construction	C408.2.5	Mechanical	Furnished HVAC as-built drawings submitted within 90 days of system acceptance.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6018 Post Construction	C408.2.5.2	Mechanical	Furnished Operation and Maintenance manuals for HVAC systems within 90 days of system acceptance.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6182 Post Construction	C408.2.5.3	Mechanical	An air and/or hydronic system balancing report is provided for HVAC systems.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6183 Post Construction	C408.2.5.4	Mechanical	Final commissioning report due to building owner within 90 days of receipt of certificate of occupancy.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6184 Post Construction	C408.3	Interior Lighting	Lighting systems have been tested to ensure proper calibration, adjustment, programming, and operation.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6177 Post Construction	C408.3.2	Interior Lighting	Furnished as-built drawings for electric power systems within 90 days of system acceptance.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6017 Post Construction	C408.3.2.2	Interior Lighting	Furnished operation and maintenance manual for lighting equipment and lighting controls provided to the building owner or designated representative.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

EnergyGaugeSummit® 8.0
INPUT DATA REPORT

Project Information

Project Name: Rainbolt Tech

Project Title: Renovation for Rainbolt Tech

Address: 162 SW Spencer Ct

State: FL

Zip: 32024

Owner: Rainbow Tech

Orientation: 0 Deg Clockwise. Walls &

Windows will be rotated

Building Type: Office
accordingly

Building Classification: Renovation to existing building

No.of Stories: 1

GrossArea: 7603 SF

Zones

No	Acronym	Description	Type	Area [sf]	Multiplier	Total Area [sf]	
1	1st FL	1st Floor	CONDITIONED	3926.0	1	3926.0	<input type="checkbox"/>
2	2nd FL	Zone 2	CONDITIONED	3677.0	1	3677.0	<input type="checkbox"/>

Spaces

No	Acronym	Description	Type	Depth [ft]	Width [ft]	Height [ft]	Multi plier	Total Area [sf]	Total Volume [cf]	
In Zone: 1st FL										
1	Corridor	Corridor	Corridor	1.00	720.00	10.00	1	720.0	7200.0	<input type="checkbox"/>
2	Foyer	Foyer	Corridor	1.00	379.00	10.00	1	379.0	3790.0	<input type="checkbox"/>
3	Gym	Gym	Office - Open Plan	1.00	636.00	10.00	1	636.0	6360.0	<input type="checkbox"/>
4	Men	Men	Toilet and Washroom	1.00	105.00	10.00	1	105.0	1050.0	<input type="checkbox"/>
5	Women	Women	Toilet and Washroom	1.00	150.00	10.00	1	150.0	1500.0	<input type="checkbox"/>
6	Stairway	Stairway	Stair - Active Traffic	1.00	197.00	10.00	1	197.0	1970.0	<input type="checkbox"/>
7	Office 1	Office 1	Office - Enclosed	1.00	253.00	10.00	1	253.0	2530.0	<input type="checkbox"/>
8	Office 2	Office 2	Office - Enclosed	1.00	256.00	10.00	1	256.0	2560.0	<input type="checkbox"/>
9	Office 3	Office 3	Office - Enclosed	1.00	205.00	10.00	1	205.0	2050.0	<input type="checkbox"/>
10	Office 4	Office 4	Office - Enclosed	1.00	150.00	10.00	1	150.0	1500.0	<input type="checkbox"/>
11	Office 5	Office 5	Office - Enclosed	1.00	137.00	10.00	1	137.0	1370.0	<input type="checkbox"/>
12	Office 6	Office 6	Office - Enclosed	1.00	107.00	10.00	1	107.0	1070.0	<input type="checkbox"/>
13	Office 7	Office 7	Office - Enclosed	1.00	125.00	10.00	1	125.0	1250.0	<input type="checkbox"/>
14	Office 8	Office 8	Office - Enclosed	1.00	200.00	10.00	1	200.0	2000.0	<input type="checkbox"/>
15	Office 9	Office 9	Office - Enclosed	1.00	136.00	10.00	1	136.0	1360.0	<input type="checkbox"/>
16	Office 10	Office 10	Office - Enclosed	1.00	170.00	10.00	1	170.0	1700.0	<input type="checkbox"/>
In Zone: 2nd FL										
1	Bath	Bath	Toilet and Washroom	1.00	61.00	10.00	1	61.0	610.0	<input type="checkbox"/>
2	Breakroom	Breakroom	Office - Enclosed	1.00	238.00	10.00	1	238.0	2380.0	<input type="checkbox"/>
3	Conference	Conference	Conference/meeting (Multiple Functions)	1.00	339.00	10.00	1	339.0	3390.0	<input type="checkbox"/>
4	Corridor	Corridor	Corridor	1.00	1198.00	10.00	1	1198.0	11980.0	<input type="checkbox"/>
5	Cubicle 1	Cubicle 1	Office - Open Plan	1.00	196.00	10.00	1	196.0	1960.0	<input type="checkbox"/>

6	Cubicle 2	Cubicle 2	Office - Open Plan	1.00	183.00	10.00	1	183.0	1830.0	<input type="checkbox"/>
7	Lounge	Lounge	Lobby (General) - Reception and Waiting	1.00	329.00	10.00	1	329.0	3290.0	<input type="checkbox"/>
8	Men	Men	Toilet and Washroom	1.00	41.00	10.00	1	41.0	410.0	<input type="checkbox"/>
9	Office 11	Office 11	Office - Enclosed	1.00	150.00	10.00	1	150.0	1500.0	<input type="checkbox"/>
10	Office 12	Office 12	Office - Enclosed	1.00	84.00	10.00	1	84.0	840.0	<input type="checkbox"/>
11	Office 13	Office 13	Office - Enclosed	1.00	87.00	10.00	1	87.0	870.0	<input type="checkbox"/>
12	Office 14	Office 14	Office - Enclosed	1.00	84.00	10.00	1	84.0	840.0	<input type="checkbox"/>
13	Office 15	Office 15	Office - Enclosed	1.00	137.00	10.00	1	137.0	1370.0	<input type="checkbox"/>
14	Office 16	Office 16	Office - Enclosed	1.00	80.00	10.00	1	80.0	800.0	<input type="checkbox"/>
15	Office 17	Office 17	Office - Enclosed	1.00	80.00	10.00	1	80.0	800.0	<input type="checkbox"/>
16	Office 18	Office 18	Office - Enclosed	1.00	80.00	10.00	1	80.0	800.0	<input type="checkbox"/>
17	Office 19	Office 19	Office - Enclosed	1.00	269.00	10.00	1	269.0	2690.0	<input type="checkbox"/>
18	Women	Women	Toilet and Washroom	1.00	41.00	10.00	1	41.0	410.0	<input type="checkbox"/>

Lighting							
No	Type	Category	No. of Luminaires	Watts per Luminaire	Power [W]	Control Type	
<div>In Zone: 1st FL</div> <div>In Space: Corridor</div> <div>1LEDGeneral Lighting1618288Occupant Sensor Auto OFF (Full or Partial)-Occupant Sensor Auto OFF (Full or Partial)Time-Switch: Auto Full Off or ScheduledOff-Time-Switch: Auto Full Off or Scheduled Off</div> <div>In Space: Foyer</div>							

In Space:	Gym	1	LED	General Lighting	8	18	144	Occupant Sensor Auto OFF (Full or Partial)-Occupant Sensor Auto OFF (Full or Partial) Time-Switch: Auto Full Off or Scheduled Off-Time-Switch: Auto Full Off or Scheduled Off	<input type="checkbox"/>
	Gym	1	LED	General Lighting	11	18	198	Manual (Local Control)-Manual (Local Control) Occupant Sensor (50%)-Occupant Sensor (50%) Occupant Sensor Auto Full OFF-Occupant Sensor Auto Full OFF	<input type="checkbox"/>
	Men	1	LED	General Lighting	3	18	54	Occupant Sensor (50%)-Occupant Sensor (50%) Occupant Sensor Auto Full OFF-Occupant Sensor Auto Full OFF	<input type="checkbox"/>
	Women	1	LED	General Lighting	3	18	54	Occupant Sensor (50%)-Occupant Sensor (50%) Occupant Sensor Auto Full OFF-Occupant Sensor Auto Full OFF	<input type="checkbox"/>
	Stairway	1	LED	General Lighting	5	18	90	Occupant Sensor (50%)-Occupant Sensor (50%) Occupant Sensor Auto Full OFF-Occupant Sensor Auto Full OFF	<input type="checkbox"/>
In Space: Office 1									

In Space:	Office 2	1	LED	General Lighting	4	18	72	Manual (Local Control)-Manual (Local Control) Occupant Sensor (50%)-Occupant Sensor (50%) Occupant Sensor Auto Full OFF-Occupant Sensor Auto Full OFF	<input type="checkbox"/>
	Office 3	1	LED	General Lighting	4	18	72	Manual (Local Control)-Manual (Local Control) Occupant Sensor (50%)-Occupant Sensor (50%) Occupant Sensor Auto Full OFF-Occupant Sensor Auto Full OFF	<input type="checkbox"/>
	Office 4	1	LED	General Lighting	4	18	72	Manual (Local Control)-Manual (Local Control) Occupant Sensor (50%)-Occupant Sensor (50%) Occupant Sensor Auto Full OFF-Occupant Sensor Auto Full OFF	<input type="checkbox"/>
	Office 5								

In Space:	Office 6	1	LED	General Lighting	4	18	72	Manual (Local Control)-Manual (Local Control) Occupant Sensor (50%)-Occupant Sensor (50%) Occupant Sensor Auto Full OFF-Occupant Sensor Auto Full OFF	<input type="checkbox"/>
	Office 7	1	LED	General Lighting	4	18	72	Manual (Local Control)-Manual (Local Control) Occupant Sensor (50%)-Occupant Sensor (50%) Occupant Sensor Auto Full OFF-Occupant Sensor Auto Full OFF	<input type="checkbox"/>
	Office 8	1	LED	General Lighting	4	18	72	Manual (Local Control)-Manual (Local Control) Occupant Sensor (50%)-Occupant Sensor (50%) Occupant Sensor Auto Full OFF-Occupant Sensor Auto Full OFF	<input type="checkbox"/>
	Office 9								

In Zone: 2nd FL In Space: Office 10	1	LED	General Lighting	4	18	72	Manual (Local Control)-Manual (Local Control) Occupant Sensor (50%)-Occupant Sensor (50%) Occupant Sensor Auto Full OFF-Occupant Sensor Auto Full OFF	<input type="checkbox"/>
	1	LED	General Lighting	4	18	72	Manual (Local Control)-Manual (Local Control) Occupant Sensor (50%)-Occupant Sensor (50%) Occupant Sensor Auto Full OFF-Occupant Sensor Auto Full OFF	<input type="checkbox"/>
	1	LED	General Lighting	1	15	15	Occupant Sensor (50%)-Occupant Sensor (50%) Occupant Sensor Auto Full OFF-Occupant Sensor Auto Full OFF	<input type="checkbox"/>
	1	LED	General Lighting	1	18	18	Manual (Local Control)-Manual (Local Control) Occupant Sensor (50%)-Occupant Sensor (50%) Occupant Sensor Auto Full OFF-Occupant Sensor Auto Full OFF	<input type="checkbox"/>
In Space: Conference								

In Space:	Corridor	1	LED	General Lighting	10	18	180	Manual (Local Control)-Manual (Local Control) Occupant Sensor (50%)-Occupant Sensor (50%) Occupant Sensor Auto Full OFF-Occupant Sensor Auto Full OFF	<input type="checkbox"/>
		1	LED	General Lighting	16	18	288	Occupant Sensor Auto OFF (Full or Partial)-Occupant Sensor Auto OFF (Full or Partial) Time-Switch: Auto Full Off or Scheduled Off-Time-Switch: Auto Full Off or Scheduled Off	<input type="checkbox"/>
	Cubicle 1	1	LED	General Lighting	6	18	108	Manual (Local Control)-Manual (Local Control) Occupant Sensor (50%)-Occupant Sensor (50%) Time-Switch: Auto Full Off or Scheduled Off-Time-Switch: Auto Full Off or Scheduled Off	<input type="checkbox"/>
	Cubicle 2	1	LED	General Lighting	6	18	108	Manual (Local Control)-Manual (Local Control) Occupant Sensor (50%)-Occupant Sensor (50%) Occupant Sensor Auto Full OFF-Occupant Sensor Auto Full OFF	<input type="checkbox"/>
In Space:	Lounge								

	1	LED	General Lighting	6	18	108	Occupant Sensor (50%)-Occupant Sensor (50%) Time-Switch: Auto Full Off or Scheduled Off-Time-Switch: Auto Full Off or Scheduled Off	<input type="checkbox"/>
In Space: Men	1	LED	General Lighting	1	18	18	Occupant Sensor (50%)-Occupant Sensor (50%) Occupant Sensor Auto Full OFF-Occupant Sensor Auto Full OFF	<input type="checkbox"/>
In Space: Office 11	1	LED	General Lighting	4	18	72	Manual (Local Control)-Manual (Local Control) Occupant Sensor (50%)-Occupant Sensor (50%) Occupant Sensor Auto Full OFF-Occupant Sensor Auto Full OFF	<input type="checkbox"/>
In Space: Office 12	1	LED	General Lighting	2	18	36	Manual (Local Control)-Manual (Local Control) Occupant Sensor (50%)-Occupant Sensor (50%) Occupant Sensor Auto Full OFF-Occupant Sensor Auto Full OFF	<input type="checkbox"/>
In Space: Office 13								

In Space:	Office 14	1	LED	General Lighting	2	18	36	Manual (Local Control)-Manual (Local Control) Occupant Sensor (50%)-Occupant Sensor (50%) Occupant Sensor Auto Full OFF-Occupant Sensor Auto Full OFF	<input type="checkbox"/>
	Office 15	1	LED	General Lighting	2	18	36	Manual (Local Control)-Manual (Local Control) Occupant Sensor (50%)-Occupant Sensor (50%) Occupant Sensor Auto Full OFF-Occupant Sensor Auto Full OFF	<input type="checkbox"/>
	Office 16	1	LED	General Lighting	2	18	36	Manual (Local Control)-Manual (Local Control) Occupant Sensor (50%)-Occupant Sensor (50%) Occupant Sensor Auto Full OFF-Occupant Sensor Auto Full OFF	<input type="checkbox"/>
	Office 17								

In Space:	Office 18	1	LED	General Lighting	2	18	36	Manual (Local Control)-Manual (Local Control) Occupant Sensor (50%)-Occupant Sensor (50%) Occupant Sensor Auto Full OFF-Occupant Sensor Auto Full OFF	<input type="checkbox"/>
	Office 19	1	LED	General Lighting	2	18	36	Manual (Local Control)-Manual (Local Control) Occupant Sensor (50%)-Occupant Sensor (50%) Occupant Sensor Auto Full OFF-Occupant Sensor Auto Full OFF	<input type="checkbox"/>
	Office 19	1	LED	General Lighting	2	18	36	Manual (Local Control)-Manual (Local Control) Occupant Sensor (50%)-Occupant Sensor (50%) Occupant Sensor Auto Full OFF-Occupant Sensor Auto Full OFF	<input type="checkbox"/>
	Women	1	LED	General Lighting	2	18	36	Occupant Sensor (50%)-Occupant Sensor (50%) Occupant Sensor Auto Full OFF-Occupant Sensor Auto Full OFF	<input type="checkbox"/>

Walls (Walls will be rotated clockwise by building rotation value)

No	Description	Type	Width [ft]	H (Effec [ft]	Multi plier	Area [sf]	Orientation	Conductance [Btu/hr. sf. F]	Heat Capacity [Btu/sf.F]	Dens. [lb/cf]	R-Value [h.s.f.F/Btu]	
In Zone:		1st FL										
1	East	Metal siding/2x4@24"+R1 1Batt/5/8"Gyp	88.33	10.00	1	883.3	East	0.0920	1.072	19.38	10.9	<input type="checkbox"/>
2	West	Metal siding/2x4@24"+R1 1Batt/5/8"Gyp	62.67	10.00	1	626.7	West	0.0920	1.072	19.38	10.9	<input type="checkbox"/>
3	North	0.5 Ply/35/8" Mtl std@24"oc/R11/0.5" Gyp	58.53	10.00	1	585.3	North	0.0798	0.539	7.98	12.5	<input type="checkbox"/>
4	South	0.5 Ply/35/8" Mtl std@24"oc/R11/0.5" Gyp	82.50	10.00	1	825.0	South	0.0798	0.539	7.98	12.5	<input type="checkbox"/>
In Zone:		2nd FL										
1	East	Metal siding/2x4@24"+R1 1Batt/5/8"Gyp	88.50	10.00	1	885.0	East	0.0920	1.072	19.38	10.9	<input type="checkbox"/>
2	North	0.5 Ply/35/8" Mtl std@24"oc/R11/0.5" Gyp	88.50	10.00	1	885.0	North	0.0798	0.539	7.98	12.5	<input type="checkbox"/>
3	South	0.5 Ply/35/8" Mtl std@24"oc/R11/0.5" Gyp	82.50	10.00	1	825.0	North	0.0798	0.539	7.98	12.5	<input type="checkbox"/>
4	West	Metal siding/2x4@24"+R1 1Batt/5/8"Gyp	88.50	10.00	1	885.0	West	0.0920	1.072	19.38	10.9	<input type="checkbox"/>

Windows (Windows will be rotated clockwise by building rotation value)

No	Description	Orientation	Shaded	U [Btu/hr sf F]	SHGC	Vis.Tra	W [ft]	H (Effec) [ft]	Multi plier	Total Area [sf]
----	-------------	-------------	--------	--------------------	------	---------	-----------	-------------------	----------------	--------------------

In Zone: 1st FL											
In Wall: East											
1	Pr0Zo1Wa1Wi1	East	No	1.2500	0.82	0.76	3.00	5.00	2	30.0	<input type="checkbox"/>
2	Pr0Zo1Wa1Wi2	East	No	1.2500	0.82	0.76	3.00	6.67	2	40.0	<input type="checkbox"/>

Doors												
No	Description	Type	Shaded?	Width [ft]	H (Effec) [ft]	Multi plier	Area [sf]	Cond. [Btu/hr. sf. F]	Dens. [lb/cf]	Heat Cap. [Btu/sf. F]	R-Value [h.sf.F/Btu]	
In Zone: 1st FL												
In Wall: North												
1	Pr0Zo1Wa3Dr1	Solid core flush (2.25)	No	3.00	6.67	1	20.0	0.3504	0.00	0.00	2.85	<input type="checkbox"/>

Roofs												
No	Description	Type	Width [ft]	H (Effec) [ft]	Multi plier	Area [sf]	Tilt [deg]	Cond. [Btu/hr. Sf. F]	Heat Cap [Btu/sf. F]	Dens. [lb/cf]	R-Value [h.sf.F/Btu]	
In Zone:	2nd FL											
1	Pr0Zo2Rf1	Mtl Bldg Roof/R-19 Batt	37.09	100.00	1	3709.0	0.00	0.0492	1.34	9.49	20.3	<input type="checkbox"/>

Skylights											
No	Description	Type	U [Btu/hr sf F]	SHGC	Vis.Trans	W [ft]	H (Effec) [ft]	Multiplier	Area [Sf]	Total Area [Sf]	
In Zone:											
In Roof:											
<input type="checkbox"/>											

Floors											
No	Description	Type	Width [ft]	H (Effec [ft]	Multi plier	Area [sf]	Cond. [Btu/hr. sf. F]	Heat Cap. [Btu/sf. F]	Dens. [lb/cf]	R-Value [h.s.f.F/Btu]	
In Zone: 1st FL											
1	Pr0Zo1Fl1	1 ft. soil, concrete floor, carpet and rubber pad	39.23	100.00	1	3923.0	0.2681	34.00	113.33	3.73	<input type="checkbox"/>

Systems											
AH-1/AH-2		System 1			Constant Volume Air Cooled Split System < 65000 Btu/hr				No. Of Units 1		
Component		Category			Capacity		Efficiency		IPLV		
1		Cooling System			60000.00		14.30		7.50		
2		Heating System			51195.00		1.00				
3		Air Handling System -Supply			1500.00		0.80				
DS-1/DS-2		5 Ton Multi-head Ductless Minisplit			Constant Volume Air Cooled Split System < 65000 Btu/hr				No. Of Units 1		
Component		Category			Capacity		Efficiency		IPLV		
1		Cooling System			60000.00		19.00		7.50		
2		Heating System			60000.00		8.50				
3		Air Handling System -Supply			1500.00		0.80				

Plant					
Equipment	Category	Size	Inst.No	Eff.	IPLV

Water Heaters					
W-Heater Description	Capacity Cap.Unit	I/P Rt.	Efficiency	Loss	
1 Electric Storage water heater (1 units)	30 [Gal]	5 [kW]	0.9200 [Ef]	Btu/h	<input type="checkbox"/>

Ext-Lighting						
Description	Category	No. of Luminaires	Watts per Luminaire	Area/Len/No. of units [sf/ft/No]	Control Type	Wattage [W]
						<input type="checkbox"/>

Piping						
No	Type	Operating Temperature [F]	Insulation Conductivity [Btu-in/h.sf.F]	Nomonal pipe Diameter [in]	Insulation Thickness [in]	Is Runout?
1	Domestic and Service Hot Water Systems	105.00	0.28	0.75	1.00	No <input type="checkbox"/>

Fenestration Used					
Name	Glass Type	No. of Panes	Glass Conductance [Btu/h.sf.F]	SHGC	VLT
ASHULSglClrAll Frm	User Defined	1	1.2500	0.8200	0.7600 <input type="checkbox"/>

Materials Used

Mat No	Acronym	Description	Only R-Value Used	RValue [h.sf.F/Btu]	Thickness [ft]	Conductivity [Btu/h.ft.F]	Density [lb/cf]	SpecificHeat [Btu/lb.F]	
187	Matl187	GYP OR PLAS BOARD,1/2IN	No	0.4533	0.0417	0.0920	50.00	0.2000	<input type="checkbox"/>
178	Matl178	CARPET W/RUBBER PAD	Yes	1.2300					<input type="checkbox"/>
265	Matl265	Soil, 1 ft	No	2.0000	1.0000	0.5000	100.00	0.2000	<input type="checkbox"/>
48	Matl48	6 in. Heavyweight concrete	No	0.5000	0.5000	1.0000	140.00	0.2000	<input type="checkbox"/>
211	Matl211	POLYSTYRENE,EXP.,1/2IN	No	2.0850	0.0417	0.0200	1.80	0.2900	<input type="checkbox"/>
12	Matl12	3 in. Insulation	No	10.0000	0.2500	0.0250	2.00	0.2000	<input type="checkbox"/>
23	Matl23	6 in. Insulation	No	20.0000	0.5000	0.0250	5.70	0.2000	<input type="checkbox"/>
4	Matl4	Steel siding	No	0.0002	0.0050	26.0000	480.00	0.1000	<input type="checkbox"/>
271	Matl271	2x4@24" oc + R11 Batt	No	10.4179	0.2917	0.0280	7.11	0.2000	<input type="checkbox"/>
279	Matl279	Solid core flush (2.25")	Yes	2.8537					<input type="checkbox"/>
94	Matl94	BUILT-UP ROOFING, 3/8IN	No	0.3366	0.0313	0.0930	70.00	0.3500	<input type="checkbox"/>

Constructs Used

No	Name	Simple Construct	Massless Construct	Conductance [Btu/h.sf.F]	Heat Capacity [Btu/sf.F]	Density [lb/cf]	RValue [h.sf.F/Btu]	
1015	0.5 Ply/35/8" Mtl std@24"oc/R11/0.5" Gyp	No	No	0.08	0.54	7.98	12.5	<input type="checkbox"/>
	Layer	Material No.	Material	Thickness [ft]	Framing Factor			
	1	211	POLYSTYRENE,EXP.,1/2IN,	0.0417	0.000			<input type="checkbox"/>
	2	12	3 in. Insulation	0.2500	0.000			<input type="checkbox"/>
	3	187	GYP OR PLAS BOARD,1/2IN	0.0417	0.000			<input type="checkbox"/>

No	Name	Simple Construct	Massless Construct	Conductance [Btu/h.sf.F]	Heat Capacity [Btu/sf.F]	Density [lb/cf]	RValue [h.sf.F/Btu]	
1055	Metal siding/2x4@24"+R11Batt/5/8"Gyp	No	No	0.09	1.07	19.38	10.9	<input type="checkbox"/>
	Layer	Material No.	Material	Thickness [ft]	Framing Factor			
	1	4	Steel siding	0.0050	0.000			<input type="checkbox"/>
	2	271	2x4@24" oc + R11 Batt	0.2917	0.000			<input type="checkbox"/>
	3	187	GYP OR PLAS BOARD,1/2IN	0.0417	0.000			<input type="checkbox"/>
No	Name	Simple Construct	Massless Construct	Conductance [Btu/h.sf.F]	Heat Capacity [Btu/sf.F]	Density [lb/cf]	RValue [h.sf.F/Btu]	
1056	Mtl Bldg Roof/R-19 Batt	No	No	0.05	1.34	9.49	20.3	<input type="checkbox"/>
	Layer	Material No.	Material	Thickness [ft]	Framing Factor			
	1	94	BUILT-UP ROOFING, 3/8IN	0.0313	0.000			<input type="checkbox"/>
	2	23	6 in. Insulation	0.5000	0.000			<input type="checkbox"/>
No	Name	Simple Construct	Massless Construct	Conductance [Btu/h.sf.F]	Heat Capacity [Btu/sf.F]	Density [lb/cf]	RValue [h.sf.F/Btu]	
1057	1 ft. soil, concrete floor, carpet and rubber pad	No	No	0.27	34.00	113.33	3.7	<input type="checkbox"/>
	Layer	Material No.	Material	Thickness [ft]	Framing Factor			
	1	265	Soil, 1 ft	1.0000	0.000			<input type="checkbox"/>
	2	48	6 in. Heavyweight concrete	0.5000	0.000			<input type="checkbox"/>
	3	178	CARPET W/RUBBER PAD		0.000			<input type="checkbox"/>

No	Name	Simple Construct	Massless Construct	Conductance [Btu/h.sf.F]	Heat Capacity [Btu/sf.F]	Density [lb/cf]	RValue [h.sf.F/Btu]	
1058	Solid core flush (2.25)	No	Yes	0.35			2.9	<input type="checkbox"/>
	Layer	Material No.	Material	Thickness [ft]	Framing Factor			
	1	279	Solid core flush (2.25")		0.000			<input type="checkbox"/>

Rainbolt Tech 1st Floor

Location	20219 93rd Place Obrein FL 32071
Building owner	Rainbolt Tech
Program user	Rachel Miller
Company	Go Green Engineering
Comments	
By	Go Green Engineering LLC
Dataset name	C:\PROJECTS\GREEN ENGINEERING SOLUTIONS\2024\RAINBOLT TECH\RAINBOLT TECH.TRC
Calculation time	10:36 AM on 05/16/2024
TRACE® 700 version	6.3.5
Location	Jacksonville, Florida
Latitude	30.0 deg
Longitude	81.0 deg
Time Zone	5
Elevation	24 ft
Barometric pressure	29.9 in. Hg
Air density	0.0760 lb/cu ft
Air specific heat	0.2444 Btu/lb·°F
Density-specific heat product	1.1144 Btu/h·cfm·°F
Latent heat factor	4,905.3 Btu·min/h·cu ft
Enthalpy factor	4.5588 lb·min/hr·cu ft
Summer design dry bulb	97.3 °F
Summer design wet bulb	76.5 °F
Winter design dry bulb	32.0 °F
Summer clearness number	0.95
Winter clearness number	0.95
Summer ground reflectance	0.20
Winter ground reflectance	0.20
Carbon Dioxide Level	400 ppm
Design simulation period	January - December
Cooling load methodology	TETD-TA1
Heating load methodology	UATD



By Go Green Engineering LLC

DS-1/2

Constant Volume

COOLING COIL PEAK					CLG SPACE PEAK		HEATING COIL PEAK				TEMPERATURES		
Peaked at Time:		Mo/Hr: 7 / 16			Mo/Hr: 6 / 13		Mo/Hr: Heating Design				Cooling		Heating
Outside Air:		OADB/WB/HR: 94 / 77 / 117			OADB: 95		OADB: 32				SADB	55.0	72.4
											Ra Plenum	77.1	68.9
											Return	77.0	68.9
											Ret/OA	78.4	65.8
											Fn MtrTD	0.0	0.0
											Fn BldTD	0.0	0.0
											Fn Frict	0.0	0.0
	Space	Plenum	Net	Percent	Space	Percent	Space Peak	Coil Peak	Percent				
	Sens. + Lat.	Sens. + Lat	Total	Of Total	Sensible	Of Total	Space Sens	Tot Sens	Of Total				
	Btu/h	Btu/h	Btu/h	(%)	Btu/h	(%)	Btu/h	Btu/h	(%)				
Envelope Loads					Envelope Loads								
Skylite Solar	0	0	0	0	0	0	Skylite Solar	0	0	0.00			
Skylite Cond	0	0	0	0	0	0	Skylite Cond	0	0	0.00			
Roof Cond	0	9,255	9,255	8	0	0	Roof Cond	0	-3,704	13.63			
Glass Solar	2,093	0	2,093	2	2,010	2	Glass Solar	0	0	0.00			
Glass/Door Cond	260	0	260	0	276	0	Glass/Door Cond	-683	-683	2.51			
Wall Cond	9,466	2,314	11,780	10	10,212	12	Wall Cond	-7,722	-9,628	35.42			
Partition/Door	0	0	0	0	0	0	Partition/Door	0	0	0.00			
Floor	0	0	0	0	0.00	0	Floor	0	0	0.00			
Adjacent Floor	0.00	0.00	0.00	0.00	0.00	0.00	Adjacent Floor	0.00	0.00	0.00			
Infiltration	0	0	0	0	0	0	Infiltration	0	0	0.00			
Sub Total ==>	11,820	11,569	23,389	20	12,499	15	Sub Total ==>	-8,405	-14,016	51.56			
Internal Loads					Internal Loads								
Lights	26,778	0	26,778	23	26,778	32	Lights	0	0	0.00			
People	12,700	0	12,700	11	7,700	9	People	0	0	0.00			
Misc	33,473	0	33,473	29	33,473	40	Misc	0	0	0.00			
Sub Total ==>	72,951	0	72,951	64	67,951	82	Sub Total ==>	0	0	0.00			
Ceiling Load	2,543	-2,543	0	0	2,525	3	Ceiling Load	-1,382	0	0.00			
Ventilation Load	0	0	18,519	16	0	0	Ventilation Load	0	-13,169	48.44			
Adj Air Trans Heat	0	0	0	0	0	0	Adj Air Trans Heat	0	0	0			
Dehumid. Ov Sizing			0	0			Ov/Undr Sizing	0	0	0.00			
Ov/Undr Sizing	0		0	0	0	0	Exhaust Heat	0	0	0.00			
Exhaust Heat		0	0	0			OA Preheat Diff.	0	0	0.00			
Sup. Fan Heat		0	0	0			RA Preheat Diff.	0	0	0.00			
Ret. Fan Heat		0	0	0			Additional Reheat	0	0	0.00			
Duct Heat Pkup		0	0	0									
Underflr Sup Ht Pkup			0	0			Underflr Sup Ht Pkup		0	0.00			
Supply Air Leakage		0	0	0			Supply Air Leakage		0	0.00			
Grand Total ==>	87,314	9,026	114,859	100.00	82,975	100.00	Grand Total ==>	-9,787	-27,185	100.00			

AIRFLOWS		
	Cooling	Heating
Diffuser	3,723	3,723
Terminal	3,723	3,723
Main Fan	3,723	3,723
Sec Fan	0	0
Nom Vent	311	311
AHU Vent	311	311
Infil	0	0
MinStop/Rh	0	0
Return	3,412	3,412
Exhaust	0	0
Rm Exh	311	311
Auxiliary	0	0
Leakage Dwn	0	0
Leakage Ups	0	0

ENGINEERING CKS		
	Cooling	Heating
% OA	8.4	8.4
cfm/ft²	0.95	0.95
cfm/ton	388.97	
ft²/ton	409.86	
Btu/hr-ft²	29.28	-6.93
No. People	20	

COOLING COIL SELECTION											AREAS				HEATING COIL SELECTION				
	Total Capacity ton	Capacity MBh	Sens Cap. MBh	Coil Airflow cfm	Enter °F	DB/WB/HR °F gr/lb		Leave °F	DB/WB/HR °F gr/lb		Gross Total	Glass ft² (%)		Capacity MBh	Coil Airflow cfm	Ent °F	Lvg °F		
Main Clg	9.6	114.9	97.5	3,723	78.4	63.0	61.4	55.0	52.4	54.5	Floor	3,923		Main Htg	-27.2	3,723	65.8	72.4	
Aux Clg	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	Part	0		Aux Htg	0.0	0	0.0	0.0	
Opt Vent	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	Int Door	1		Preheat	0.0	0	0.0	0.0	
											ExFlr	0							
Total	9.6	114.9									Roof	2,144	0	Humidif	0.0	0	0.0	0.0	
											Wall	4,016	35	Opt Vent	0.0	0	0.0	0.0	
											Ext Door	20	0	Total	-27.2				

By Go Green Engineering LLC

Corridor

COOLING COIL PEAK					CLG SPACE PEAK			HEATING COIL PEAK				TEMPERATURES							
Peaked at Time: Mo/Hr: 7 / 16					Mo/Hr: 6 / 17			Mo/Hr: Heating Design				Cooling			Heating				
Outside Air: OADB/WB/HR: 94 / 77 / 117					OADB: 96			OADB: 32				SADB	55.0	70.6					
												Ra Plenum	77.2	68.9					
												Return	77.2	68.9					
												Ret/OA	78.6	65.9					
												Fn MtrTD	0.0	0.0					
												Fn BldTD	0.0	0.0					
												Fn Frict	0.0	0.0					
Space		Plenum		Net Total	Percent Of Total	Space		Percent Of Total	Space Peak		Coil Peak		Percent Of Total						
Sens. + Lat.	Sens. + Lat.	Sens. + Lat.	Sens. + Lat.			Space Sens	Coil Tot Sens		Coil Tot Sens	Coil Tot Sens									
Btu/h	Btu/h	Btu/h	Btu/h	Btu/h	Btu/h	Btu/h	Btu/h	Btu/h	Btu/h	Btu/h	Btu/h	Btu/h	Btu/h	Btu/h	Btu/h				
Envelope Loads					Envelope Loads			Envelope Loads				Envelope Loads							
Skylite Solar	0	0	0	0	0	0	0	0	0	0	0	0.00	0	0	0.00				
Skylite Cond	0	0	0	0	0	0	0	0	0	0	0	0.00	0	0	0.00				
Roof Cond	0	3,140	3,140	18	0	0	0	0	0	-1,239	45.12	0	0	0	0.00				
Glass Solar	0	0	0	0	0	0	0	0	0	0	0	0.00	0	0	0.00				
Glass/Door Cond	0	0	0	0	0	0	0	0	0	0	0	0.00	0	0	0.00				
Wall Cond	95	23	117	1	131	1	0	0	-78	-97	3.52	0	0	0	0.00				
Partition/Door	0	0	0	0	0	0	0	0	0	0	0	0.00	0	0	0.00				
Floor	0	0	0	0	0.00	0	0	0	0	0	0	0.00	0	0	0.00				
Adjacent Floor	0.00	0.00	0.00	0.00	0.00	0.00	0	0	0.00	0.00	0.00	0.00	0	0	0.00				
Infiltration	0	0	0	0	0	0	0	0	0	0	0	0.00	0	0	0.00				
Sub Total ==>	95	3,163	3,258	19	131	1	0	0	-78	-1,336	48.64	0	0	0	0.00				
Internal Loads					Internal Loads			Internal Loads				Internal Loads							
Lights	4,894	0	4,894	29	4,894	42	0	0	0	0	0	0.00	0	0	0.00				
People	0	0	0	0	0	0	0	0	0	0	0	0.00	0	0	0.00				
Misc	6,118	0	6,118	36	6,118	53	0	0	0	0	0	0.00	0	0	0.00				
Sub Total ==>	11,012	0	11,012	65	11,012	95	0	0	0	0	0	0.00	0	0	0.00				
Ceiling Load	506	-506	0	0	505	4	0	0	-253	0	0.00	0	0	0	0.00				
Ventilation Load	0	0	2,748	16	0	0	0	0	0	-1,821	66.32	0	0	0	0.00				
Adj Air Trans Heat	0	0	0	0	0	0	0	0	0	0	0	0.00	0	0	0.00				
Dehumid. Ov Sizing	0	0	0	0	0	0	0	0	0	0	0	0.00	0	0	0.00				
Ov/Undr Sizing	0	0	0	0	0	0	0	0	0	0	0	0.00	0	0	0.00				
Exhaust Heat	0	0	0	0	0	0	0	0	0	0	0	0.00	0	0	0.00				
Sup. Fan Heat	0	0	0	0	0	0	0	0	0	0	0	0.00	0	0	0.00				
Ret. Fan Heat	0	0	0	0	0	0	0	0	0	0	0	0.00	0	0	0.00				
Duct Heat Pkup	0	0	0	0	0	0	0	0	0	0	0	0.00	0	0	0.00				
Underflr Sup Ht Pkup	0	0	0	0	0	0	0	0	0	0	0	0.00	0	0	0.00				
Supply Air Leakage	0	0	0	0	0	0	0	0	0	0	0	0.00	0	0	0.00				
Grand Total ==>	11,613	2,657	17,018	100.00	11,647	100.00	0	0	-331	-2,746	100.00	0	0	0	0.00				
AIRFLOWS					AIRFLOWS					AIRFLOWS					AIRFLOWS				
Cooling					Cooling					Cooling					Cooling				
Heating					Heating					Heating					Heating				
Diffuser					Diffuser					Diffuser					Diffuser				
Terminal					Terminal					Terminal					Terminal				
Main Fan					Main Fan					Main Fan					Main Fan				
Sec Fan					Sec Fan					Sec Fan					Sec Fan				
Nom Vent					Nom Vent					Nom Vent					Nom Vent				
AHU Vent					AHU Vent					AHU Vent					AHU Vent				
Infil					Infil					Infil					Infil				
MinStop/Rh					MinStop/Rh					MinStop/Rh					MinStop/Rh				
Return					Return					Return					Return				
Exhaust					Exhaust					Exhaust					Exhaust				
Rm Exh					Rm Exh					Rm Exh					Rm Exh				
Auxiliary					Auxiliary					Auxiliary					Auxiliary				
Leakage Dwn					Leakage Dwn					Leakage Dwn					Leakage Dwn				
Leakage Ups					Leakage Ups					Leakage Ups					Leakage Ups				
ENGINEERING CKS					ENGINEERING CKS					ENGINEERING CKS					ENGINEERING CKS				
Cooling					Cooling					Cooling					Cooling				
Heating					Heating					Heating					Heating				
% OA					% OA					% OA					% OA				
cfm/ft²					cfm/ft²					cfm/ft²					cfm/ft²				
cfm/ton					cfm/ton					cfm/ton					cfm/ton				
ft²/ton					ft²/ton					ft²/ton					ft²/ton				
Btu/hr-ft²					Btu/hr-ft²					Btu/hr-ft²					Btu/hr-ft²				
No. People					No. People					No. People					No. People				

COOLING COIL SELECTION									AREAS			HEATING COIL SELECTION				
Total Capacity		Sens Cap.	Coil Airflow	Enter DB/WB/HR		Leave DB/WB/HR		Gross Total	Glass		Capacity		Coil Airflow	Ent °F	Lvg °F	
ton	MBh			°F	°F	gr/lb	°F		°F	gr/lb	ft²	(%)				MBh
Main Clg	1.4	17.0	15.2	523	78.6	62.8	60.2	55.0	51.5	51.2	-2.8	523	65.9	70.6		
Aux Clg	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0	0.0	0.0		
Opt Vent	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0	0.0	0.0		
Total	1.4	17.0														
									Floor			Main Htg				
									Part			Aux Htg				
									Int Door			Preheat				
									ExFlr							
									Roof			Humidif				
									Wall			Opt Vent				
									Ext Door			Total				

By Go Green Engineering LLC

Foyer

COOLING COIL PEAK					CLG SPACE PEAK			HEATING COIL PEAK				TEMPERATURES		
Peaked at Time:		Mo/Hr: 8 / 11			Mo/Hr: 6 / 11		Mo/Hr: Heating Design				Cooling		Heating	
Outside Air:		OADB/WB/HR: 88 / 75 / 110			OADB: 90		OADB: 32				SADB	55.0	73.1	
											Ra Plenum	76.2	68.9	
											Return	76.2	68.9	
											Ret/OA	77.2	65.7	
											Fn MtrTD	0.0	0.0	
											Fn BldTD	0.0	0.0	
											Fn Frict	0.0	0.0	
	Space	Plenum	Net	Percent	Space	Percent		Space Peak	Coil Peak	Percent				
	Sens. + Lat.	Sens. + Lat	Total	Of Total	Sensible	Of Total		Space Sens	Tot Sens	Of Total				
	Btu/h	Btu/h	Btu/h	(%)	Btu/h	(%)		Btu/h	Btu/h	(%)				
Envelope Loads					Envelope Loads									
Skylite Solar	0	0	0	0	0	0	Skylite Solar	0	0	0.00				
Skylite Cond	0	0	0	0	0	0	Skylite Cond	0	0	0.00				
Roof Cond	0	0	0	0	0	0	Roof Cond	0	0	0.00				
Glass Solar	2,093	0	2,093	15	2,010	18	Glass Solar	0	0	0.00				
Glass/Door Cond	171	0	171	1	190	2	Glass/Door Cond	-531	-531	13.07				
Wall Cond	1,633	434	2,067	14	1,721	16	Wall Cond	-1,024	-1,294	31.84				
Partition/Door	0		0	0	0	0	Partition/Door	0	0	0.00				
Floor	0		0	0	0.00	0	Floor	0	0	0.00				
Adjacent Floor	0.00	0.00	0.00	0.00	0.00	0.00	Adjacent Floor	0.00	0.00	0.00				
Infiltration	0		0	0	0	0	Infiltration	0	0	0.00				
Sub Total ==>	3,898	434	4,332	30	3,922	36	Sub Total ==>	-1,555	-1,825	44.91				
Internal Loads					Internal Loads									
Lights	2,587	0	2,587	18	2,587	24	Lights	0	0	0.00				
People	2,000	0	2,000	14	1,000	9	People	0	0	0.00				
Misc	3,234	0	3,234	23	3,234	30	Misc	0	0	0.00				
Sub Total ==>	7,821	0	7,821	55	6,821	63	Sub Total ==>	0	0	0.00				
Ceiling Load	138	-138	0	0	159	1	Ceiling Load	-134	0	0.00				
Ventilation Load	0	0	2,162	15	0	0	Ventilation Load	0	-1,821	44.82				
Adj Air Trans Heat	0		0	0	0	0	Adj Air Trans Heat	0	0	0				
Dehumid. Ov Sizing			0	0			Ov/Undr Sizing	0	0	0.00				
Ov/Undr Sizing	0		0	0	0	0	Exhaust Heat	0	0	0.00				
Exhaust Heat		0	0	0			OA Preheat Diff.		0	0.00				
Sup. Fan Heat			0	0			RA Preheat Diff.		0	0.00				
Ret. Fan Heat		0	0	0			Additional Reheat		0	0.00				
Duct Heat Pkup		0	0	0			System Plenum Heat		-417	10.27				
Underflr Sup Ht Pkup			0	0			Underflr Sup Ht Pkup		0	0.00				
Supply Air Leakage		0	0	0			Supply Air Leakage		0	0.00				
Grand Total ==>	11,856	296	14,315	100.00	10,902	100.00	Grand Total ==>	-1,689	-4,063	100.00				
											AIRFLOWS			
											Cooling	Heating		
											Diffuser	489	489	
											Terminal	489	489	
											Main Fan	489	489	
											Sec Fan	0	0	
											Nom Vent	43	43	
											AHU Vent	43	43	
											Infil	0	0	
											MinStop/Rh	0	0	
											Return	446	446	
											Exhaust	0	0	
											Rm Exh	43	43	
											Auxiliary	0	0	
											Leakage Dwn	0	0	
											Leakage Ups	0	0	
											ENGINEERING CKS			
											Cooling	Heating		
											% OA	8.8	8.8	
											cfm/ft²	1.29	1.29	
											cfm/ton	410.06		
											ft²/ton	317.71		
											Btu/hr·ft²	37.77	-10.72	
											No. People	4.0	10.6/1000 ft²	

COOLING COIL SELECTION										AREAS				HEATING COIL SELECTION					
	Total Capacity ton	MBh	Sens Cap. MBh	Coil Airflow cfm	Enter DB/WB/HR °F °F gr/lb			Leave DB/WB/HR °F °F gr/lb			Gross Total		Glass ft² (%)		Capacity MBh	Coil Airflow cfm	Ent °F	Lvg °F	
Main Clg	1.2	14.3	11.8	489	77.2	63.1	63.7	55.0	53.1	57.3	Floor	379			Main Htg	-4.1	489	65.7	73.1
Aux Clg	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	Part	0			Aux Htg	0.0	0	0.0	0.0
Opt Vent	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	Int Door	1			Preheat	0.0	0	0.0	0.0
											ExFlr	0							
											Roof	0	0	0	Humidif	0.0	0	0.0	0.0
											Wall	570	35	6	Opt Vent	0.0	0	0.0	0.0
											Ext Door	0	0	0	Total	-4.1			

Room Checksums

By Go Green Engineering LLC

Gym

COOLING COIL PEAK					CLG SPACE PEAK			HEATING COIL PEAK				TEMPERATURES		
Peaked at Time: Mo/Hr: 8 / 14					Mo/Hr: 6 / 13			Mo/Hr: Heating Design						
Outside Air: OADB/WB/HR: 94 / 77 / 117					OADB: 95			OADB: 32						
Space Sens. + Lat.	Plenum Sens. + Lat.	Net Total	Percent Of Total		Space Sensible	Percent Of Total		Space Peak	Coil Peak	Percent		SADB	Cooling	Heating
Btu/h	Btu/h	Btu/h	(%)		Btu/h	(%)		Space Sens	Tot Sens	Of Total		Ra Plenum		
								Btu/h	Btu/h	(%)		Ret/OA		
												Fn MtrTD		
												Fn BldTD		
												Fn Frict		
Envelope Loads					Envelope Loads			Envelope Loads						
Skylite Solar	0	0	0	0	0	0	0	0	0	0.00	0	0.00	55.0	72.2
Skylite Cond	0	0	0	0	0	0	0	0	0	0.00	0	0.00	77.1	68.9
Roof Cond	0	0	0	0	0	0	0	0	0	0.00	0	0.00	77.1	68.9
Glass Solar	0	0	0	0	0	0	0	0	0	0.00	0	0.00	78.7	65.4
Glass/Door Cond	0	0	0	0	0	0	0	0	0	0.00	0	0.00	0.0	0.0
Wall Cond	1,655	392	2,047	9	1,889	12	0	-1,554	-1,931	34.73	0	0.00	0.0	0.0
Partition/Door	0	0	0	0	0	0	0	0	0	0.00	0	0.00	0.0	0.0
Floor	0	0	0	0	0.00	0	0	0	0	0.00	0	0.00	0.0	0.0
Adjacent Floor	0.00	0.00	0.00	0.00	0.00	0.00	0	0.00	0.00	0.00	0	0.00	0.0	0.0
Infiltration	0	0	0	0	0	0	0	0	0	0.00	0	0.00	0.0	0.0
Sub Total ==>	1,655	392	2,047	9	1,889	12	0	-1,554	-1,931	34.73	0	0.00	0.0	0.0
Internal Loads					Internal Loads			Internal Loads						
Lights	4,341	0	4,341	20	4,341	27	0	0	0	0.00	0	0.00	730	730
People	5,700	0	5,700	26	4,200	26	0	0	0	0.00	0	0.00	730	730
Misc	5,427	0	5,427	25	5,427	33	0	0	0	0.00	0	0.00	730	730
Sub Total ==>	15,468	0	15,468	71	13,968	86	0	0	0	0.00	0	0.00	0	0
Ceiling Load					Ceiling Load			Ceiling Load						
Ventilation Load	419	-419	0	0	408	3	0	-224	0	0.00	0	0.00	70	70
Adj Air Trans Heat	0	0	4,274	20	0	0	0	0	-2,964	53.31	0	0.00	70	70
Dehumid. Ov Sizing	0	0	0	0	0	0	0	0	0	0	0	0.00	0	0
Ov/Undr Sizing	0	0	0	0	0	0	0	0	0	0.00	0	0.00	0	0
Exhaust Heat	0	0	0	0	0	0	0	0	0	0.00	0	0.00	0	0
Sup. Fan Heat	0	0	0	0	0	0	0	0	0	0.00	0	0.00	0	0
Ret. Fan Heat	0	0	0	0	0	0	0	0	0	0.00	0	0.00	0	0
Duct Heat Pkup	0	0	0	0	0	0	0	0	0	0.00	0	0.00	0	0
Underflr Sup Ht Pkup	0	0	0	0	0	0	0	0	0	0.00	0	0.00	0	0
Supply Air Leakage	0	0	0	0	0	0	0	0	0	0.00	0	0.00	0	0
Grand Total ==>	17,542	-26	21,789	100.00	16,265	100.00	0	-1,778	-5,560	100.00	0	0.00	0	0

AIRFLOWS		
	Cooling	Heating
Diffuser	730	730
Terminal	730	730
Main Fan	730	730
Sec Fan	0	0
Nom Vent	70	70
AHU Vent	70	70
Infil	0	0
MinStop/Rh	0	0
Return	660	660
Exhaust	0	0
Rm Exh	70	70
Auxiliary	0	0
Leakage Dwn	0	0
Leakage Ups	0	0

ENGINEERING CKS		
	Cooling	Heating
% OA	9.6	9.6
cfm/ft²	1.15	1.15
cfm/ton	401.92	
ft²/ton	350.27	
Btu/hr-ft²	34.26	-8.74
No. People	6.0	9.4/1000 ft²

COOLING COIL SELECTION										AREAS				HEATING COIL SELECTION					
	Total Capacity		Sens Cap.	Coil Airflow	Enter DB/WB/HR			Leave DB/WB/HR			Gross Total		Glass			Capacity	Coil Airflow	Ent	Lvg
	ton	MBh	MBh	cfm	°F	°F	gr/lb	°F	°F	gr/lb			ft²	(%)		MBh	cfm	°F	°F
Main Clg	1.8	21.8	17.5	730	78.7	63.8	64.9	55.0	53.8	59.9	Floor	636			Main Htg	-5.6	730	65.4	72.2
Aux Clg	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	Part	0			Aux Htg	0.0	0	0.0	0.0
Opt Vent	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	Int Door	1			Preheat	0.0	0	0.0	0.0
											ExFlr	0							
											Roof	0	0	0	Humidif	0.0	0	0.0	0.0
											Wall	798	0	0	Opt Vent	0.0	0	0.0	0.0
											Ext Door	0	0	0	Total	-5.6			
Total	1.8	21.8																	

Room Checksums

By Go Green Engineering LLC

Men

COOLING COIL PEAK					CLG SPACE PEAK			HEATING COIL PEAK				TEMPERATURES		
Peaked at Time: Mo/Hr: 6 / 14					Mo/Hr: 6 / 14			Mo/Hr: Heating Design				Cooling Heating		
Outside Air: OADB/WB/HR: 97 / 76 / 99					OADB: 97			OADB: 32				SADB	55.0	79.4
Space Sens. + Lat.	Plenum Sens. + Lat.	Net Total	Percent Of Total		Space Sensible	Percent Of Total		Space Peak	Coil Peak	Percent		Ra Plenum	77.2	68.9
Btu/h	Btu/h	Btu/h	(%)		Btu/h	(%)		Space Sens	Tot Sens	Of Total		Return	77.2	68.9
Envelope Loads					Envelope Loads			Envelope Loads				Fn MtrTD	0.0	0.0
Skylite Solar	0	0	0	0	0	0	0	0	0	0.00	0	Fn BldTD	0.0	0.0
Skylite Cond	0	0	0	0	0	0	0	0	0	0.00	0	Fn Frict	0.0	0.0
Roof Cond	0	0	0	0	0	0	0	0	0	0.00	0	AIRFLOWS		
Glass Solar	0	0	0	0	0	0	0	0	0	0.00	0	Cooling Heating		
Glass/Door Cond	0	0	0	0	0	0	0	0	0	0.00	0	Diffuser	153	153
Wall Cond	1,717	407	2,124	57	1,717	50	0	-1,554	-1,931	108.47	0	Terminal	153	153
Partition/Door	0	0	0	0	0	0	0	0	0	0.00	0	Main Fan	153	153
Floor	0	0	0	0	0.00	0	0	0	0	0.00	0	Sec Fan	0	0
Adjacent Floor	0.00	0.00	0.00	0.00	0.00	0.00	0	0.00	0.00	0.00	0	Nom Vent	0	0
Infiltration	0	0	0	0	0	0	0	0	0	0.00	0	AHU Vent	0	0
Sub Total ==>	1,717	407	2,124	57	1,717	50	0	-1,554	-1,931	108.47	0	Infil	0	0
Internal Loads					Internal Loads			Internal Loads				MinStop/Rh	0	0
Lights	717	0	717	19	717	21	0	0	0	0.00	0	Return	153	153
People	0	0	0	0	0	0	0	0	0	0.00	0	Exhaust	0	0
Misc	896	0	896	24	896	26	0	0	0	0.00	0	Rm Exh	0	0
Sub Total ==>	1,613	0	1,613	43	1,613	47	0	0	0	0.00	0	Auxiliary	0	0
Ceiling Load	74	-74	0	0	74	2	0	-37	0	0.00	0	Leakage Dwn	0	0
Ventilation Load	0	0	0	0	0	0	0	0	0	0.00	0	Leakage Ups	0	0
Adj Air Trans Heat	0	0	0	0	0	0	0	0	0	0	0	ENGINEERING CKS		
Dehumid. Ov Sizing	0	0	0	0	0	0	0	0	0	0.00	0	Cooling Heating		
Ov/Undr Sizing	0	0	0	0	0	0	0	0	0	0.00	0	% OA	0.0	0.0
Exhaust Heat	0	0	0	0	0	0	0	0	0	0.00	0	cfm/ft²	1.45	1.45
Sup. Fan Heat	0	0	0	0	0	0	0	0	0	0.00	0	cfm/ton	490.53	
Ret. Fan Heat	0	0	0	0	0	0	0	0	0	0.00	0	ft²/ton	337.21	
Duct Heat Pkup	0	0	0	0	0	0	0	0	0	0.00	0	Btu/hr-ft²	35.59	-16.95
Underflr Sup Ht Pkup	0	0	0	0	0	0	0	0	0	0.00	0	No. People	0.0	0.0/1000 ft²
Supply Air Leakage	0	0	0	0	0	0	0	0	0	0.00	0			
Grand Total ==>	3,404	332	3,737	100.00	3,404	100.00	0	-1,591	-1,780	100.00	0			

COOLING COIL SELECTION										AREAS			HEATING COIL SELECTION				
Total Capacity	Sens Cap.	Coil Airflow	Enter DB/WB/HR		Leave DB/WB/HR		Gross Total		Glass	CapacityCoil Airflow		Ent	Lvg				
ton MBh	MBh	cfm	°F °F	gr/lb	°F °F	gr/lb			ft² (%)	MBh	cfm	°F	°F				
Main Clg	0.3	3.7	3.7	153	77.2 57.8	40.5	55.0	48.6	40.5	Floor	105	-1.8	153	68.9	79.4		
Aux Clg	0.0	0.0	0.0	0	0.0 0.0	0.0	0.0	0.0	0.0	Part	0	0.0	0	0.0	0.0		
Opt Vent	0.0	0.0	0.0	0	0.0 0.0	0.0	0.0	0.0	0.0	Int Door	1	0.0	0	0.0	0.0		
										ExFlr	0	0	0	0.0	0.0		
										Roof	0	0	0	0.0	0.0		
										Wall	798	0	0	0.0	0.0		
										Ext Door	0	0	0	0.0	0.0		
Total	0.3	3.7										-1.8					

Room Checksums

By Go Green Engineering LLC

Office 107

COOLING COIL PEAK					CLG SPACE PEAK			HEATING COIL PEAK				TEMPERATURES		
Peaked at Time: Mo/Hr: 7 / 16					Mo/Hr: 6 / 17			Mo/Hr: Heating Design						
Outside Air: OADB/WB/HR: 94 / 77 / 117					OADB: 96			OADB: 32						
Space Sens. + Lat.	Plenum Sens. + Lat.	Net Total	Percent Of Total		Space Sensible	Percent Of Total		Space Peak	Coil Peak	Percent		Cooling	Heating	
Btu/h	Btu/h	Btu/h	(%)		Btu/h	(%)		Space Sens	Tot Sens	Of Total				
Btu/h	Btu/h	Btu/h	(%)		Btu/h	(%)		Btu/h	Btu/h	(%)				
Envelope Loads					Envelope Loads			Envelope Loads						
Skylite Solar	0	0	0	0	0	0	0	0	0	0.00	0	55.0	72.4	SADB
Skylite Cond	0	0	0	0	0	0	0	0	0	0.00	0	77.2	68.9	Ra Plenum
Roof Cond	0	547	547	14	0	0	0	0	-216	22.38	0	77.2	68.9	Return
Glass Solar	0	0	0	0	0	0	0	0	0	0.00	0	79.1	64.6	Ret/OA
Glass/Door Cond	0	0	0	0	0	0	0	0	0	0.00	0	0.0	0.0	Fn MtrTD
Wall Cond	205	48	253	6	234	9	0	-248	-308	31.95	0	0.0	0.0	Fn BldTD
Partition/Door	0	0	0	0	0	0	0	0	0	0.00	0	0.0	0.0	Fn Frict
Floor	0	0	0	0	0.00	0	0	0	0	0.00	0			
Adjacent Floor	0.00	0.00	0.00	0.00	0.00	0.00	0	0.00	0.00	0.00	0			
Infiltration	0	0	0	0	0	0	0	0	0	0.00	0			
Sub Total ==>	205	595	800	20	234	9	0	-248	-524	54.33	0			
Internal Loads					Internal Loads			Internal Loads						
Lights	853	0	853	21	853	34	0	0	0	0.00	0			
People	500	0	500	12	250	10	0	0	0	0.00	0			
Misc	1,067	0	1,067	27	1,067	43	0	0	0	0.00	0			
Sub Total ==>	2,420	0	2,420	60	2,170	87	0	0	0	0.00	0			
Ceiling Load					Ceiling Load			Ceiling Load						
Ventilation Load	88	-88	0	0	88	4	0	-44	0	0.00	0			
Adj Air Trans Heat	0	0	784	20	0	0	0	0	-550	57.04	0			
Dehumid. Ov Sizing	0	0	0	0	0	0	0	0	0	0.00	0			
Ov/Undr Sizing	0	0	0	0	0	0	0	0	0	0.00	0			
Exhaust Heat	0	0	0	0	0	0	0	0	0	0.00	0			
Sup. Fan Heat	0	0	0	0	0	0	0	0	0	0.00	0			
Ret. Fan Heat	0	0	0	0	0	0	0	0	0	0.00	0			
Duct Heat Pkup	0	0	0	0	0	0	0	0	0	0.00	0			
Underflr Sup Ht Pkup	0	0	0	0	0	0	0	0	0	0.00	0			
Supply Air Leakage	0	0	0	0	0	0	0	0	0	0.00	0			
Grand Total ==>	2,713	507	4,004	100.00	2,492	100.00	0	-292	-965	100.00	0			

AIRFLOWS		
	Cooling	Heating
Diffuser	112	112
Terminal	112	112
Main Fan	112	112
Sec Fan	0	0
Nom Vent	13	13
AHU Vent	13	13
Infil	0	0
MinStop/Rh	0	0
Return	99	99
Exhaust	0	0
Rm Exh	13	13
Auxiliary	0	0
Leakage Dwn	0	0
Leakage Ups	0	0

ENGINEERING CKS		
	Cooling	Heating
% OA	11.6	11.6
cfm/ft²	0.89	0.89
cfm/ton	335.08	
ft²/ton	374.66	
Btu/hr-ft²	32.03	-7.72
No. People	1.0	8.0/1000 ft²

COOLING COIL SELECTION										AREAS				HEATING COIL SELECTION					
	Total Capacity		Sens Cap.	Coil Airflow	Enter DB/WB/HR			Leave DB/WB/HR			Gross Total		Glass			Capacity	Coil Airflow	Ent	Lvg
	ton	MBh	MBh	cfm	°F	°F	gr/lb	°F	°F	gr/lb			ft²	(%)		MBh	cfm	°F	°F
Main Clg	0.3	4.0	3.2	112	79.1	64.4	66.9	55.0	52.3	54.2	Floor	125			Main Htg	-1.0	112	64.6	72.4
Aux Clg	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	Part	0			Aux Htg	0.0	0	0.0	0.0
Opt Vent	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	Int Door	1			Preheat	0.0	0	0.0	0.0
											ExFlr	0							
											Roof	125	0	0	Humidif	0.0	0	0.0	0.0
											Wall	128	0	0	Opt Vent	0.0	0	0.0	0.0
											Ext Door	0	0	0	Total	-1.0			
Total	0.3	4.0																	

Room Checksums

By Go Green Engineering LLC

Office 101

COOLING COIL PEAK					CLG SPACE PEAK			HEATING COIL PEAK				TEMPERATURES		
Peaked at Time: Mo/Hr: 8 / 17					Mo/Hr: 6 / 15			Mo/Hr: Heating Design				Cooling Heating		
Outside Air: OADB/WB/HR: 93 / 78 / 119					OADB: 97			OADB: 32				SADB	55.0	70.4
Space Sens. + Lat. Btu/h	Plenum Sens. + Lat. Btu/h	Net Total Btu/h	Percent Of Total (%)		Space Sensible Btu/h	Percent Of Total (%)		Space Peak Space Sens Btu/h	Coil Peak Tot Sens Btu/h	Percent Of Total (%)		Ra Plenum	77.0	68.9
Envelope Loads								Envelope Loads				Return	77.0	68.9
Skylite Solar	0	0	0	0	0	0	0	0	0	0.00	0.00	Ret/OA	78.2	66.0
Skylite Cond	0	0	0	0	0	0	0	0	0	0.00	0.00	Fn MtrTD	0.0	0.0
Roof Cond	0	0	0	0	0	0	0	0	0	0.00	0.00	Fn BldTD	0.0	0.0
Glass Solar	0	0	0	0	0	0	0	0	0	0.00	0.00	Fn Frict	0.0	0.0
Glass/Door Cond	0	0	0	0	0	0	0	0	0	0.00	0.00	AIRFLOWS		
Wall Cond	0	0	0	0	0	0	0	0	0	0.00	0.00	Cooling Heating		
Partition/Door	0	0	0	0	0	0	0	0	0	0.00	0.00	Diffuser	194	194
Floor	0	0	0	0	0.00	0	0	0	0	0.00	0.00	Terminal	194	194
Adjacent Floor	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Main Fan	194	194
Infiltration	0	0	0	0	0	0	0	0	0	0.00	0.00	Sec Fan	0	0
Sub Total ==>	0	0	0	0	0	0	0	0	0	0.00	0.00	Nom Vent	15	15
Internal Loads								Internal Loads				AHU Vent	15	15
Lights	1,727	0	1,727	32	1,727	40	0	0	0	0.00	0.00	Infil	0	0
People	500	0	500	9	250	6	0	0	0	0.00	0.00	MinStop/Rh	0	0
Misc	2,159	0	2,159	41	2,159	50	0	0	0	0.00	0.00	Return	179	179
Sub Total ==>	4,386	0	4,386	82	4,136	96	0	0	0	0.00	0.00	Exhaust	0	0
Ceiling Load	164	-164	0	0	187	4	0	-89	0	0.00	0.00	Rm Exh	15	15
Ventilation Load	0	0	938	18	0	0	0	0	-635	67.14	0.00	Auxiliary	0	0
Adj Air Trans Heat	0	0	0	0	0	0	0	0	0	0	0.00	Leakage Dwn	0	0
Dehumid. Ov Sizing	0	0	0	0	0	0	0	0	0	0.00	0.00	Leakage Ups	0	0
Ov/Undr Sizing	0	0	0	0	0	0	0	0	0	0.00	0.00	ENGINEERING CKS		
Exhaust Heat	0	0	0	0	0	0	0	0	0	0.00	0.00	Cooling Heating		
Sup. Fan Heat	0	0	0	0	0	0	0	0	0	0.00	0.00	% OA	7.7	7.7
Ret. Fan Heat	0	0	0	0	0	0	0	0	0	0.00	0.00	cfm/ft²	0.77	0.77
Duct Heat Pkup	0	0	0	0	0	0	0	0	0	0.00	0.00	cfm/ton	437.22	
Underflr Sup Ht Pkup	0	0	0	0	0	0	0	0	0	0.00	0.00	ft²/ton	570.33	
Supply Air Leakage	0	0	0	0	0	0	0	0	0	0.00	0.00	Btu/hr-ft²	21.04	-3.74
Grand Total ==>	4,550	-164	5,323	100.00	4,323	100.00	Grand Total ==>	-89	-946	100.00	No. People	1.0	4.0/1000 ft²	

COOLING COIL SELECTION										AREAS				HEATING COIL SELECTION					
	Total Capacity		Sens Cap.	Coil Airflow	Enter DB/WB/HR		Leave DB/WB/HR			Gross Total		Glass			Capacity	Coil Airflow	Ent	Lvg	
	ton	MBh	MBh	cfm	°F	°F	gr/lb	°F	°F	gr/lb			ft² (%)		MBh	cfm	°F	°F	
Main Clg	0.4	5.3	4.4	194	78.2	63.1	62.4	55.0	53.9	60.1	Floor	253		Main Htg	-1.0	194	66.0	70.4	
Aux Clg	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	Part	0		Aux Htg	0.0	0	0.0	0.0	
Opt Vent	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	Int Door	1		Preheat	0.0	0	0.0	0.0	
											ExFlr	0							
											Roof	0	0	0	Humidif	0.0	0	0.0	0.0
											Wall	0	0	0	Opt Vent	0.0	0	0.0	0.0
											Ext Door	0	0	0	Total	-1.0			
Total	0.4	5.3																	

Room Checksums

By Go Green Engineering LLC

Office 102

COOLING COIL PEAK					CLG SPACE PEAK			HEATING COIL PEAK				TEMPERATURES		
Peaked at Time: Mo/Hr: 7 / 18					Mo/Hr: 6 / 19			Mo/Hr: Heating Design						
Outside Air: OADB/WB/HR: 91 / 77 / 119					OADB: 91			OADB: 32						
Space Sens. + Lat.	Plenum Sens. + Lat.	Net Total	Percent Of Total		Space Sensible	Percent Of Total		Space Peak	Coil Peak	Percent			Cooling	Heating
Btu/h	Btu/h	Btu/h	(%)		Btu/h	(%)		Space Sens	Tot Sens	Of Total				
Envelope Loads					Envelope Loads			Envelope Loads						
Skylite Solar	0	0	0	0	0	0	0	Skylite Solar	0	0	0.00	SADB	55.0	71.5
Skylite Cond	0	0	0	0	0	0	0	Skylite Cond	0	0	0.00	Ra Plenum	76.9	68.9
Roof Cond	0	0	0	0	0	0	0	Roof Cond	0	0	0.00	Return	76.9	68.9
Glass Solar	0	0	0	0	0	0	0	Glass Solar	0	0	0.00	Ret/OA	77.9	66.4
Glass/Door Cond	0	0	0	0	0	0	0	Glass/Door Cond	0	0	0.00	Fn MtrTD	0.0	0.0
Wall Cond	519	126	645	11	586	12	0	Wall Cond	-274	-341	27.20	Fn BldTD	0.0	0.0
Partition/Door	0	0	0	0	0	0	0	Partition/Door	0	0	0.00	Fn Frict	0.0	0.0
Floor	0	0	0	0	0.00	0	0	Floor	0	0	0.00			
Adjacent Floor	0.00	0.00	0.00	0.00	0.00	0.00	0	Adjacent Floor	0.00	0.00	0.00			
Infiltration	0	0	0	0	0	0	0	Infiltration	0	0	0.00			
Sub Total ==>	519	126	645	11	586	12	0	Sub Total ==>	-274	-341	27.20			
Internal Loads					Internal Loads			Internal Loads						
Lights	1,747	0	1,747	29	1,747	36	0	Lights	0	0	0.00			
People	500	0	500	8	250	5	0	People	0	0	0.00			
Misc	2,184	0	2,184	36	2,184	45	0	Misc	0	0	0.00			
Sub Total ==>	4,432	0	4,432	74	4,182	85	0	Sub Total ==>	0	0	0.00			
Ceiling Load					Ceiling Load			Ceiling Load						
Ventilation Load	0	0	914	15	0	0	0	Ventilation Load	0	-635	50.65			
Adj Air Trans Heat	0	0	0	0	0	0	0	Adj Air Trans Heat	0	0	0			
Dehumid. Ov Sizing	0	0	0	0	0	0	0	Ov/Undr Sizing	0	0	0.00			
Ov/Undr Sizing	0	0	0	0	0	0	0	Exhaust Heat	0	0	0.00			
Exhaust Heat	0	0	0	0	0	0	0	OA Preheat Diff.	0	0	0.00			
Sup. Fan Heat	0	0	0	0	0	0	0	RA Preheat Diff.	0	0	0.00			
Ret. Fan Heat	0	0	0	0	0	0	0	Additional Reheat	0	0	0.00			
Duct Heat Pkup	0	0	0	0	0	0	0	System Plenum Heat	-278	22.15				
Underflr Sup Ht Pkup	0	0	0	0	0	0	0	Underflr Sup Ht Pkup	0	0	0.00			
Supply Air Leakage	0	0	0	0	0	0	0	Supply Air Leakage	0	0	0.00			
Grand Total ==>	5,105	-28	5,991	100.00	4,905	100.00	0	Grand Total ==>	-365	-1,254	100.00			

AIRFLOWS		
	Cooling	Heating
Diffuser	220	220
Terminal	220	220
Main Fan	220	220
Sec Fan	0	0
Nom Vent	15	15
AHU Vent	15	15
Infil	0	0
MinStop/Rh	0	0
Return	205	205
Exhaust	0	0
Rm Exh	15	15
Auxiliary	0	0
Leakage Dwn	0	0
Leakage Ups	0	0

ENGINEERING CKS		
	Cooling	Heating
% OA	6.8	6.8
cfm/ft²	0.86	0.86
cfm/ton	440.84	
ft²/ton	512.74	
Btu/hr-ft²	23.40	-4.90
No. People	1.0	3.9/1000 ft²

COOLING COIL SELECTION										AREAS			HEATING COIL SELECTION				
	Total Capacity	Sens Cap.	Coil Airflow	Enter DB/WB/HR		Leave DB/WB/HR				Gross Total	Glass		Capacity	Coil Airflow	Ent	Lvg	
	ton	MBh	MBh	cfm	°F °F	gr/lb	°F °F	gr/lb			ft²	(%)	MBh	cfm	°F	°F	
Main Clg	0.5	6.0	5.1	220	77.9 62.8	61.3	55.0 53.5	58.8		Floor	256		Main Htg	-1.3	220	66.4	71.5
Aux Clg	0.0	0.0	0.0	0	0.0 0.0	0.0	0.0 0.0	0.0		Part	0		Aux Htg	0.0	0	0.0	0.0
Opt Vent	0.0	0.0	0.0	0	0.0 0.0	0.0	0.0 0.0	0.0		Int Door	1		Preheat	0.0	0	0.0	0.0
										ExFlr	0						
Total	0.5	6.0								Roof	0	0 0	Humidif	0.0	0	0.0	0.0
										Wall	141	0 0	Opt Vent	0.0	0	0.0	0.0
										Ext Door	0	0 0	Total	-1.3			

Room Checksums

By Go Green Engineering LLC

Office 103

COOLING COIL PEAK					CLG SPACE PEAK					HEATING COIL PEAK					TEMPERATURES		
Peaked at Time: Mo/Hr: 7 / 18					Mo/Hr: 6 / 19					Mo/Hr: Heating Design							
Outside Air: OADB/WB/HR: 91 / 77 / 119					OADB: 91					OADB: 32							
Space Sens. + Lat.	Plenum Sens. + Lat.	Net Total	Percent Of Total		Space Sensible	Percent Of Total				Space Peak	Coil Peak	Percent					
Btu/h	Btu/h	Btu/h	(%)		Btu/h	(%)				Space Sens	Tot Sens	Of Total	(%)				
Envelope Loads					Envelope Loads					Envelope Loads							
Skylite Solar	0	0	0	0	0	0	0	0	0	0	0	0.00	0.00	0.00			
Skylite Cond	0	0	0	0	0	0	0	0	0	0	0	0.00	0.00	0.00			
Roof Cond	0	740	740	12	0	0	0	0	0	0	-354	24.76	0.00	0.00			
Glass Solar	0	0	0	0	0	0	0	0	0	0	0	0.00	0.00	0.00			
Glass/Door Cond	0	0	0	0	0	0	0	0	0	0	0	0.00	0.00	0.00			
Wall Cond	785	191	976	15	886	20	0	0	0	-415	-516	36.06	0.00	0.00			
Partition/Door	0	0	0	0	0	0	0	0	0	0	0	0.00	0.00	0.00			
Floor	0	0	0	0	0.00	0	0	0	0	0	0	0.00	0.00	0.00			
Adjacent Floor	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			
Infiltration	0	0	0	0	0	0	0	0	0	0	0	0.00	0.00	0.00			
Sub Total ==>	785	931	1,716	27	886	20	0	0	0	-415	-870	60.82	0.00	0.00			
Internal Loads					Internal Loads					Internal Loads							
Lights	1,399	0	1,399	22	1,399	32	0	0	0	0	0	0.00	0.00	0.00			
People	500	0	500	8	250	6	0	0	0	0	0	0.00	0.00	0.00			
Misc	1,749	0	1,749	27	1,749	40	0	0	0	0	0	0.00	0.00	0.00			
Sub Total ==>	3,648	0	3,648	57	3,398	77	0	0	0	0	0	0.00	0.00	0.00			
Ceiling Load	124	-124	0	0	111	3	0	0	0	-72	0	0.00	0.00	0.00			
Ventilation Load	0	0	1,028	16	0	0	0	0	0	0	-720	50.32	0.00	0.00			
Adj Air Trans Heat	0	0	0	0	0	0	0	0	0	0	0	0	0.00	0.00			
Dehumid. Ov Sizing	0	0	0	0	0	0	0	0	0	0	0	0.00	0.00	0.00			
Ov/Undr Sizing	0	0	0	0	0	0	0	0	0	0	0	0.00	0.00	0.00			
Exhaust Heat	0	0	0	0	0	0	0	0	0	0	0	0.00	0.00	0.00			
Sup. Fan Heat	0	0	0	0	0	0	0	0	0	0	0	0.00	0.00	0.00			
Ret. Fan Heat	0	0	0	0	0	0	0	0	0	0	0	0.00	0.00	0.00			
Duct Heat Pkup	0	0	0	0	0	0	0	0	0	0	0	0.00	0.00	0.00			
Underflr Sup Ht Pkup	0	0	0	0	0	0	0	0	0	0	0	0.00	0.00	0.00			
Supply Air Leakage	0	0	0	0	0	0	0	0	0	0	0	0.00	0.00	0.00			
Grand Total ==>	4,557	807	6,392	100.00	4,395	100.00	0	0	0	-487	-1,431	100.00	0.00	0.00			

	Cooling	Heating
SADB	55.0	72.2
Ra Plenum	76.9	68.9
Return	76.9	68.9
Ret/OA	78.1	65.7
Fn MtrTD	0.0	0.0
Fn BldTD	0.0	0.0
Fn Frict	0.0	0.0

AIRFLOWS		
	Cooling	Heating
Diffuser	197	197
Terminal	197	197
Main Fan	197	197
Sec Fan	0	0
Nom Vent	17	17
AHU Vent	17	17
Infil	0	0
MinStop/Rh	0	0
Return	180	180
Exhaust	0	0
Rm Exh	17	17
Auxiliary	0	0
Leakage Dwn	0	0
Leakage Ups	0	0

ENGINEERING CKS		
	Cooling	Heating
% OA	8.6	8.6
cfm/ft²	0.96	0.96
cfm/ton	370.18	
ft²/ton	384.83	
Btu/hr-ft²	31.18	-6.98
No. People	1.0	4.9/1000 ft²

COOLING COIL SELECTION										AREAS				HEATING COIL SELECTION					
	Total Capacity		Sens Cap.	Coil Airflow	Enter DB/WB/HR			Leave DB/WB/HR			Gross Total		Glass		Capacity	Coil Airflow	Ent	Lvg	
	ton	MBh	MBh	cfm	°F	°F	gr/lb	°F	°F	gr/lb			ft²	(%)	MBh	cfm	°F	°F	
Main Clg	0.5	6.4	5.4	197	78.1	63.2	63.1	55.0	52.2	53.6	Floor	205			Main Htg	-1.4	197	65.7	72.2
Aux Clg	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	Part	0			Aux Htg	0.0	0	0.0	0.0
Opt Vent	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	Int Door	1			Preheat	0.0	0	0.0	0.0
											ExFlr	0							
Total	0.5	6.4									Roof	205	0	0	Humidif	0.0	0	0.0	0.0
											Wall	213	0	0	Opt Vent	0.0	0	0.0	0.0
											Ext Door	0	0	0	Total	-1.4			

Room Checksums

By Go Green Engineering LLC

Office 104

COOLING COIL PEAK					CLG SPACE PEAK					HEATING COIL PEAK					TEMPERATURES		
Peaked at Time: Mo/Hr: 7 / 16					Mo/Hr: 6 / 15					Mo/Hr: Heating Design							
Outside Air: OADB/WB/HR: 94 / 77 / 117					OADB: 97					OADB: 32							
Space Sens. + Lat. Btu/h	Plenum Sens. + Lat. Btu/h	Net Total Btu/h	Percent Of Total (%)		Space Sensible Btu/h	Percent Of Total (%)				Space Peak Space Sens Btu/h	Coil Peak Tot Sens Btu/h	Percent Of Total (%)			Cooling	Heating	
Envelope Loads					Envelope Loads					Envelope Loads							
Skylite Solar	0	0	0	0	0	0	0	0	0	0	0	0.00	0	0.00	SADB	55.0	70.4
Skylite Cond	0	0	0	0	0	0	0	0	0	0	0	0.00	0	0.00	Ra Plenum	77.2	68.9
Roof Cond	0	657	657	15	0	0	0	0	0	0	-259	33.38	0	0.00	Return	77.2	68.9
Glass Solar	0	0	0	0	0	0	0	0	0	0	0	0.00	0	0.00	Ret/OA	79.1	64.6
Glass/Door Cond	0	0	0	0	0	0	0	0	0	0	0	0.00	0	0.00	Fn MtrTD	0.0	0.0
Wall Cond	0	0	0	0	0	0	0	0	0	0	0	0.00	0	0.00	Fn BldTD	0.0	0.0
Partition/Door	0	0	0	0	0	0	0	0	0	0	0	0.00	0	0.00	Fn Frict	0.0	0.0
Floor	0	0	0	0	0.00	0	0	0	0	0	0	0.00	0	0.00			
Adjacent Floor	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			
Infiltration	0	0	0	0	0	0	0	0	0	0	0	0.00	0	0.00			
Sub Total ==>	0	657	657	15	0	0	0	0	0	0	-259	33.38	0	0.00			
Internal Loads					Internal Loads					Internal Loads							
Lights	1,024	0	1,024	24	1,024	38	0	0	0	0	0	0.00	0	0.00			
People	500	0	500	12	250	9	0	0	0	0	0	0.00	0	0.00			
Misc	1,280	0	1,280	30	1,280	48	0	0	0	0	0	0.00	0	0.00			
Sub Total ==>	2,804	0	2,804	65	2,554	96	0	0	0	0	0	0.00	0	0.00			
Ceiling Load	106	-106	0	0	111	4	0	0	0	-53	0	0.00	0	0.00			
Ventilation Load	0	0	847	20	0	0	0	0	0	0	-593	76.35	0	0.00			
Adj Air Trans Heat	0	0	0	0	0	0	0	0	0	0	0	0	0	0.00			
Dehumid. Ov Sizing	0	0	0	0	0	0	0	0	0	0	0	0.00	0	0.00			
Ov/Undr Sizing	0	0	0	0	0	0	0	0	0	0	0	0.00	0	0.00			
Exhaust Heat	0	0	0	0	0	0	0	0	0	0	0	0.00	0	0.00			
Sup. Fan Heat	0	0	0	0	0	0	0	0	0	0	0	0.00	0	0.00			
Ret. Fan Heat	0	0	0	0	0	0	0	0	0	0	0	0.00	0	0.00			
Duct Heat Pkup	0	0	0	0	0	0	0	0	0	0	0	0.00	0	0.00			
Underflr Sup Ht Pkup	0	0	0	0	0	0	0	0	0	0	0	0.00	0	0.00			
Supply Air Leakage	0	0	0	0	0	0	0	0	0	0	0	0.00	0	0.00			
Grand Total ==>	2,910	551	4,307	100.00	2,665	100.00	0	0	0	-53	-777	100.00	0	0.00			

	Cooling	Heating
SADB	55.0	70.4
Ra Plenum	77.2	68.9
Return	77.2	68.9
Ret/OA	79.1	64.6
Fn MtrTD	0.0	0.0
Fn BldTD	0.0	0.0
Fn Frict	0.0	0.0

AIRFLOWS		
	Cooling	Heating
Diffuser	120	120
Terminal	120	120
Main Fan	120	120
Sec Fan	0	0
Nom Vent	14	14
AHU Vent	14	14
Infil	0	0
MinStop/Rh	0	0
Return	106	106
Exhaust	0	0
Rm Exh	14	14
Auxiliary	0	0
Leakage Dwn	0	0
Leakage Ups	0	0

ENGINEERING CKS		
	Cooling	Heating
% OA	11.7	11.7
cfm/ft²	0.80	0.80
cfm/ton	333.08	
ft²/ton	417.89	
Btu/hr-ft²	28.72	-5.18
No. People	1.0	6.7/1000 ft²

COOLING COIL SELECTION										AREAS				HEATING COIL SELECTION					
	Total Capacity		Sens Cap.	Coil Airflow	Enter DB/WB/HR			Leave DB/WB/HR			Gross Total		Glass			Capacity	Coil Airflow	Ent	Lvg
	ton	MBh	MBh	cfm	°F	°F	gr/lb	°F	°F	gr/lb			ft²	(%)		MBh	cfm	°F	°F
Main Clg	0.4	4.3	3.5	120	79.1	64.3	66.7	55.0	52.2	53.7	Floor	150			Main Htg	-0.8	120	64.6	70.4
Aux Clg	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	Part	0			Aux Htg	0.0	0	0.0	0.0
Opt Vent	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	Int Door	1			Preheat	0.0	0	0.0	0.0
											ExFlr	0							
Total	0.4	4.3									Roof	150	0	0	Humidif	0.0	0	0.0	0.0
											Wall	0	0	0	Opt Vent	0.0	0	0.0	0.0
											Ext Door	0	0	0	Total	-0.8			

Room Checksums

By Go Green Engineering LLC

Office 105

COOLING COIL PEAK					CLG SPACE PEAK			HEATING COIL PEAK				TEMPERATURES		
Peaked at Time: Mo/Hr: 6 / 17					Mo/Hr: 6 / 19			Mo/Hr: Heating Design						
Outside Air: OADB/WB/HR: 96 / 76 / 104					OADB: 91			OADB: 32						
Space Sens. + Lat.	Plenum Sens. + Lat.	Net Total	Percent Of Total		Space Sensible	Percent Of Total		Space Peak	Coil Peak	Percent		Cooling	Heating	
Btu/h	Btu/h	Btu/h	(%)		Btu/h	(%)		Space Sens	Tot Sens	Of Total				
Btu/h	Btu/h	Btu/h	(%)		Btu/h	(%)		Btu/h	Btu/h	(%)				
Envelope Loads								Envelope Loads						
Skylite Solar	0	0	0	0	0	0	0	Skylite Solar	0	0	0.00	SADB	55.0	73.3
Skylite Cond	0	0	0	0	0	0	0	Skylite Cond	0	0	0.00	Ra Plenum	77.2	68.9
Roof Cond	0	587	587	13	0	0	0	Roof Cond	0	-237	19.35	Return	77.2	68.9
Glass Solar	0	0	0	0	0	0	0	Glass Solar	0	0	0.00	Ret/OA	78.9	65.5
Glass/Door Cond	0	0	0	0	0	0	0	Glass/Door Cond	0	0	0.00	Fn MtrTD	0.0	0.0
Wall Cond	583	139	722	16	689	22	0	Wall Cond	-467	-581	47.46	Fn BldTD	0.0	0.0
Partition/Door	0	0	0	0	0	0	0	Partition/Door	0	0	0.00	Fn Frict	0.0	0.0
Floor	0	0	0	0	0.00	0	0	Floor	0	0	0.00			
Adjacent Floor	0.00	0.00	0.00	0.00	0.00	0.00	0	Adjacent Floor	0.00	0.00	0.00			
Infiltration	0	0	0	0	0	0	0	Infiltration	0	0	0.00			
Sub Total ==>	583	726	1,309	28	689	22	0	Sub Total ==>	-467	-817	66.81			
Internal Loads								Internal Loads						
Lights	935	0	935	20	935	30	0	Lights	0	0	0.00	AIRFLOWS		
People	500	0	500	11	250	8	0	People	0	0	0.00	Cooling	Heating	
Misc	1,169	0	1,169	25	1,169	38	0	Misc	0	0	0.00	Diffuser	140	140
Sub Total ==>	2,604	0	2,604	56	2,354	76	0	Sub Total ==>	0	0	0.00	Terminal	140	140
												Main Fan	140	140
Ceiling Load	96	-96	0	0	74	2	0	Ceiling Load	-48	0	0.00	Sec Fan	0	0
Ventilation Load	0	0	709	15	0	0	0	Ventilation Load	0	-550	45.01	Nom Vent	13	13
Adj Air Trans Heat	0	0	0	0	0	0	0	Adj Air Trans Heat	0	0	0	AHU Vent	13	13
Dehumid. Ov Sizing	0	0	0	0	0	0	0	Ov/Undr Sizing	0	0	0.00	Infil	0	0
Ov/Undr Sizing	0	0	0	0	0	0	0	Exhaust Heat	0	0	0.00	MinStop/Rh	0	0
Exhaust Heat	0	0	0	0	0	0	0	OA Preheat Diff.	0	0	0.00	Return	127	127
Sup. Fan Heat	0	0	0	0	0	0	0	RA Preheat Diff.	0	0	0.00	Exhaust	0	0
Ret. Fan Heat	0	0	0	0	0	0	0	Additional Reheat	0	0	0.00	Rm Exh	13	13
Duct Heat Pkup	0	0	0	0	0	0	0	System Plenum Heat	145	-11.82		Auxiliary	0	0
Underflr Sup Ht Pkup	0	0	0	0	0	0	0	Underflr Sup Ht Pkup	0	0	0.00	Leakage Dwn	0	0
Supply Air Leakage	0	0	0	0	0	0	0	Supply Air Leakage	0	0	0.00	Leakage Ups	0	0
Grand Total ==>	3,284	630	4,622	100.00	3,117	100.00	0	Grand Total ==>	-515	-1,223	100.00	ENGINEERING CKS		

COOLING COIL SELECTION										AREAS			HEATING COIL SELECTION				
Total Capacity	Sens Cap.	Coil Airflow	Enter DB/WB/HR	Leave DB/WB/HR						Gross Total	Glass		Capacity	Coil Airflow	Ent	Lvg	
ton MBh	MBh	cfm	°F °F gr/lb	°F °F gr/lb							ft² (%)		MBh	cfm	°F	°F	
Main Clg	0.4	4.6	4.0	140	78.9	63.5	63.3	55.0	52.3	54.1			Main Htg	-1.2	140	65.5	73.3
Aux Clg	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0			Aux Htg	0.0	0	0.0	0.0
Opt Vent	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0			Preheat	0.0	0	0.0	0.0
Total	0.4	4.6											Humidif	0.0	0	0.0	0.0
													Opt Vent	0.0	0	0.0	0.0
													Total	-1.2			

Room Checksums

By Go Green Engineering LLC

Office 106

COOLING COIL PEAK					CLG SPACE PEAK			HEATING COIL PEAK				TEMPERATURES		
Peaked at Time: Mo/Hr: 7 / 16					Mo/Hr: 6 / 18			Mo/Hr: Heating Design						
Outside Air: OADB/WB/HR: 94 / 77 / 117					OADB: 93			OADB: 32						
Space Sens. + Lat.	Plenum Sens. + Lat	Net Total	Percent Of Total		Space Sensible	Percent Of Total		Space Peak	Coil Peak	Percent		Cooling	Heating	
Btu/h	Btu/h	Btu/h	(%)		Btu/h	(%)		Space Sens	Tot Sens	Of Total				
Btu/h	Btu/h	Btu/h	(%)		Btu/h	(%)		Btu/h	Btu/h	(%)				
Envelope Loads					Envelope Loads			Envelope Loads						
Skylite Solar	0	0	0	0	0	0	0	0	0	0.00	0	SADB	55.0	72.4
Skylite Cond	0	0	0	0	0	0	0	0	0	0.00	0	Ra Plenum	77.2	68.9
Roof Cond	0	469	469	13	0	0	0	0	-185	22.28	0	Return	77.2	68.9
Glass Solar	0	0	0	0	0	0	0	0	0	0.00	0	Ret/OA	79.1	64.7
Glass/Door Cond	0	0	0	0	0	0	0	0	0	0.00	0	Fn MtrTD	0.0	0.0
Wall Cond	181	42	223	6	213	10	0	-219	-272	32.79	0	Fn BldTD	0.0	0.0
Partition/Door	0	0	0	0	0	0	0	0	0	0.00	0	Fn Frict	0.0	0.0
Floor	0	0	0	0	0.00	0	0	0	0	0.00	0			
Adjacent Floor	0.00	0.00	0.00	0.00	0.00	0.00	0	0.00	0.00	0.00	0			
Infiltration	0	0	0	0	0	0	0	0	0	0.00	0			
Sub Total ==>	181	511	692	20	213	10	0	-219	-457	55.07	0			
Internal Loads					Internal Loads			Internal Loads						
Lights	730	0	730	21	730	34	0	0	0	0.00	0			
People	500	0	500	14	250	11	0	0	0	0.00	0			
Misc	913	0	913	26	913	42	0	0	0	0.00	0			
Sub Total ==>	2,143	0	2,143	61	1,893	87	0	0	0	0.00	0			
Ceiling Load					Ceiling Load			Ceiling Load						
Ventilation Load	75	-75	0	0	68	3	0	-38	0	0.00	0			
Adj Air Trans Heat	0	0	659	19	0	0	0	0	-466	56.14	0			
Dehumid. Ov Sizing	0	0	0	0	0	0	0	0	0	0.00	0			
Ov/Undr Sizing	0	0	0	0	0	0	0	0	0	0.00	0			
Exhaust Heat	0	0	0	0	0	0	0	0	0	0.00	0			
Sup. Fan Heat	0	0	0	0	0	0	0	0	0	0.00	0			
Ret. Fan Heat	0	0	0	0	0	0	0	0	0	0.00	0			
Duct Heat Pkup	0	0	0	0	0	0	0	0	0	0.00	0			
Underflr Sup Ht Pkup	0	0	0	0	0	0	0	0	0	0.00	0			
Supply Air Leakage	0	0	0	0	0	0	0	0	0	0.00	0			
Grand Total ==>	2,400	435	3,494	100.00	2,175	100.00	0	-257	-830	100.00	0			

COOLING COIL SELECTION										AREAS			HEATING COIL SELECTION				
Total Capacity	Sens Cap.	Coil Airflow	Enter DB/WB/HR	Leave DB/WB/HR						Gross Total	Glass		Capacity	Coil Airflow	Ent	Lvg	
ton	MBh	MBh	°F °F gr/lb	°F °F gr/lb							ft² (%)		MBh	cfm	°F	°F	
Main Clg	0.3	3.5	2.8	98	79.1	64.4	67.1	55.0	52.4	54.4			Main Htg	-0.8	98	64.7	72.4
Aux Clg	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0			Aux Htg	0.0	0	0.0	0.0
Opt Vent	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0			Preheat	0.0	0	0.0	0.0
Total	0.3	3.5											Humidif	0.0	0	0.0	0.0
													Opt Vent	0.0	0	0.0	0.0
													Total	-0.8			

Room Checksums

By Go Green Engineering LLC

Office 108

COOLING COIL PEAK					CLG SPACE PEAK			HEATING COIL PEAK				TEMPERATURES		
Peaked at Time: Mo/Hr: 7 / 16					Mo/Hr: 6 / 15			Mo/Hr: Heating Design						
Outside Air: OADB/WB/HR: 94 / 77 / 117					OADB: 97			OADB: 32						
Space Sens. + Lat.	Plenum Sens. + Lat.	Net Total	Percent Of Total		Space Sensible	Percent Of Total		Space Peak	Coil Peak	Percent		Cooling	Heating	
Btu/h	Btu/h	Btu/h	(%)		Btu/h	(%)		Space Sens	Tot Sens	Of Total				
Envelope Loads					Envelope Loads			Envelope Loads						
Skylite Solar	0	0	0	0	0	0	0	0	0	0.00	0	55.0	70.4	SADB
Skylite Cond	0	0	0	0	0	0	0	0	0	0.00	0	77.2	68.9	Ra Plenum
Roof Cond	0	876	876	16	0	0	0	0	-346	35.91	0	77.2	68.9	Return
Glass Solar	0	0	0	0	0	0	0	0	0	0.00	0	79.0	64.9	Ret/OA
Glass/Door Cond	0	0	0	0	0	0	0	0	0	0.00	0	0.0	0.0	Fn MtrTD
Wall Cond	0	0	0	0	0	0	0	0	0	0.00	0	0.0	0.0	Fn BldTD
Partition/Door	0	0	0	0	0	0	0	0	0	0.00	0	0.0	0.0	Fn Frict
Floor	0	0	0	0	0.00	0	0	0	0	0.00	0			
Adjacent Floor	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			
Infiltration	0	0	0	0	0	0	0	0	0	0.00	0			
Sub Total ==>	0	876	876	16	0	0	0	0	-346	35.91	0			
Internal Loads					Internal Loads			Internal Loads						
Lights	1,365	0	1,365	25	1,365	39	0	0	0	0.00	0			
People	500	0	500	9	250	7	0	0	0	0.00	0			
Misc	1,707	0	1,707	31	1,707	49	0	0	0	0.00	0			
Sub Total ==>	3,572	0	3,572	65	3,322	96	0	0	0	0.00	0			
Ceiling Load	141	-141	0	0	148	4	0	-70	0	0.00	0			
Ventilation Load	0	0	1,040	19	0	0	0	0	-720	74.82	0			
Adj Air Trans Heat	0		0	0	0	0	0	0	0	0	0			
Dehumid. Ov Sizing			0	0			0	0	0	0.00	0			
Ov/Undr Sizing	0		0	0	0	0	0	0	0	0.00	0			
Exhaust Heat		0	0	0			0	0	0	0.00	0			
Sup. Fan Heat			0	0			0	0	0	0.00	0			
Ret. Fan Heat		0	0	0			0	0	0	0.00	0			
Duct Heat Pkup		0	0	0			0	0	0	0.00	0			
Underflr Sup Ht Pkup			0	0			0	0	0	0.00	0			
Supply Air Leakage		0	0	0			0	0	0	0.00	0			
Grand Total ==>	3,713	735	5,488	100.00	3,469	100.00	Grand Total ==>	-70	-962	100.00				

AIRFLOWS			Cooling	Heating
Diffuser	156	156		
Terminal	156	156		
Main Fan	156	156		
Sec Fan	0	0		
Nom Vent	17	17		
AHU Vent	17	17		
Infil	0	0		
MinStop/Rh	0	0		
Return	139	139		
Exhaust	0	0		
Rm Exh	17	17		
Auxiliary	0	0		
Leakage Dwn	0	0		
Leakage Ups	0	0		

ENGINEERING CKS			Cooling	Heating
% OA	10.9	10.9		
cfm/ft²	0.78	0.78		
cfm/ton	340.41			
ft²/ton	437.34			
Btu/hr-ft²	27.44	-4.81		
No. People	1.0	5.0/1000 ft²		

COOLING COIL SELECTION										AREAS			HEATING COIL SELECTION				
Total Capacity	Sens Cap.	Coil Airflow	Enter DB/WB/HR		Leave DB/WB/HR		Gross Total		Glass	Capacity		Coil Airflow	Ent	Lvg			
ton	MBh	MBh	°F	°F	°F	°F	ft²	(%)	ft²	MBh	MBh	cfm	°F	°F			
Main Clg	0.5	5.5	4.6	156	79.0	64.0	65.3	55.0	52.1	53.3							
Aux Clg	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0							
Opt Vent	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0							
Total	0.5	5.5															

Floor	200																
Part	0																
Int Door	1																
ExFlr	0																
Roof	200	0	0														
Wall	0	0	0														
Ext Door	0	0	0														

Main Htg	-1.0	156	64.9	70.4													
Aux Htg	0.0	0	0.0	0.0													
Preheat	0.0	0	0.0	0.0													
Humidif	0.0	0	0.0	0.0													
Opt Vent	0.0	0	0.0	0.0													
Total	-1.0																

Room Checksums

By Go Green Engineering LLC

Office 109

COOLING COIL PEAK					CLG SPACE PEAK			HEATING COIL PEAK				TEMPERATURES		
Peaked at Time: Mo/Hr: 7 / 16					Mo/Hr: 6 / 15			Mo/Hr: Heating Design				Cooling Heating		
Outside Air: OADB/WB/HR: 94 / 77 / 117					OADB: 97			OADB: 32				SADB 55.0 70.4		
Space		Plenum	Net	Percent	Space		Coil Peak		Percent		Ra Plenum 77.2 68.9			
Sens. + Lat.		Sens. + Lat	Total	Of Total	Sensible Of Total		Space Sens Tot Sens Of Total				Return 77.2 68.9			
Btu/h		Btu/h	Btu/h	(%)	Btu/h (%)		Btu/h (%)				Ret/OA 79.2 64.5			
Envelope Loads					Envelope Loads					Fn MtrTD 0.0 0.0				
Skylite Solar	0	0	0	0	0	0	Skylite Solar	0	0	0.00	Fn BldTD 0.0 0.0			
Skylite Cond	0	0	0	0	0	0	Skylite Cond	0	0	0.00	Fn Frict 0.0 0.0			
Roof Cond	0	596	596	15	0	0	Roof Cond	0	-235	32.73				
Glass Solar	0	0	0	0	0	0	Glass Solar	0	0	0.00				
Glass/Door Cond	0	0	0	0	0	0	Glass/Door Cond	0	0	0.00				
Wall Cond	0	0	0	0	0	0	Wall Cond	0	0	0.00				
Partition/Door	0		0	0	0	0	Partition/Door	0	0	0.00				
Floor	0		0	0	0.00	0	Floor	0	0	0.00				
Adjacent Floor	0.00	0.00	0.00	0.00	0.00	0.00	Adjacent Floor	0.00	0.00	0.00				
Infiltration	0		0	0	0	0	Infiltration	0	0	0.00				
Sub Total ==>	0	596	596	15	0	0	Sub Total ==>	0	-235	32.73				
Internal Loads					Internal Loads									
Lights	928	0	928	23	928	38	Lights	0	0	0.00				
People	500	0	500	13	250	10	People	0	0	0.00				
Misc	1,160	0	1,160	29	1,160	48	Misc	0	0	0.00				
Sub Total ==>	2,589	0	2,589	65	2,339	96	Sub Total ==>	0	0	0.00				
Ceiling Load	96	-96	0	0	100	4	Ceiling Load	-48	0	0.00				
Ventilation Load	0	0	783	20	0	0	Ventilation Load	0	-550	76.68				
Adj Air Trans Heat	0		0	0	0	0	Adj Air Trans Heat	0	0	0				
Dehumid. Ov Sizing			0	0			Ov/Undr Sizing	0	0	0.00				
Ov/Undr Sizing	0		0	0	0	0	Exhaust Heat	0	0	0.00				
Exhaust Heat		0	0	0			OA Preheat Diff.	0	0	0.00				
Sup. Fan Heat			0	0			RA Preheat Diff.	0	0	0.00				
Ret. Fan Heat		0	0	0			Additional Reheat	0	0	0.00				
Duct Heat Pkup		0	0	0			System Plenum Heat	68	-9.41					
Underflr Sup Ht Pkup			0	0			Underflr Sup Ht Pkup	0	0	0.00				
Supply Air Leakage		0	0	0			Supply Air Leakage	0	0	0.00				
Grand Total ==>	2,685	500	3,967	100.00	2,439	100.00	Grand Total ==>	-48	-718	100.00				

AIRFLOWS		
	Cooling	Heating
Diffuser	109	109
Terminal	109	109
Main Fan	109	109
Sec Fan	0	0
Nom Vent	13	13
AHU Vent	13	13
Infil	0	0
MinStop/Rh	0	0
Return	96	96
Exhaust	0	0
Rm Exh	13	13
Auxiliary	0	0
Leakage Dwn	0	0
Leakage Ups	0	0

ENGINEERING CKS		
	Cooling	Heating
% OA	11.9	11.9
cfm/ft²	0.80	0.80
cfm/ton	331.05	
ft²/ton	411.37	
Btu/hr·ft²	29.17	-5.28
No. People	1.0	7.4/1000 ft²

COOLING COIL SELECTION										AREAS			HEATING COIL SELECTION				
Total Capacity	Sens Cap.	Coil Airflow	Enter DB/WB/HR		Leave DB/WB/HR					Gross Total	Glass		Capacity	Coil Airflow	Ent	Lvg	
ton	MBh	MBh	cfm	°F °F	gr/lb	°F °F	gr/lb	°F °F	gr/lb		ft² (%)		MBh	cfm	°F	°F	
Main Clg	0.3	4.0	3.2	109	79.2 64.4	67.1	55.0 52.2	53.9		Floor	136		Main Htg	-0.7	109	64.5	70.4
Aux Clg	0.0	0.0	0.0	0	0.0 0.0	0.0	0.0 0.0	0.0		Part	0		Aux Htg	0.0	0	0.0	0.0
Opt Vent	0.0	0.0	0.0	0	0.0 0.0	0.0	0.0 0.0	0.0		Int Door	1		Preheat	0.0	0	0.0	0.0
										ExFlr	0						
Total	0.3	4.0								Roof	136	0 0	Humidif	0.0	0	0.0	0.0
										Wall	0	0 0	Opt Vent	0.0	0	0.0	0.0
										Ext Door	0	0 0	Total	-0.7			

Room Checksums

By Go Green Engineering LLC

Office 110

COOLING COIL PEAK					CLG SPACE PEAK			HEATING COIL PEAK				TEMPERATURES		
Peaked at Time: Mo/Hr: 7 / 16					Mo/Hr: 6 / 17			Mo/Hr: Heating Design						
Outside Air: OADB/WB/HR: 94 / 77 / 117					OADB: 96			OADB: 32						
Space Sens. + Lat.	Plenum Sens. + Lat.	Net Total	Percent Of Total		Space Sensible	Percent Of Total		Space Peak	Coil Peak	Percent		Cooling	Heating	
Btu/h	Btu/h	Btu/h	(%)		Btu/h	(%)		Space Sens	Tot Sens	Of Total				
Envelope Loads					Envelope Loads			Envelope Loads						
Skylite Solar	0	0	0	0	0	0	0	Skylite Solar	0	0	0.00	SADB	55.0	72.1
Skylite Cond	0	0	0	0	0	0	0	Skylite Cond	0	0	0.00	Ra Plenum	77.2	68.9
Roof Cond	0	745	745	15	0	0	0	Roof Cond	0	-294	26.02	Return	77.2	68.9
Glass Solar	0	0	0	0	0	0	0	Glass Solar	0	0	0.00	Ret/OA	78.9	65.1
Glass/Door Cond	0	0	0	0	0	0	0	Glass/Door Cond	0	0	0.00	Fn MtrTD	0.0	0.0
Wall Cond	225	52	278	5	257	8	8	Wall Cond	-273	-339	29.99	Fn BldTD	0.0	0.0
Partition/Door	0	0	0	0	0	0	0	Partition/Door	0	0	0.00	Fn Frict	0.0	0.0
Floor	0	0	0	0	0.00	0	0	Floor	0	0	0.00			
Adjacent Floor	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Adjacent Floor	0.00	0.00	0.00			
Infiltration	0	0	0	0	0	0	0	Infiltration	0	0	0.00			
Sub Total ==>	225	797	1,022	20	257	8	8	Sub Total ==>	-273	-632	56.01			
Internal Loads					Internal Loads			Internal Loads						
Lights	1,160	0	1,160	23	1,160	36	36	Lights	0	0	0.00			
People	500	0	500	10	250	8	8	People	0	0	0.00			
Misc	1,451	0	1,451	29	1,451	45	45	Misc	0	0	0.00			
Sub Total ==>	3,111	0	3,111	62	2,861	88	88	Sub Total ==>	0	0	0.00			
Ceiling Load	120	-120	0	0	120	4	4	Ceiling Load	-60	0	0.00			
Ventilation Load	0	0	916	18	0	0	0	Ventilation Load	0	-635	56.26			
Adj Air Trans Heat	0	0	0	0	0	0	0	Adj Air Trans Heat	0	0	0			
Dehumid. Ov Sizing	0	0	0	0	0	0	0	Ov/Undr Sizing	0	0	0.00			
Ov/Undr Sizing	0	0	0	0	0	0	0	Exhaust Heat	0	0	0.00			
Exhaust Heat	0	0	0	0	0	0	0	OA Preheat Diff.	0	0	0.00			
Sup. Fan Heat	0	0	0	0	0	0	0	RA Preheat Diff.	0	0	0.00			
Ret. Fan Heat	0	0	0	0	0	0	0	Additional Reheat	0	0	0.00			
Duct Heat Pkup	0	0	0	0	0	0	0	System Plenum Heat	139	-12.27				
Underflr Sup Ht Pkup	0	0	0	0	0	0	0	Underflr Sup Ht Pkup	0	0	0.00			
Supply Air Leakage	0	0	0	0	0	0	0	Supply Air Leakage	0	0	0.00			
Grand Total ==>	3,456	677	5,049	100.00	3,237	100.00	100.00	Grand Total ==>	-332	-1,129	100.00			

AIRFLOWS		
	Cooling	Heating
Diffuser	145	145
Terminal	145	145
Main Fan	145	145
Sec Fan	0	0
Nom Vent	15	15
AHU Vent	15	15
Infil	0	0
MinStop/Rh	0	0
Return	130	130
Exhaust	0	0
Rm Exh	15	15
Auxiliary	0	0
Leakage Dwn	0	0
Leakage Ups	0	0

ENGINEERING CKS		
	Cooling	Heating
% OA	10.3	10.3
cfm/ft²	0.85	0.85
cfm/ton	345.21	
ft²/ton	404.02	
Btu/hr-ft²	29.70	-6.64
No. People	1.0	5.9/1000 ft²

COOLING COIL SELECTION										AREAS			HEATING COIL SELECTION				
	Total Capacity	Sens Cap.	Coil Airflow	Enter DB/WB/HR			Leave DB/WB/HR			Gross Total	Glass	(%)		Capacity	Coil Airflow	Ent	Lvg
	ton	MBh	MBh	cfm	°F	°F	gr/lb	°F	°F	gr/lb	ft²			MBh	cfm	°F	°F
Main Clg	0.4	5.1	4.2	145	78.9	63.9	65.1	55.0	52.1	53.6	Floor	170	Main Htg	-1.1	145	65.1	72.1
Aux Clg	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	Part	0	Aux Htg	0.0	0	0.0	0.0
Opt Vent	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	Int Door	1	Preheat	0.0	0	0.0	0.0
											ExFlr	0					
Total	0.4	5.1									Roof	170	Humidif	0.0	0	0.0	0.0
											Wall	140	Opt Vent	0.0	0	0.0	0.0
											Ext Door	0	Total	-1.1			

Room Checksums

By Go Green Engineering LLC

Stairwell

COOLING COIL PEAK					CLG SPACE PEAK					HEATING COIL PEAK					TEMPERATURES		
Peaked at Time: Mo/Hr: 6 / 16					Mo/Hr: 6 / 17					Mo/Hr: Heating Design					Cooling Heating		
Outside Air: OADB/WB/HR: 97 / 77 / 106					OADB: 96					OADB: 32					SADB	55.0	71.7
Space	Plenum	Net	Percent		Space	Percent				Space Peak	Coil Peak	Percent			Ra Plenum	77.3	68.9
Sens. + Lat.	Sens. + Lat	Total	Of Total		Sensible	Of Total				Space Sens	Tot Sens	Of Total			Return	77.3	68.9
Btu/h	Btu/h	Btu/h	(%)		Btu/h	(%)				Btu/h	Btu/h	(%)			Ret/OA	78.9	66.0
Envelope Loads					Envelope Loads					Envelope Loads					Fn MtrTD	0.0	0.0
Skylite Solar	0	0	0	0	0	0	0	0	0	0	0	0.00	0	0.00	Fn BldTD	0.0	0.0
Skylite Cond	0	0	0	0	0	0	0	0	0	0	0	0.00	0	0.00	Fn Frict	0.0	0.0
Roof Cond	0	897	897	19	0	0	0	0	0	0	-340	35.35	0	0.00	AIRFLOWS		
Glass Solar	0	0	0	0	0	0	0	0	0	0	0	0.00	0	0.00	Cooling Heating		
Glass/Door Cond	89	0	89	2	86	3	86	3	86	-152	-152	15.78	0	0.00	Diffuser	150	150
Wall Cond	81	35	116	2	103	3	103	3	103	-62	-88	9.19	0	0.00	Terminal	150	150
Partition/Door	0	0	0	0	0	0	0	0	0	0	0	0.00	0	0.00	Main Fan	150	150
Floor	0	0	0	0	0.00	0	0.00	0	0.00	0	0	0.00	0	0.00	Sec Fan	0	0
Adjacent Floor	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Nom Vent	12	12
Infiltration	0	0	0	0	0	0	0	0	0	0	0	0.00	0	0.00	AHU Vent	12	12
Sub Total ==>	170	932	1,102	23	189	6	189	6	189	-214	-581	60.32	0	0.00	Infil	0	0
Internal Loads					Internal Loads					Internal Loads					MinStop/Rh	0	0
Lights	1,345	0	1,345	28	1,345	40	1,345	40	1,345	0	0	0.00	0	0.00	Return	138	138
People	0	0	0	0	0	0	0	0	0	0	0	0.00	0	0.00	Exhaust	0	0
Misc	1,681	0	1,681	35	1,681	50	1,681	50	1,681	0	0	0.00	0	0.00	Rm Exh	12	12
Sub Total ==>	3,026	0	3,026	62	3,026	90	3,026	90	3,026	0	0	0.00	0	0.00	Auxiliary	0	0
Ceiling Load					Ceiling Load					Ceiling Load					Leakage Dwn	0	0
Ventilation Load	0	0	717	15	0	0	0	0	0	-69	0	0.00	0	0.00	Leakage Ups	0	0
Adj Air Trans Heat	0	0	0	0	0	0	0	0	0	0	-508	52.78	0	0	ENGINEERING CKS		
Dehumid. Ov Sizing	0	0	0	0	0	0	0	0	0	0	0	0.00	0	0.00	Cooling Heating		
Ov/Undr Sizing	0	0	0	0	0	0	0	0	0	0	0	0.00	0	0.00	% OA	8.0	8.0
Exhaust Heat	0	0	0	0	0	0	0	0	0	0	0	0.00	0	0.00	cfm/ft²	0.76	0.76
Sup. Fan Heat	0	0	0	0	0	0	0	0	0	0	0	0.00	0	0.00	cfm/ton	372.65	
Ret. Fan Heat	0	0	0	0	0	0	0	0	0	0	0	0.00	0	0.00	ft²/ton	487.88	
Duct Heat Pkup	0	0	0	0	0	0	0	0	0	0	126	-13.10	0	0.00	Btu/hr-ft²	24.60	-4.89
Underflr Sup Ht Pkup	0	0	0	0	0	0	0	0	0	0	0	0.00	0	0.00	No. People	0.0	0.0/1000 ft²
Supply Air Leakage	0	0	0	0	0	0	0	0	0	0	0	0.00	0	0.00			
Grand Total ==>	3,341	787	4,845	100.00	3,354	100.00	3,354	100.00	3,354	-283	-963	100.00	0	0.00			

COOLING COIL SELECTION										AREAS				HEATING COIL SELECTION				
Total Capacity	Sens Cap.	Coil Airflow	Enter DB/WB/HR		Leave DB/WB/HR					Gross Total	Glass			CapacityCoil Airflow	Ent	Lvg		
ton MBh	MBh	cfm	°F °F	gr/lb	°F °F	gr/lb	°F °F	gr/lb			ft² (%)			MBh cfm	°F	°F		
Main Clg	0.4	4.9	4.4	150	78.9	62.6	59.1	55.0	51.5	197				Main Htg	-1.0	150	66.0	71.7
Aux Clg	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0				Aux Htg	0.0	0	0.0	0.0
Opt Vent	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	1				Preheat	0.0	0	0.0	0.0
										ExFlr	0							
Total	0.4	4.9								Roof	197	0	0	Humidif	0.0	0	0.0	0.0
										Wall	37	0	0	Opt Vent	0.0	0	0.0	0.0
										Ext Door	20	0	0	Total	-1.0			

Room Checksums

By Go Green Engineering LLC

Women

COOLING COIL PEAK					CLG SPACE PEAK					HEATING COIL PEAK					TEMPERATURES		
Peaked at Time: Mo/Hr: 6 / 13					Mo/Hr: 6 / 13					Mo/Hr: Heating Design					Cooling Heating		
Outside Air: OADB/WB/HR: 95 / 75 / 97					OADB: 95					OADB: 32					SADB	55.0	77.7
Space Sens. + Lat.	Plenum Sens. + Lat.	Net Total	Percent Of Total		Space Sensible	Percent Of Total				Space Peak	Coil Peak	Percent			Ra Plenum	77.0	68.9
Btu/h	Btu/h	Btu/h	(%)		Btu/h	(%)				Space Sens	Tot Sens	Of Total			Ret/OA	77.0	68.9
										Btu/h	Btu/h	(%)			Fn MtrTD	0.0	0.0
Envelope Loads					Envelope Loads					Envelope Loads					Fn BldTD	0.0	0.0
Skylite Solar	0	0	0	0	0	0	0	0	0	0	0	0.00	0	0	Fn Frict	0.0	0.0
Skylite Cond	0	0	0	0	0	0	0	0	0	0	0	0.00	0	0			
Roof Cond	0	0	0	0	0	0	0	0	0	0	0	0.00	0	0			
Glass Solar	0	0	0	0	0	0	0	0	0	0	0	0.00	0	0			
Glass/Door Cond	0	0	0	0	0	0	0	0	0	0	0	0.00	0	0			
Wall Cond	1,787	426	2,213	49	1,787	43	0	0	0	-1,554	-1,931	104.97	0	0			
Partition/Door	0	0	0	0	0	0	0	0	0	0	0	0.00	0	0			
Floor	0	0	0	0	0.00	0	0	0	0	0	0	0.00	0	0			
Adjacent Floor	0.00	0.00	0.00	0.00	0.00	0.00	0	0	0	0.00	0.00	0.00	0	0			
Infiltration	0	0	0	0	0	0	0	0	0	0	0	0.00	0	0			
Sub Total ==>	1,787	426	2,213	49	1,787	43	0	0	0	-1,554	-1,931	104.97	0	0			
Internal Loads					Internal Loads					Internal Loads							
Lights	1,024	0	1,024	23	1,024	24	0	0	0	0	0	0.00	0	0			
People	0	0	0	0	0	0	0	0	0	0	0	0.00	0	0			
Misc	1,280	0	1,280	28	1,280	31	0	0	0	0	0	0.00	0	0			
Sub Total ==>	2,304	0	2,304	51	2,304	55	0	0	0	0	0	0.00	0	0			
Ceiling Load	96	-96	0	0	96	2	0	0	0	-53	0	0.00	0	0			
Ventilation Load	0	0	0	0	0	0	0	0	0	0	0	0.00	0	0			
Adj Air Trans Heat	0	0	0	0	0	0	0	0	0	0	0	0	0	0			
Dehumid. Ov Sizing			0	0			0	0	0	0	0	0.00	0	0			
Ov/Undr Sizing	0	0	0	0	0	0	0	0	0	0	0	0.00	0	0			
Exhaust Heat		0	0	0			0	0	0	0	0	0.00	0	0			
Sup. Fan Heat			0	0			0	0	0	0	0	0.00	0	0			
Ret. Fan Heat		0	0	0			0	0	0	0	0	0.00	0	0			
Duct Heat Pkup		0	0	0			0	0	0	0	0	0.00	0	0			
Underflr Sup Ht Pkup			0	0			0	0	0	0	0	0.00	0	0			
Supply Air Leakage		0	0	0			0	0	0	0	0	0.00	0	0			
Grand Total ==>	4,187	330	4,517	100.00	4,187	100.00	0	0	0	-1,607	-1,839	100.00	0	0			

TEMPERATURES		
	Cooling	Heating
SADB	55.0	77.7
Ra Plenum	77.0	68.9
Return	77.0	68.9
Ret/OA	77.0	68.9
Fn MtrTD	0.0	0.0
Fn BldTD	0.0	0.0
Fn Frict	0.0	0.0

AIRFLOWS		
	Cooling	Heating
Diffuser	188	188
Terminal	188	188
Main Fan	188	188
Sec Fan	0	0
Nom Vent	0	0
AHU Vent	0	0
Infil	0	0
MinStop/Rh	0	0
Return	188	188
Exhaust	0	0
Rm Exh	0	0
Auxiliary	0	0
Leakage Dwn	0	0
Leakage Ups	0	0

ENGINEERING CKS		
	Cooling	Heating
% OA	0.0	0.0
cfm/ft²	1.25	1.25
cfm/ton	499.11	
ft²/ton	398.52	
Btu/hr-ft²	30.11	-12.26
No. People	0.0	0.0/1000 ft²

COOLING COIL SELECTION										AREAS			HEATING COIL SELECTION				
	Total Capacity	Sens Cap.	Coil Airflow	Enter DB/WB/HR		Leave DB/WB/HR				Gross Total	Glass		Capacity	Coil Airflow	Ent	Lvg	
	ton	MBh	MBh	cfm	°F °F	gr/lb	°F °F	gr/lb			ft²	(%)	MBh	cfm	°F	°F	
Main Clg	0.4	4.5	4.5	188	77.0 57.7	40.5	55.0 48.6	40.5		Floor	150		Main Htg	-1.8	188	68.9	77.7
Aux Clg	0.0	0.0	0.0	0	0.0 0.0	0.0	0.0 0.0	0.0		Part	0		Aux Htg	0.0	0	0.0	0.0
Opt Vent	0.0	0.0	0.0	0	0.0 0.0	0.0	0.0 0.0	0.0		Int Door	1		Preheat	0.0	0	0.0	0.0
										ExFlr	0						
Total	0.4	4.5								Roof	0	0 0	Humidif	0.0	0	0.0	0.0
										Wall	798	0 0	Opt Vent	0.0	0	0.0	0.0
										Ext Door	0	0 0	Total	-1.8			