



Britt Surveying and Mapping, LLC
1438 SW Main Blvd • Lake City, FL 32025
386-752-7163 P • 386-752-5573 F • www.brittsurvey.com

07/09/2024

L-30582

Re: Mini Storage of Lake City

Permit # 000049328

Stephen Douglas

To Whom It May Concern:

The finished floor elevation for building # 1100 is found to be 97.48 feet and the finished floor elevation for building #1200 is found to be 97.44 feet. The building plans show an elevation of 97.3 feet for the minimum floor elevation. The elevations shown hereon are based on NAVD 88 datum.

Sincerely,

L. Scott Britt
LS 5757

