



Britt Surveying and Mapping, LLC
2086 SW Main Blvd Ste 112 • Lake City, FL 32025
386-752-7163 P • 386-752-5573 F • www.brittsurvey.com

07/24/2021

Permit # 000041956

L-27854


Trent Giebeig Construction

Re: Lot 9 Crosswinds

To Whom It May Concern:

The top of the finished slab on said Lot 9 is 100.38 feet. The building permit requires the minimum floor to be 100.25 feet. The elevations shown hereon are based on NAVD 88 datum.

Sincerely,


L. Scott Britt

LS 5757