

**From:** [Boozer, Dwight](#)  
**To:** [Melissa Garber](#)  
**Subject:** RE: App #55522  
**Date:** Monday, September 19, 2022 4:47:39 PM  
**Attachments:** [image001.png](#)

---

The actual piping plan is fine they just need to install the 5' Storz connection instead of the double 2 ½' connection.



***Lake City Fire Department***

Assistant Fire Chief/Fire Inspector

Dwight Boozer

386-752-3312

386-965-8696

---

**From:** Melissa Garber <[mgarber@columbiacountyfla.com](mailto:mgarber@columbiacountyfla.com)>  
**Sent:** Monday, September 19, 2022 4:25 PM  
**To:** Boozer, Dwight <[BoozerD@lcfla.com](mailto:BoozerD@lcfla.com)>  
**Subject:** RE: App #55522

Thank you. Does this plan meet that or do they need to change something to meet that requirement? Thanks!

*"Autumn is a second  
spring where every  
leaf is a flower."*



***Melissa Garber***

Administrative Supervisor

Columbia County

Building and Zoning

135 NE Hernando Ave, Suite B-21

Lake City, Florida 32055

Ph (386) 758-1007

CONFIDENTIALITY NOTICE: This e-mail message, including any attachments, is for the sole use of the intended recipient(s) and may contain confidential, proprietary, and/or privileged information protected by law. If you are not the intended recipient, you may not use, copy, or distribute this e-mail message or its attachments. If you believe you have received this e-mail message in error, please contact the sender by reply e-mail and telephone immediately and destroy all copies of the original message.

---

**From:** Boozer, Dwight <[BoozerD@lcfla.com](mailto:BoozerD@lcfla.com)>  
**Sent:** Monday, September 19, 2022 4:20 PM  
**To:** Melissa Garber <[mgarber@columbiacountyfla.com](mailto:mgarber@columbiacountyfla.com)>  
**Subject:** Re: App #55522

I have approved the Life Safety portion of the plans. I'm not sure if it was relayed to you, but we do require a 5" Stortz connection for the FDC.

Sent from my iPhone

On Sep 19, 2022, at 3:49 PM, Melissa Garber <[mgarber@columbiacountyfla.com](mailto:mgarber@columbiacountyfla.com)> wrote:

Good afternoon,  
Attached are the plans for the hospital. Can you advise if these have been approved.  
Thanks! Have a great day!

*"Autumn is a second  
spring where every  
leaf is a flower."*

*Melissa Garber*

Administrative Supervisor  
Columbia County  
Building and Zoning  
135 NE Hernando Ave, Suite B-21  
Lake City, Florida 32055  
Ph (386) 758-1007

CONFIDENTIALITY NOTICE: This e-mail message, including any attachments, is for the sole use of the intended recipient(s) and may contain confidential, proprietary, and/or

privileged information protected by law. If you are not the intended recipient, you may not use, copy, or distribute this e-mail message or its attachments. If you believe you have received this e-mail message in error, please contact the sender by reply e-mail and telephone immediately and destroy all copies of the original message.

## **Disclaimer**

The information contained in this communication from the sender is confidential. It is intended solely for use by the recipient and others authorized to receive it. If you are not the recipient, you are hereby notified that any disclosure, copying, distribution or taking action in relation of the contents of this information is strictly prohibited and may be unlawful.

This email has been scanned for viruses and malware, and may have been automatically archived. We have implemented **HAVEN™**, from **Corvid Cyberdefense** which protects our networks, data, email and endpoints with leading edge threat prevention controls and **24x7x365** threat detection and monitoring. To find out more [Click Here](#).