



Britt Surveying and Mapping, LLC
2086 SW Main Blvd Ste 112 • Lake City, FL 32025
386-752-7163 P • 386-752-5573 F • www.brittsurvey.com

05/23/2022

Permit # 000044237

L-28628

Suzzan Molinski

Re: 02227-001

To Whom It May Concern:

The top of the finished floor of the mobile home is found to be 117.84 feet. The center of NW Ash Drive is found to be 115.85 feet. The building permit shows the minimum floor elevation to be one foot above the road. The elevations shown hereon are based on NAVD 88 datum.

Sincerely,

A handwritten signature in black ink, appearing to read "L. Scott Britt", is written over a circular professional seal. The signature is fluid and cursive.

L. Scott Britt
LS 5757

