

Bounds Heating and Air Inc  
Lic: CA-C057642  
25645 W Newberry Road  
Newberry, FL 32669



Phone: (352) 472-2761  
Fax: (352) 472-1809  
bounds\_hvac@yahoo.com  
www.boundshvac.com

Phone Number:

Email Address:

Bill to  
**Amira Builders**  
14901 Main St  
Alachua, FL 32616

Ship to  
**Amira Morse 22-287**  
125 SW Hawaii Ter  
Fort White, FL 32038

Work Order #: 76899

Assigned Tech: Julius J.

Task: Blower Door Test

Completion Date: 1/10/2023

## Blower Door Test Form

Blower Door Test Form

### Air Filtration Test Results

1. CFM (50) =	919
2. VOLUME =	14184
3. ACH (50)= CFM (50) X 60 / VOLUME =	3.8
4. Double check grills, pick up all trash including dry wall debris. Do final walk through of home.	<input checked="" type="checkbox"/>
5. Pass Fail (more than 7 ACH)	PASS
6. Pass Fail (more than 7 ACH)	<input checked="" type="checkbox"/> PASS

*Passing results of 3-7 ACH, does not require mechanical ventilation. Less than 3 ACH will require mechanical ventilation.*

7. Certification of Test Results R402.4.1.1 Testing.	5.00
--	------

Bounds Heating and Air Inc  
Lic: CA-C057642  
25645 W Newberry Road  
Newberry, FL 32669



Phone: (352) 472-2761  
Fax: (352) 472-1809  
bounds\_hvac@yahoo.com  
www.bounds HVAC.com

## Technician

A handwritten signature in black ink, consisting of stylized, overlapping loops and a long horizontal stroke extending to the right.

---

Julius J.

1/10/2023