

Notice of Prevention for Subterranean Termites

(As required by Florida Building Code (FBC) 104.2.6)



A locally owned
company serving
you since 1978

17856 U.S. 129 • McALPIN, FLORIDA 32062
(386) 362-3887 • 1-800-771-3887 • Fax: (386) 364-3529

302 SW CROW TERRACE FORT WHITE, FL 32038

Address of Treatment or Lot/Block of Treatment

Date	7-15-24	Time	1200 pm	Applicator	OTTO #84
Product Used	PROUNISE	Chemical used (active ingredient)	IMIDACLOPRID	Number of gallons applied	107.6 gal
Percent Concentration	1%	Area treated (square feet)	NA	Linear feet treated	269 linear

FINAL GRADE
Stage of treatment (Horizontal, Vertical, Adjoining Slab, retreat of disturbed area)

As per 104.2.6 - If soil chemical barrier method for Subterrean termite prevention is used, final exterior treatment shall be completed prior to final building approval.

The building has received a complete treatment for the prevention of subterranean termites. Treatment is in accordance with rules & laws established by the Florida Department of Agriculture & Consumer Services. Initial and date this line.

7-15-24 OTTO
If this notice is for the final exterior treatment initial and date this line. 7-15-24 OTTO