



---

**Britt Surveying and Mapping, LLC**  
1438 SW Main Blvd • Lake City, FL 32025  
386-752-7163 P • 386-752-5573 F • [www.brittsurvey.com](http://www.brittsurvey.com)

02/16/2023

Permit # 000046170

L-29292

Re: Lot 16 Pinewood Estates Unit 2

Edward Morales

To Whom It May Concern:

The finished slab elevation is found to be 86.76 feet. The minimum floor elevation per the building permit is shown to be 84 feet. All elevations are shown in NAVD 88 datum.

Sincerely,

  
L. Scott Britt  
LS 5757