Mobile Home Permit Worksheet	Application Number: Date:
Installer: <u>Robert Sheppard</u> License # <u>JH</u> 1025386 Address of home <u>TBD 5W McGuire Terrace</u> being installed <u>Lake City, F1, 32024</u> Manufacturer <u>Champion</u> Length x width <u>28 X 72</u> NOTE: if home is a single wide fill out one half of the blocking plan if home is a triple or quad wide sketch in remainder of home I understand Lateral Arm Systems cannot be used on any home (new or used)	New Home Used Home Home installed to the Manufacturer's Installation Manual Home is installed in accordance with Rule 15-C Single wide Wind Zone II Double wide Installation Decal # 38465 Triple/Quad Serial # FL261-00P-H-B202440 PIER SPACING TABLE FOR USED HOMES
where the sidewall ties exceed 5 ft 4 in. Typical pier spacing 2' 5 Lateral Longitudinal and Lateral Systems (use dark lines to show these locations)	$ \begin{array}{ c c c c c c c c c c c c c c c c c c c$
	* interpolated from Rule 15C-1 pier spacing table. PIER PAD SIZES I-beam pier pad size 17225 Perimeter pier pad size 16×16 256 16 $\times 16$ 256 16 $\times 18$ 288 17 $\times 25$ Other pier pad sizes 17×25 (required by the mfg.) TTT Draw the approximate locations of marriage 20×20 400
nearriage wall piers within 2' of end of home per Rule 15C	wall openings 4 foot or greater. Use this symbol to show the piers. List all marriage wall openings greater than 4 foot and their pier pad sizes below. Opening Pier pad size $\frac{0}{4 \text{ ft}} \underbrace{5 \text{ ft}}_{5 \text{ ft}}$
Plans Plans Compliance Compliance Plans Pl	TIEDOWN COMPONENTS within 2' of end of home spaced at 5' 4" oc TIEDOWN COMPONENTS OTHER TIES Longitudinal Stabilizing Device (LSD) Sidewall Manufacturer Under the spaced at 5' 4" oc Manufacturer Number Longitudinal Stabilizing Device (LSD) Sidewall Manufacturer Under the spaced at 5' 4" oc Manufacturer Manufacturer Manufacturer Manufacturer Manufactur

Mobile Home Permit Worksheet	Application Number:Date:
POCKET PENETROMETER TEST The pocket penetrometer tests are rounded down to psf or check here to declare 1000 lb. soil without testing. X X X	Site Preparation Debris and organic material removed
x x x x	or id a peorly installed or no gasket being installed. I understand a strip of tape will not serve as a gasket. Installer's initials
TORQUE PROBE TEST The results of the torque probe test is 290 inch pounds or check here if you are declaring 5' anchors without testing A test showing 275 inch pounds or less will require 5 foot anchors. Note: A state approved lateral arm system is being used and 4 ft.	Type gasket Foam Installed: Pg. 22 Installed: Between Floors Yes Between Walls Yes Bottom of ridgebeam Yes Weatherproofing
anchors are allowed at the sidewall locations. I understand 5 ft anchors are required at all centerline tie points where the torque test reading is 275 or less and where the mobile home manufacturer may requires anchors with 4000 lb holding capacity.	The bottomboard will be repaired and/or taped. Yes Pg Siding on units is installed to manufacturer's specifications. Yes Fireplace chimney installed so as not to allow intrusion of rain water. Yes Miscellaneous
ALL TESTS MUST BE PERFORMED BY A LICENSED INSTALLER Installer Name	Skirting to be installed. Yes No Dryer vent installed outside of skirting. Yes N/A Range downflow vent installed outside of skirting. Yes N/A Drain lines supported at 4 foot intervals. Yes Electrical crossovers protected. Yes Other :
Electrical	
Connect electrical conductors between multi-wide units, but not to the main power source. This includes the bonding wire between mult-wide units. Pg	Installer verifies all information given with this permit worksheet is accurate and true based on the manufacturer's installation instructions and or Rule 15C-1 & 2
Connect all potable water supply piping to an existing water meter, water tap, or other independent water supply systems. Pg22	Installer Signature Robert Shepparch Date 9/25/20
Page	2 of 2



