



Britt Surveying and Mapping, LLC
2086 SW Main Blvd Ste 112 • Lake City, FL 32025
386-752-7163 P • 386-752-5573 F • www.brittsurvey.com

05/11/20

Permit # 000002848

L-26538

Re: 01-5S-16-03397-204

To Whom It May Concern:

The elevation of the slab on this parcel is established to be 89.49 feet. The highest adjacent grade is 89.5 feet and the lowest adjacent grade is 88.1 feet. The minimum floor elevation as per the building permit is to be 83.9 feet. The elevations are shown in an assumed datum.

Sincerely,

L. Scott Britt
LS 5757

