



Britt Surveying and Mapping, LLC
1438 SW Main Blvd • Lake City, FL 32025
386-752-7163 P • 386-752-5573 F • www.brittsurvey.com

11/11/2022

Permit # 000043402

L-29077

Re: 03813-003

Bill Ladson

To Whom It May Concern:

The finished slab elevation is found to be 73.18 feet. The minimum floor elevation per the building permit is shown to be 72.3 feet. All elevations are shown in NAVD 88 datum.

Sincerely,

L. Scott Britt
LS 5757