



## ENGINEERING & TESTING LABORATORY

P.O. Box 1625, Lake City, FL 32056-1625  
7540 103rd St. Suite 215 • Jacksonville, FL 32210

Lake City • (386) 755-3633  
Fax • (386) 752-5456

Jacksonville • (904) 381-8901  
Fax • (904) 381-8902

JOB NO.: 22-157 22-58  
DATE TESTED: 12-14-23

### REPORT OF IN-PLACE DENSITY TEST

ASTM METHOD: \_\_\_\_\_ (D-2922) Nuclear \_\_\_\_\_ (D-2937) Drive Cylinder \_\_\_\_\_ Other

PROJECT: House pad

CLIENT: Stanley Crawford Coast

GENERAL CONTRACTOR: \_\_\_\_\_ EARTHWORK CONTRACTOR: \_\_\_\_\_

SOIL USE (SEE NOTE): \_\_\_\_\_ SPECIFICATION REQUIREMENTS: 95%

TECHNICIAN: J. Green

MODIFIED (ASTM D-1557): \_\_\_\_\_ STANDARD (ASTM D-698): \_\_\_\_\_

TEST NO.	TEST LOCATION	TEST: DEPTH ELEV. LIFT	PROCTOR NO.	WET DENS. LBS./CU.FT.	DRY DENS. LBS./CU.FT.	MOIST PERCENT	% MAX. DENS.
1	10 ft from NE corner		1054	112.7	109.9	36	103.2
2	middle of pad		1054	109.7	105.3	42	99.9
3	15 ft from SW corner		1054	114.1	109.5	42	103.9

REMARKS: \_\_\_\_\_

PROCTOR NO.	SOIL DESCRIPTION	PROCTOR VALUE	OPT. MOIST.

NOTE: 1. Building Fill 2. Trench Backfill 3. Base Course 4. Subbase/Stabilized Subgrade 5. Embankment 6. Subgrade/Natural Soil 7. Other  
The test results presented in this report are specific only to the samples tested at the time of testing. The tests were performed in accordance with generally accepted methods and standards. Since material conditions can vary between test location and change with time, sound judgement should be exercised with regard to the use and interpretation of the data.