



NEMO | etc.

Certificate of Authorization #32455
353 Christian Street, Unit #13
Oxford, CT 06478
(203) 262-9245

ENGINEER

TEST

CONSULT

P.E. EVALUATION REPORT (PEER)

TAMKO Building Products, LLC

PO Box 97
Galena, KS 66739
(417) 624-6644

PEER-TAM-003.B.R3

FL12328-R12 (HVHZ)

Date of Issuance: 09/29/2020

Revision 3: 02/12/2024

SCOPE:

This P.E. Evaluation Report (henceforth 'PEER') is issued under Rule 61G20-3 and the applicable rules and regulations governing the use of construction materials in the State of Florida. The documentation submitted has been reviewed by Robert Nieminen, P.E. for use of the product under the Florida Building Code. The products described herein have been evaluated for compliance with the **8th Edition (2023) Florida Building Code, High Velocity Hurricane Zone** sections noted herein.

DESCRIPTION: TAMKO Roof Underlayments (HVHZ)

LABELING: Labeling shall be in accordance with the requirements of the Accredited Quality Assurance Agency noted herein.

CONTINUED COMPLIANCE: This PEER is valid until such time as the named product(s) changes, the referenced Quality Assurance or production facility location(s) changes, or Code provisions that relate to the product(s) change. Acceptance of our PEERs by the named client constitutes agreement to notify NEMO ETC, LLC of any changes to the product(s), the Quality Assurance or the production facility location(s). NEMO ETC, LLC requires a complete review of its PEER relative to updated Code requirements with each Code Cycle.

ADVERTISEMENT: The Florida Product Approval Number (FL#) preceded by the words "NEMO P.E. Evaluated" may be displayed in advertising literature. If any portion of the PEER is displayed, then it shall be done in its entirety.

INSPECTION: Upon request, a copy of this entire PEER shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This PEER consists of pages 1 through 6.

Prepared by:

Digitally signed by
Robert Nieminen
Date: 2024.02.12
'16:45:37 -05'00

This item has been digitally signed and sealed by Robert Nieminen, P.E.
Printed copies of this document are not considered signed and sealed, and the signature must be verified on any electronic copies.
Robert Nieminen, Florida P.E. 59166, FBC ANE1983
NEMO ETC, LLC, Florida CA #32455



CERTIFICATION OF INDEPENDENCE:

1. NEMO ETC, LLC does not have, nor does it intend to acquire or will it acquire, a financial interest in any company manufacturing or distributing products it evaluates.
2. NEMO ETC, LLC is not owned, operated or controlled by any company manufacturing or distributing products it evaluates.
3. Robert Nieminen, P.E. does not have nor will acquire, a financial interest in any company manufacturing or distributing products for which the PEERs are being issued.
4. Robert Nieminen, P.E. does not have, nor will acquire, a financial interest in any other entity involved in the approval process of the product.
5. This is a building code evaluation. Neither NEMO ETC, LLC nor Robert Nieminen, P.E. are, in any way, the Designer of Record for any project on which this PEER, or previous versions thereof, is/was used for permitting or design guidance unless retained specifically for that purpose.

©2019, NEMO ETC, LLC

**ROOFING COMPONENT EVALUATION****1. SCOPE:****Product Category:** Roofing**Sub-Category:** Underlayment**Product Approval Method:** Method 1, Option D – Codified Material, Evaluation by Engineer**Compliance Statement:** TAMKO Roof Underlayments, as produced by TAMKO Building Products LLC, have demonstrated compliance with the following sections of the 8th Edition (2023) Florida Building Code, High Velocity Hurricane Zone through testing in accordance with the following Standards. Compliance is subject to the Installation Requirements and Limitations of Use set forth herein.**2. STANDARDS:**

SECTION	PROPERTY	STANDARD
1518.2, 1518.2.1, TAS 110, RAS 118, RAS 119, RAS 120, RAS 130	Material standard	ASTM D226
1518.2, 1518.2.1, TAS 110, RAS 130	Material standard	ASTM D1970
TAS 110, RAS 118, RAS 119, RAS 120	Material standard	ASTM D6380
TAS 103, Section 7	Wind uplift	UL1897

3. REFERENCES:

ENTITY	EXAMINATION	REFERENCE	DATE
MTI (TST2508)	ASTM D1970	DX24H7B	10/03/2017
PRI (TST5878)	ASTM D1970	TAP-388-02-01	10/04/2017
PRI (TST5878)	ASTM D226, Type II	TAP-420-02-01	04/19/2018
PRI (TST5878)	ASTM D6380	847T0009	12/21/2019
PRI (TST5878)	ASTM D6380	847T00010	12/21/2019
PRI (TST5878)	ASTM D226, Type II	TAP-351-02-01	04/25/2016
NEMO (TST6049)	ASTM D1970	4j-TAM-22-SSUDL-01.A	11/14/2022
NEMO (TST6049)	UL1897	4a-TAM-23-LSWUS-01.A	12/25/2023
UL LLC (QUA9625)	Quality Assurance	Service Confirmation	06/01/2023
UL LLC (QUA9625)	Quality Assurance	Florida BCIS	Current

4. PRODUCT DESCRIPTION:

TABLE 1: EVALUATED UNDERLAYMENTS			
PRODUCT	MATERIAL STANDARD	PLANT(S)	DESCRIPTION
No. 30 UL	ASTM D226, Type II	Joplin, MO Green Cove Springs, FL	Asphalt-saturated organic felt
Moisture Guard®	ASTM D1970	Joplin, MO	Self-adhering, fiberglass reinforced SBS modified bitumen roof underlayment with a mineral top surface.
TW Underlayment	ASTM D1970 ¹	Columbus, KS	Self-adhering, SBS modified bitumen roof underlayment with a polymer-film top surface.
TW Metal and Tile Underlayment	ASTM D1970 ¹	Joplin, MO	Self-adhering, fiberglass reinforced SBS modified bitumen roof underlayment with a polymer-film top surface.
TW Seam Tape	ASTM D1970	Columbus, KS	Self-adhering, SBS modified bitumen roof underlayment with a polymer-film top surface.

¹ Agreement between purchaser and seller, as set forth in Section 4.3, Note 1 of ASTM D1970-17, should be established as to slip resistance of TW Underlayment and TW Metal and Tile Underlayment.

TABLE 1: EVALUATED UNDERLAYMENTS			
PRODUCT	MATERIAL STANDARD	PLANT(S)	DESCRIPTION
ASTM Slate Surfaced Roll Roofing	ASTM D6380, Class M, Type II	Green Cove Springs, FL	Asphalt-saturated organic mat, coated on both sides with asphalt and surfaced with granules.
ASTM Tile Underlayment	ASTM D6380, Class M, Type II	Green Cove Springs, FL	Asphalt-saturated organic felt, coated on both sides with asphalt and surfaced with granules.

5. LIMITATIONS:

- 5.1 This is a building code evaluation. Neither NEMO ETC, LLC nor Robert Nieminen, P.E. are, in any way, the Designer of Record for any project on which this PEER, or previous versions thereof, is/was used for permitting or design guidance. PEERs are not to be construed as representing any attributes not specifically listed, nor are PEERs to be construed as an endorsement of the subject, or a recommendation for its use. There is no warranty by NEMO ETC, LLC or Robert Nieminen, P.E., express or implied, as to any finding or other matter in this PEER, or as to any product covered by the PEER.
- 5.2 This PEER is exclusively for use in FBC High Velocity Hurricane Zone jurisdictions, as defined in FBC Chapter 2 (Broward and Miami-Dade Counties).
- 5.3 This PEER pertains to above-deck roof components. Roof decks and structural members shall be in accordance with FBC requirements to the satisfaction of the Authority Having Jurisdiction.
- 5.4 This PEER does not include evaluation of fire classification. Refer to **FBC HVHZ 1516** for requirements and limitations regarding roof assembly fire classification. Refer to **FBC 2603** for requirements and limitations concerning the use of foam plastic insulation.
- 5.5 **TAMKO Roof Underlayments** may be used with any prepared roof cover where the product is specifically referenced within FBC approval documents. If not listed, a request may be made to the Authority Having Jurisdiction for approval based on this PEER combined with supporting data for the prepared roof covering.
- 5.6 Allowable Roof Covers:

TABLE 2: ROOF COVER OPTIONS						
<u>FBC HVHZ:</u>	<i>RAS 115 1518.2.1</i>	<i>RAS 118, 119 & 120</i>		<i>RAS 133 1518.2.1</i>	<i>1518.2.1</i>	<i>RAS 130 1518.10</i>
UNDERLAYMENT	ASPHALT SHINGLES	CLAY AND CONCRETE TILE		METAL	SLATE OR SLATE- TYPE SHINGLES	WOOD
		MECHANICAL ATTACH	ADHESIVE-SET			
No. 30 UL	Yes	Yes (as Base Sheet, <i>See Section 6</i>)	Yes (as Base Sheet, <i>See Section 6</i>)	Yes	Yes	Yes
Moisture Guard®	Yes	No	No	No	Yes	Yes (Valley Liner)
TW Underlayment	Yes	No	No	Yes	Yes	Yes (Valley Liner)
TW Metal and Tile Underlayment	Yes	No	No	Yes	Yes	Yes (Valley Liner)
TW Seam Tape	Yes ²	Yes ²	Yes ²	Yes ²	Yes ²	Yes ²
ASTM Slate Surfaced Roll Roofing	Yes (Valley Liner)	Yes (Cap Sheet in 2- ply system)	No	No	No	No
ASTM Tile Underlayment	Yes (Valley Liner)	Yes (Cap Sheet in 2- ply system)	No	No	No	No

² Used as min. 3 ¾-inch wide joint-strips per FBC HVHZ 1518.2.1(2).

5.7 Allowable Substrates:

TABLE 3: SUBSTRATE OPTIONS FOR ADHERED UNDERLAYMENTS			
UNDERLAYMENT	APPLICATION	SUBSTRATES (DESIGNED TO MEET WIND LOADS FOR PROJECT)	
		PRIMER	SUBSTRATES
Moisture Guard®, TW Underlayment or TW Metal and Tile Underlayment	self-adhering	(Optional) ASTM D41	plywood
		None	No. 30 UL
TW Seam Tape	self-adhering	(Optional) ASTM D41	plywood (for use as Secondary Water Barrier only)
ASTM Slate Surfaced Roll Roofing or ASTM Tile Underlayment	hot asphalt	None	No. 30 UL

5.8 Attachment Limitations:

5.8.1 Refer to [Section 6](#) for codified prescriptive systems.

5.8.2 Refer to [Table 4](#) for underlayment systems which have documented compliance with Section 7 of [TAS 103](#). The Maximum Design Pressure is the result of testing for wind load resistance based on allowable wind loads, and reflects the ultimate passing pressure divided by 2 (the 2 to 1 margin of safety has already been applied). No extrapolation or rational analysis is permitted for assemblies marked with an asterisk*.

TABLE 4: ALLOWABLE DESIGN PRESSURES, 2-PLY UNDERLAYMENT SYSTEMS IN TILE ROOF APPLICATIONS						
SYSTEM No.	DECK	JOINT TREATMENT	BASE SHEET		CAP PLY	MDP (PSF)
			TYPE	ATTACH		
UDL-1.	Plywood, APA rated sheathing, 32/16, Exposure 1, PS1, 15/32 category	(Optional) TW Seam Tape, self-adhered	No. 30 UL	12 ga. x 1.5-inch annular ring shank nails with 32 ga., 1-5/8-inch diameter tin caps, 6-inch o.c. at the 4-inch laps and 12-inch o.c. at two (2) equally spaced center rows	ASTM Slate Surfaced Roll Roofing or ASTM Tile Underlayment, applied in ASTM D312, Type IV hot asphalt and back-nailed using 12 ga. ring shank nails with 32 ga., 1-5/8-inch diameter tin caps, 12-inch o.c.	-45.0
UDL-2.	Plywood, APA rated sheathing, 32/16, Exposure 1, PS1, 15/32 category	(Optional) TW Seam Tape, self-adhered	No. 30 UL	12 ga. x 1.5-inch annular ring shank nails with 32 ga., 1-5/8-inch diameter tin caps, 6-inch o.c. at the 4-inch laps and 6-inch o.c. at two (2) equally spaced center rows	ASTM Slate Surfaced Roll Roofing or ASTM Tile Underlayment, applied in ASTM D312, Type IV hot asphalt and back-nailed using 12 ga. ring shank nails with 32 ga., 1-5/8-inch diameter tin caps, 12-inch o.c.	-67.5

5.9 Exposure Limitations:

TABLE 4: EXPOSURE LIMITATIONS	
UNDERLAYMENT	MAXIMUM EXPOSURE (DAYS)*
No. 30 UL, Moisture Guard®, TW Underlayment or TW Metal and Tile Underlayment, ASTM Slate Surfaced Roll Roofing or ASTM Tile Underlayment	30

*Maximum exposure shall not exceed the manufacturer's recommendations, which may be less than 30 days.

5.10 Tile Slippage Limitations: When loading roof tiles on ASTM Slate Surfaced Roll Roofing or ASTM Tile Underlayment, the tile shall be staged atop battens or loading board during loading of the roof tiles.



6. INSTALLATION:

6.1 **TAMKO Roof Underlayments** shall be installed in accordance with **TAMKO Building Products LLC** installation instructions subject to the [Limitations of Use](#) set forth herein and the specifics noted below.

6.1.1 Consult TAMKO requirements for back-nailing of adhered underlayments at slopes 2:12 or greater.

6.2 Re-fasten any loose decking panels, and check for protruding nail heads. Sweep the substrate thoroughly to remove any dust and debris prior to application, and prime the substrate (if applicable).

6.3 Refer to Section 6.4 for underlayments having prescriptive codified minimum attachment or [Table 4](#) for underlayment systems having maximum design pressures established in accordance with Section 7 of [TAS 103](#).

6.4 Underlayment Assemblies with Prescriptive Minimum Attachment for use in NON-TILE applications:

- 6.4.1
- | | |
|------------------------|---|
| CODE REFERENCE: | 1518.2.1, Option 1
Underlayment adhered to deck |
| DECK DESCRIPTION: | Min. 19/32-inch plywood |
| UNDERLAYMENT: | Moisture Guard® , TW Underlayment or TW Metal and Tile Underlayment , self-adhered in accordance with FBC HVHZ 1518.2.1(1) and back-nailed max. 12-inch o.c. using FBC HVHZ Approved nails and tin caps (FBC HVHZ 1517.5). |
| SURFACING: | FBC HVHZ Approved asphalt shingles, metal roof panels or metal shingles, slate or slate type shingles, subject to the allowable roof covers in Table 2 herein. |
- 6.4.2
- | | |
|--------------------------|---|
| CODE REFERENCE: | 1518.2.1, Option 2
Self-adhering strips to deck-joints followed by underlayment mechanically attached to deck |
| DECK DESCRIPTION: | Min. 19/32" plywood or wood plank |
| SECONDARY WATER BARRIER: | TW Seam Tape self-adhered over joints of the plywood roof deck prior to installation of subsequent layer(s) in accordance with FBC HVHZ 1518.2.1(2). Do not overlap end-joints or T-joints. All end-joints and T-joints shall be butted firmly side by side, flush with each other but not overlapped. |
| UNDERLAYMENT: | No. 30 UL in accordance with FBC HVHZ Table 1518.2.1, with a minimum 4-inch side lap and 6-inch end lap, mechanically fastened to deck |
| FASTENING: | FBC HVHZ Approved nails and tin caps (FBC HVHZ 1517.5), grid pattern of 12-inches between the overlaps and 6-inch spacing at the overlaps, in accordance with FBC HVHZ Table 1518.2.1. |
| SURFACING: | FBC HVHZ Approved asphalt shingles, metal roof panels or metal shingles, slate or slate type shingles, subject to the allowable roof covers in Table 2 herein. |
- 6.4.3
- | | |
|------------------------|--|
| CODE REFERENCE: | 1518.2.1, Option 3
Two-layer underlayment mechanically fastened to deck |
| DECK DESCRIPTION: | Min. 19/32" plywood or wood plank |
| UNDERLAYMENT: | Two (2) layers of No. 30 UL in accordance with FBC HVHZ 1518.2.1(3). |
| FASTENING: | FBC HVHZ Approved nails and tin caps (FBC HVHZ 1517.5) in accordance with FBC HVHZ 1518.2.1(3). |
| SURFACING: | FBC HVHZ Approved asphalt shingles, metal roof panels or metal shingles, slate or slate type shingles, subject to the allowable roof covers in Table 2 herein. |



NEMO|etc.®

6.4.4

CODE REFERENCE:	1518.2.1, Option 1 combined with Option 2 or 3 Optional self-adhering strips to deck-joints followed by base sheet mechanically fastened to deck followed by underlayment adhered to base sheet
DECK DESCRIPTION:	Min. 19/32" plywood or wood plank
SECONDARY WATER BARRIER:	(Optional) TW Seam Tape self-adhered over joints of the plywood roof deck prior to installation of subsequent layer(s) in accordance with FBC HVHZ 1518.2.1(2). Do not overlap end-joints or T-joints. All end-joints and T-joints shall be butted firmly side by side, flush with each other but not overlapped.
BASE SHEET:	One (1) or two (2) layer(s) of No. 30 UL in accordance with FBC HVHZ Table 1518.2.1, with a minimum 4-inch side lap and 6-inch end lap, mechanically fastened to deck.
FASTENING:	FBC HVHZ Approved nails and tin caps (FBC HVHZ 1517.5), grid pattern of 12-inches between the overlaps and 6-inch spacing at the overlaps, in accordance with FBC HVHZ Table 1518.2.1.
UNDERLAYMENT:	Moisture Guard®, TW Underlayment or TW Metal and Tile Underlayment self-adhering and back-nailed max. 12-inch o.c. using FBC HVHZ Approved nails and tin caps (FBC HVHZ 1517.5).
SURFACING:	FBC HVHZ Approved asphalt shingles, metal roof panels or metal shingles, slate or slate type shingles, subject to the allowable roof covers in Table 2 herein.

7. BUILDING PERMIT REQUIREMENTS:

As required by the Building Official or Authority Having Jurisdiction in order to properly evaluate the installation of this product.

8. MANUFACTURING PLANTS:

Contact the named QA entity for manufacturing facilities covered by **F.A.C. Rule 61G20-3** QA requirements. Refer to [Section 4](#) herein for products and production locations having met codified material standards.

9. QUALITY ASSURANCE ENTITY:

[UL LLC – QUA9625](#); (360) 817-5512; bsai.inspections@ul.com

- END OF PEER -



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)
BOARD AND CODE ADMINISTRATION DIVISION
NOTICE OF ACCEPTANCE (NOA)

MIAMI-DADE COUNTY
PRODUCT CONTROL SECTION
11805 SW 26 Street, Room 208
Miami, Florida 33175-2474
T (786) 315-2590 F (786) 315-2599
www.miamidade.gov/economy

Kaycan Ltd.
1 Memorial Drive.
Richford, VT 05476

SCOPE: This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER-Product Control Section to be used in Miami-Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami-Dade County) and/ or the AHJ (in areas other than Miami-Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein and has been designed to comply with the Florida Building Code, including the High Velocity Hurricane Zone.

DESCRIPTION: Model SP-600 16" Aluminum Vented Soffit

APPROVAL DOCUMENT: Drawing No. **KAY0003**, titled "SP-600 16" Aluminum Soffit - Vented", sheets 1 through 4 of 4, dated 12/27/2011, with revision **6** dated 08/31/2023, prepared by PTC, LLC, signed and sealed by Robert J. Amoruso, P.E., bearing the Miami-Dade County Product Control revision stamp with the Notice of Acceptance number and expiration date by the Miami-Dade County Product Control Section.

MISSILE IMPACT RATING: None

LABELING: Each piece shall bear a permanent label marked at not more than 4 ft. (1.2m) o.c. with the manufacturer's name or logo, Pointe-Claire, QC, Canada and following statement: "Miami-Dade County Product Control Approved", per FBC 1709.10.2 and 1709.10.3.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/ or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA **revises NOA # 21-1208.04** and consists of this page 1 and evidence pages E-1, E-2, E-3 and E-4, as well as approval document mentioned above.

The submitted documentation was reviewed by **Carlos M. Utrera, P.E.**



NOA No. 23-0908.07
Expiration Date: June 1, 2026
Approval Date: October 26, 2023
Page 1

NOTICE OF ACCEPTANCE: EVIDENCE SUBMITTED

1. Evidence submitted under previous NOA's

A. DRAWINGS *"Submitted under NOA # 15-0612.15"*

1. Drawing No. **KAY0003**, titled "SP-600 16" Aluminum Soffit – Vented", sheets 1 through 4 of 4, dated 12/27/2011, with revision 2 dated 03/17/2015, prepared by the manufacturer, signed and sealed by Robert J. Amoruso, P.E.

B. TESTS *"Submitted under NOA # 17-0404.03"*

1. Test report on Wind Driven Rain Resistance Test per TAS 100(A) of Model SP-600 16" Aluminum Vented Soffit prepared by Fenestration Testing Laboratory, Inc., Test Report No. **9457**, dated 03/28/2017, signed and sealed by Idalmis Ortega, P.E.
"Submitted under NOA # 05-0802.03"
2. Test report of Cyclic Load Pressure Test per TAS 203 and test report of Uniform Static Load Test per TAS 202 on Aluminum Soffit SP-600 prepared by Architectural Testing, Test Report No. **55982.02-122-18**, dated 07/18/2005, signed and sealed by S. M. Urich, P.E.
3. Test report of Tensile Test per ASTM E8 on Aluminum Vented Soffit, prepared by Architectural Testing, Test Report No. **55982.03-122-18**, dated 04/26/2005, signed and sealed by Joseph A. Reed, P.E.

C. CALCULATIONS *"Submitted under NOA # 12-0124.04"*

1. Anchor calculations prepared by PTC Product Design Group, LLC, dated 12/27/2011, signed and sealed by Robert J. Amoruso, P.E.
"Submitted under NOA # 05-0802.03"
2. Anchor calculations prepared by H. R. Engineering, Inc., pages 1 through 3, dated 07/25/2005, signed and sealed by Allen N. Reeves, P.E.

D. QUALITY ASSURANCE

1. Miami-Dade Department of Regulatory and Economic Resources (RER).

E. MATERIAL CERTIFICATIONS

1. None.

F. STATEMENTS *"Submitted under NOA # 15-0612.15"*

1. Statement letter of code conformance to 5th edition (2014) FBC and of no financial interest, prepared by PTC Product Design Group, LLC, dated 03/17/2015, signed and sealed by Robert J. Amoruso, P.E.
"Submitted under NOA # 12-0124.04"
2. Statement letter of code conformance to 2010 FBC and no financial interest, prepared by PTC Product Design Group, LLC, dated 01/19/2012, signed and sealed by Robert J. Amoruso, P.E.
"Submitted under NOA # 11-0325.03"
3. Distributor agreement dated 04/25/2011.



Carlos M. Utrera, P.E.
Product Control Examiner
NOA No. 23-0908.07
Expiration Date: June 1, 2026
Approval Date: October 26, 2023

NOTICE OF ACCEPTANCE: EVIDENCE SUBMITTED

2. Evidence submitted under NOA # 17-1221.31

A. DRAWINGS

1. Drawing No. **KAY0003**, titled "SP-600 16" Aluminum Soffit – Vented", sheets 1 through 4 of 4, dated 12/27/2011, with revision 3 dated 12/01/2017, prepared by PTC, LLC, signed and sealed by Robert J. Amoruso, P.E.

B. TESTS

1. None.

C. CALCULATIONS

1. None.

D. QUALITY ASSURANCE

1. Miami-Dade Department of Regulatory and Economic Resources (RER)

E. MATERIAL CERTIFICATIONS

1. None.

F. STATEMENTS

1. Statement letter of code conformance to 6th edition (2017) FBC and of no financial interest, prepared by PTC Product Design Group, LLC, dated 12/01/2017, signed and sealed by Robert J. Amoruso, P.E.



Carlos M. Utrera, P.E.
Product Control Examiner
NOA No. 23-0908.07
Expiration Date: June 1, 2026
Approval Date: October 26, 2023

NOTICE OF ACCEPTANCE: EVIDENCE SUBMITTED

3. Evidence submitted under NOA # 20-1013.08

A. DRAWINGS

1. Drawing No. **KAY0003**, titled "SP-600 16" Aluminum Soffit – Vented", sheets 1 through 4 of 4, dated 12/27/2011, with revision 4 dated 09/30/2020, prepared by PTC, LLC, signed and sealed by Robert J. Amoruso, P.E.

B. TESTS

1. None.

C. CALCULATIONS

1. None.

D. QUALITY ASSURANCE

1. Miami-Dade Department of Regulatory and Economic Resources (RER)

E. MATERIAL CERTIFICATIONS

1. None.

F. STATEMENTS

1. Statement letter of code conformance to the 7th edition (2020) FBC and of no financial interest, prepared by PTC Product Design Group, LLC, dated 09/30/2020, signed and sealed by Robert J. Amoruso, P.E.
2. Testing contract letter issued by Molimo LLC, dated 01/19/2021, signed by Michael D. Stremmel, P.E.



Carlos M. Utrera, P.E.
Product Control Examiner
NOA No. 23-0908.07
Expiration Date: June 1, 2026
Approval Date: October 26, 2023

NOTICE OF ACCEPTANCE: EVIDENCE SUBMITTED

4. Evidence submitted under NOA # 21-1208.04 and new

A. DRAWINGS

1. Drawing No. **KAY0003**, titled "SP-600 16" Aluminum Soffit – Vented", sheets 1 through 4 of 4, dated 12/27/2011, with revision **6** dated 08/31/2023, prepared by PTC, LLC, signed and sealed by Robert J. Amoruso, P.E.

B. TESTS

1. Test reports on 1) Uniform Static Air Pressure Test, Loading per FBC TAS 202-94
2) Cyclic Wind Pressure Loading per FBC, TAS 203-94
along with marked-up drawings and installation diagram of Model SP-600 16" Aluminum Vented Soffit, by Molimo Architectural Product Testing, Report No. **2846.01-106-11**, dated 04/14/2021, signed and sealed by Michael D. Stremmel, P.E.

C. CALCULATIONS

1. None.

D. QUALITY ASSURANCE

1. Miami-Dade Department of Regulatory and Economic Resources (RER).

E. MATERIAL CERTIFICATIONS

1. None.

F. STATEMENTS

1. Statement letter of code conformance to the 8th edition (2023) of the FBC, issued by PTC Product Design Group, LLC, dated 08/31/2023, signed and sealed by Robert J. Amoruso, P.E.
2. Statement letter of no financial interest, issued by PTC Product Design Group, LLC, dated 08/31/2023, signed and sealed by Robert J. Amoruso, P.E.
3. Statement letter of code conformance to the 7th edition (2020) of the FBC and of no financial interest, issued by PTC Product Design Group, LLC, dated 11/15/2021, signed and sealed by Robert J. Amoruso, P.E.



Carlos M. Utrera, P.E.
Product Control Examiner
NOA No. 23-0908.07
Expiration Date: June 1, 2026
Approval Date: October 26, 2023