## 37149



DATE: Monday, October 08, 2018

**TO: Columbia County Building Department** 

FROM: Tim Delbene - Donald F. Lee & Associates

**CC: Bryan Zecher Construction** 

RE: Floor Elevation - Lot 65, Oaks of Lake City Phase 2

This is to certify that an elevation was obtained on the proposed floor (stem wall) for a dwelling under construction on the above referenced lands. The results are as follows:

FLOOR ELEVATION (stem wall): 76.88 feet

## DATUM: NAVD 1988

The elevation was projected from a Benchmark set by this Company from original design elevations for this development. The plat of the development (Oaks of Lake City Phase 2) indicates that the minimum floor elevation for this lot should be 76.0 feet.

why A. Delbene, PSM rida Regi Cert. No. LS 5594